

**NYC Department of Education**  
**Building Condition Assessment Survey 2018 - 2019**

Mechanical Inspection

**K331**

**Asset:** P.S./I.S. 30 MARY WHITE OVINGTON - BROOKLYN, 7002 4TH AVENUE, New York,  
**11209**

Inspection Id	Inspection Type	Time In	Last Edited
ME : K331	Mechanical	2019-03-11 8:41 AM	2019-04-15 4:19 PM

**Asset Data**

Question	Answer
Are there fuel tanks?	Yes
Total # of above ground tanks	1
Total capacity of all above ground tanks in gal.	275
Total # of below ground tanks	0
Total capacity of all below ground tanks in gal.	0
Total # of water main service entries to the asset	3
MERs/Fan Rooms Locations	None
Are there any spaces with Missing or Defective CO Detectors?	No
Are there any Emergency Stop Switches with Missing Hammers?	No
Are there any Painted/Obstructed Sprinkler Heads?	Yes
Location(s)	Emergency Generator Room C28
Have any Systems/Major Building Components been upgraded?	No

**Priority Condition**

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
No	Defective Fire/Smoke Damper	Defective Fire/Smoke Damper	VENTILATION   Metal Ductwork	Room C9	Joseph Egitto	Fireman	Sent to DSF	

**Inspection**

Question	Response
<b>Mechanical</b>	
<b>AIR CONDITIONING</b>	Inspected
<b>Chilled Water System</b>	Does not Exist
<b>Condenser Water Distribution: Piping, Pumps and Auxiliaries</b>	Does not Exist
<b>Cooling Coil in Ductwork</b>	Does not Exist
<b>Cooling Tower</b>	Does not Exist
<b>DX Split System</b>	Inspected
<b>Indoor Unit</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Outdoor Unit</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Dry Cooler</b>	Does not Exist
<b>Packaged / Rooftop Unit</b>	Inspected
Instance	Main Roof
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Source of Heating	Gas
Instance Manufacturer	Seasons4
Equipment	RTU-1
Capacity/Size Quantity	48

**NYC Department of Education  
Building Condition Assessment Survey 2018 - 2019**

Mechanical Inspection

**K331**

<b>Question</b>	<b>Response</b>
<b>AIR CONDITIONING</b>	
<b>Packaged / Rooftop Unit</b>	
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	2013
Source of Installation	Documented
Deficiency	OVER 20 TONS: DEFECTIVE GAS FURNACE
Deficiency Location/Instance	Main Roof
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance	Main Roof
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Source of Heating	Gas
Instance Manufacturer	Seasons4
Equipment	RTU-2
Capacity/Size Quantity	38
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	2013
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Main Roof
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Source of Heating	Gas
Instance Manufacturer	Seasons4
Equipment	RTU-3
Capacity/Size Quantity	49
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	2013
Source of Installation	Documented
Deficiency	OVER 20 TONS: DEFECTIVE CONTROLS
Deficiency Location/Instance	Main Roof
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.

**NYC Department of Education**  
**Building Condition Assessment Survey 2018 - 2019**

Mechanical Inspection

K331

Question	Response
<b>AIR CONDITIONING</b>	
<b>Packaged / Rooftop Unit</b>	
Instance	Main Roof
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Source of Heating	Gas
Instance Manufacturer	Seasons4
Equipment	RTU-4
Capacity/Size Quantity	93
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	2013
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Main Roof
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Source of Heating	Gas
Instance Manufacturer	Seasons4
Equipment	RTU-5
Capacity/Size Quantity	107
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	2013
Source of Installation	Documented
Deficiency	OVER 20 TONS: DEFECTIVE GAS FURNACE
Deficiency Location/Instance	Main Roof
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance	Main Roof
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Source of Heating	Gas
Instance Manufacturer	Seasons4
Equipment	RTU-6
Capacity/Size Quantity	108
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	2013
Source of Installation	Documented
Deficiency	OVER 20 TONS: DEFECTIVE GAS FURNACE

**NYC Department of Education**  
**Building Condition Assessment Survey 2018 - 2019**

Mechanical Inspection

K331

Question	Response
<b>AIR CONDITIONING</b>	
<b>Packaged / Rooftop Unit</b>	
Deficiency Location/Instance	Main Roof
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>Packaged Terminal A/C</b>	Does not Exist
<b>Refrigerant Piping</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Return Fan</b>	Does not Exist
<b>CENTRAL ACID WASTE NEUTRALIZING TANK</b>	Does not Exist
<b>CLIMATE CONTROL SYSTEM</b>	Inspected
<b>BMS</b>	Inspected
Instance	Throughout
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Installation Year	2013
Source of Installation	Documented
Deficiency	No deficiencies recorded
<b>Pneumatic System</b>	Does not Exist
<b>Hybrid System</b>	Does not Exist
<b>Electric System</b>	Does not Exist
<b>COMPACTOR</b>	Does not Exist
<b>CONVEYING</b>	Inspected
<b>Dumbwaiter</b>	Does not Exist
<b>Elevator</b>	Inspected
Are all the existing elevators operable?	Yes
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Escalator</b>	Does not Exist
<b>Non-auditorium Handicap Lift - Vertical</b>	Does not Exist
<b>Non-auditorium Handicap Lift - Stair</b>	Does not Exist
<b>Ash Hoist</b>	Does not Exist
<b>Sidewalk Elevator</b>	Does not Exist
<b>DOMESTIC WATER SYSTEM</b>	Inspected
<b>Domestic Cold Water System</b>	Inspected
<b>Gravity System</b>	Does not Exist
<b>Pressure Booster System</b>	Inspected
<b>Electric Pressure Booster System</b>	Inspected
Instance	Water Meter Room C24
Instance Condition	2 - Between Good and Fair

**NYC Department of Education**  
**Building Condition Assessment Survey 2018 - 2019**

Mechanical Inspection

K331

Question	Response
<b>DOMESTIC WATER SYSTEM</b>	
<b>Domestic Cold Water System</b>	
<b>Pressure Booster System</b>	
<b>Electric Pressure Booster System</b>	
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Liquitrol
Equipment	N/A
Capacity/Size Quantity	2
Capacity/Size UOM	Total # Pumps
Capacity/Size2 Quantity	20
Capacity/Size2 UOM	Total Pumps HP
Source of Capacity/Size	Documented
Installation Year	2013
Source of Installation	Documented
Deficiency	DEFECTIVE CONTROLS
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>Hydraulic/Pneumatic Booster System</b>	Does not Exist
<b>Water Service</b>	Inspected
Instance	Valve/Meter Room C16
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	No deficiencies recorded
Instance	Water Meter Room C24
Instance Condition	1 - Good
Instance Quantity	2
Instance Quantity Uom	EACH
Deficiency	No deficiencies recorded
<b>Domestic Hot Water System</b>	Inspected
<b>Domestic Hot Water Remote Storage Tank</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Domestic Water Heat Exchanger</b>	Does not Exist
<b>Electric Domestic Water Heater</b>	Does not Exist
<b>Gas Fired Domestic Water Heater</b>	Inspected
Instance	Boiler Room
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Laars
Equipment	N/A
Capacity/Size Quantity	300

**NYC Department of Education**  
**Building Condition Assessment Survey 2018 - 2019**

Mechanical Inspection

K331

Question	Response
<b>DOMESTIC WATER SYSTEM</b>	
<b>Domestic Hot Water System</b>	
<b>Gas Fired Domestic Water Heater</b>	
Capacity/Size UOM	MBH Input
Capacity/Size2 Quantity	0
Capacity/Size2 UOM	Gallons
Source of Capacity/Size	Documented
Installation Year	2013
Source of Installation	Documented
Deficiency	No deficiencies recorded
<b>Oil Fired Domestic Water Heater</b>	Does not Exist
<b>Domestic Water Distribution Piping</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>DRAIN/WASTE/VENT AND STORM SYSTEM</b>	
<b>Interior Storm Piping</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Sewage/Waste/Vent Piping</b>	Inspected
Condition	1 - Good
Deficiency	SEWAGE/WASTE PIPING: DEFECTIVE/LEAKS
Deficiency Location/Instance	Slop Sink 420A
Deficiency Quantity	10
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>Sewage Ejector Pump</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Sump Pump</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)</b>	
Does not Exist	
<b>FIXTURES</b>	
Inspected	
<b>Staff And Other</b>	
Inspected	
<b>Janitor Sink</b>	
Inspected	
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Lavatory/Sink</b>	
Inspected	
Condition	1 - Good
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	Gymnasium Coach Office - Toilet Room 310C
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3

**NYC Department of Education  
Building Condition Assessment Survey 2018 - 2019**

Mechanical Inspection

K331

Question	Response
<b>FIXTURES</b>	
<b>Staff And Other</b>	
<b>Lavatory/Sink</b>	Inspected
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>Toilet</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Urinal</b>	Does not Exist
<b>Student</b>	Inspected
<b>Drinking Fountain</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	Gymnasium
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>Lavatory/Sink</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Locker Room Shower</b>	Does not Exist
<b>Sink And Fountain Combo Unit</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	Room 119
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>Toilet</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Urinal</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>GAS FIRED FURNACE</b>	Does not Exist
<b>GAS SERVICE</b>	Inspected
<b>Gas Distribution Piping</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Gas Meter Room Exhaust Fan</b>	Inspected

**NYC Department of Education**  
**Building Condition Assessment Survey 2018 - 2019**

Mechanical Inspection

K331

Question	Response
<b>GAS SERVICE</b>	
<b>Gas Meter Room Exhaust Fan</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Gas Meter Room Vent</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Gas Pressure Booster</b>	Does not Exist
<b>CO/Gas Leak Detection</b>	Inspected
Instance	Boiler Room, Gas Meter Room
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Installation Year	2013
Source of Installation	Documented
Deficiency	No deficiencies recorded
<b>HEATING</b>	Inspected
<b>Heating Coil In Ductwork</b>	Does not Exist
<b>Hydronic Heating</b>	Inspected
<b>Hydronic Hot Water Distribution: Piping, Pumps and Auxiliaries</b>	Inspected
Condition	1 - Good
Deficiency	PUMP: DEFECTIVE
Deficiency Location/Instance	Boiler Room (defective bearings)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo 1	No photo recorded
Violations	No violations recorded.
<b>Backflow Preventer</b>	Does not Exist
<b>Hot Water Heat Exchanger</b>	Does not Exist
<b>Radiator/Convactor/Fin Tube</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Steam Heating</b>	Does not Exist
<b>Steam supplied by External Sources</b>	Does not Exist
<b>Unit Heater/Cabinet Heater</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>HEATING PLANT</b>	Inspected
Replacement Quantity	2,086
Replacement Uom	MBH Net
Instance on Penthouse	Inspected
Burner Type	Gas
Heating Plant Oil Number	N/A
<b>Boiler Auxiliaries</b>	Inspected
Instance on Penthouse	Inspected
<b>Boiler Auxiliary Piping</b>	



**NYC Department of Education  
Building Condition Assessment Survey 2018 - 2019**

Mechanical Inspection

K331

Question	Response
<b>HEATING PLANT</b>	
<b>Boiler Auxiliaries</b>	
<b>Boiler Auxiliary Piping</b>	
Instance on Penthouse	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Boiler Emergency Stop Switch</b>	
Instance on Penthouse	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Boiler Feedwater System</b>	
Instance on Penthouse	Does not Exist
<b>Boiler Feedwater Treatment(Automatic)</b>	
Instance on Penthouse	Does not Exist
<b>Boiler Flue Exhaust</b>	
Instance on Penthouse	Does not Exist
<b>Boiler Make-up Water Backflow Preventer</b>	
Instance on Penthouse	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DEFECTIVE RPZ
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>Boiler Room Steam And Condensate Piping</b>	
Instance on Penthouse	Does not Exist
<b>Boiler Safety Valve</b>	
Instance on Penthouse	Does not Exist
<b>Boiler System</b>	
Instance on Penthouse	Inspected
<b>Coal-fired Boiler</b>	
Instance on Penthouse	Does not Exist
<b>Hot Water Boiler</b>	
Instance on Penthouse	Does not Exist
<b>Modular Boiler</b>	
Instance on Penthouse	Inspected
Instance	Boiler Room
Instance Condition	1 - Good
Instance Quantity	1,043
Instance Quantity Uom	MBH Net
Instance Manufacturer	AERCO
Equipment	164411-01
Capacity/Size Quantity	1,500
Capacity/Size UOM	MBH Input
Source of Capacity/Size	Documented

**NYC Department of Education**  
**Building Condition Assessment Survey 2018 - 2019**

Mechanical Inspection

K331

Question	Response
<b>HEATING PLANT</b>	
<b>Boiler System</b>	
<b>Modular Boiler</b>	
Installation Year	2013
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Boiler Room
Instance Condition	1 - Good
Instance Quantity	1,043
Instance Quantity Uom	MBH Net
Instance Manufacturer	AERCO
Equipment	164411-02
Capacity/Size Quantity	1,500
Capacity/Size UOM	MBH Input
Source of Capacity/Size	Documented
Installation Year	2013
Source of Installation	Documented
Deficiency	No deficiencies recorded
<b>Steam Boiler</b>	
Instance on Penthouse	Does not Exist
<b>Fuel System</b>	Inspected
Instance on Penthouse	Inspected
<b>Boiler Fresh Air Louver/Damper</b>	
Instance on Penthouse	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Burner/Burner Control Panel</b>	
Instance on Penthouse	Does not Exist
<b>Fuel Oil Storage/Supply System</b>	
Instance on Penthouse	Does not Exist
<b>Gas Trains And Vent At The Boiler</b>	
Instance on Penthouse	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Enclosed IDF Room</b>	
Instance on Room 312	Inspected
Instance on Rooms C10, 108, 410	Inspected
<b>Dedicated A/C Equipment</b>	
Instance on Rooms C10, 108, 410	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 312	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE
Deficiency Location/Instance	Room 312
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2

**NYC Department of Education**  
**Building Condition Assessment Survey 2018 - 2019**

Mechanical Inspection

K331

<b>Question</b>	<b>Response</b>
<b>Enclosed IDF Room</b>	Inspected
<b>Dedicated A/C Equipment</b>	
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>KITCHEN</b>	Inspected
Instance on Basement	Inspected
<b>CO Detector</b>	Inspected
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Gas System</b>	Inspected
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Grease Trap</b>	Inspected
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Hood</b>	Inspected
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Hood Exhaust Ductwork</b>	Inspected
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Hood Exhaust Fan</b>	Inspected
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Hood Fire Suppression System</b>	Inspected
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Hot Water Temperature Booster</b>	Inspected
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Kitchen Sink</b>	Inspected
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>MDF Room</b>	Inspected
Instance on Room 210	Inspected
<b>Dedicated A/C Equipment</b>	Inspected
Instance on Room 210	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>SCIENCE DEMO ROOM</b>	Does not Exist
<b>SCIENCE LAB</b>	Inspected

**NYC Department of Education**  
**Building Condition Assessment Survey 2018 - 2019**

Mechanical Inspection

K331

<b>Question</b>	<b>Response</b>
<b>SCIENCE LAB</b>	
Instance on Room 321	Inspected
Alternative use	No
<b>Acid Waste Neutralizing Tank</b>	Inspected
Instance on Room 321	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>CO Detector</b>	Not Required
Instance on Room 321	Not Required
<b>Emergency Shower</b>	Does not Exist
Instance on Room 321	Does not Exist
<b>Eye Wash</b>	Inspected
Instance on Room 321	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Hood Exhaust Ductwork</b>	Does not Exist
Instance on Room 321	Does not Exist
<b>Hood Exhaust Fan</b>	Does not Exist
Instance on Room 321	Does not Exist
<b>Fixed Laboratory Hood</b>	Does not Exist
Instance on Room 321	Does not Exist
<b>Laboratory Sink</b>	Inspected
Instance on Room 321	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Make-up Air Unit</b>	Does not Exist
Instance on Room 321	Does not Exist
<b>SCIENCE PREP ROOM</b>	
Instance on Room 321A	Inspected
Alternative use	No
<b>Acid Waste Neutralizing Tank</b>	Does not Exist
Instance on Room 321A	Does not Exist
<b>CO Detector</b>	Not Required
Instance on Room 321A	Not Required
<b>Emergency Shower</b>	Does not Exist
Instance on Room 321A	Does not Exist
<b>Eye Wash</b>	Does not Exist
Instance on Room 321A	Does not Exist
<b>Hood Exhaust Ductwork</b>	Does not Exist
Instance on Room 321A	Does not Exist
<b>Hood Exhaust Fan</b>	Does not Exist
Instance on Room 321A	Does not Exist
<b>Fixed Laboratory Hood</b>	Does not Exist
Instance on Room 321A	Does not Exist
<b>Laboratory Sink</b>	Inspected
Instance on Room 321A	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Make-up Air Unit</b>	Does not Exist

**NYC Department of Education  
Building Condition Assessment Survey 2018 - 2019**

Mechanical Inspection

K331

<b>Question</b>	<b>Response</b>
<b>SCIENCE PREP ROOM</b>	Inspected
<b>Make-up Air Unit</b>	Does not Exist
Instance on Room 321A	Does not Exist
<b>SPRINKLERS, STANDPIPE, FIRE SYSTEM</b>	Inspected
<b>Dry Sprinkler Alarm Valve Assembly</b>	Does not Exist
<b>Wet Sprinkler Alarm Valve Assembly</b>	Does not Exist
<b>Fire Booster Pump Assembly</b>	Inspected
Condition	1 - Good
Deficiency	DEFECTIVE FIRE BOOSTER PUMP
Deficiency Location/Instance	Fire Pump Room C01 (leaking)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>Roof Tank</b>	Does not Exist
<b>Siamese Connection</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Sprinkler Head</b>	Inspected
Condition	1 - Good
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Emergency Generator Room C28
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>Sprinkler Piping</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Standpipe System</b>	Inspected
<b>Hose Valve Assembly</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Piping</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Water Gong</b>	Does not Exist
<b>SWIMMING POOL</b>	Does not Exist
<b>VENTILATION</b>	Inspected
<b>Exhaust Fan</b>	Inspected
Approximate Total # of Fans	1-25
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded

**NYC Department of Education**  
**Building Condition Assessment Survey 2018 - 2019**

Mechanical Inspection

K331

Question	Response
<b>VENTILATION</b>	
<b>Heating And Ventilating Unit</b>	Does not Exist
<b>Metal Ductwork</b>	Inspected
Condition	1 - Good
Deficiency	DEFECTIVE REGISTER/DIFFUSER
Deficiency Location/Instance	Gymnasium
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DEFECTIVE FIRE/SMOKE DAMPER
Deficiency Location/Instance	Room C9
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>Supply Fan</b>	Inspected
Approximate Total # of Fans	1-5
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Unit Ventilator</b>	Does not Exist