

**NYC Department of Education
Building Condition Assessment Survey 2017 - 2018**

Electrical Inspection

K541

Asset: DEWEY AF - BROOKLYN, 50 AVENUE X, New York, 11223

Inspection Id	Inspection Type	Time In	Last Edited
EE : K541	Electrical	2017-12-11 12:51 PM	2018-03-29 4:26 PM

Asset Data

Question	Answer
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	No
Water Penetration in Electrical Room?	No
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Athletic Field (Exterior Lighting)
	Years: 2004, 2011

DEDICATED INTERCOMS IN FIRE RESCUE AREAS

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	No

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
No condition recorded								

Inspection

Question	Response
Electrical	
ATHLETIC FIELD	Inspected
Exterior Lighting	Inspected
Replacement Quantity	9
Replacement Uom	EACH
Condition	4 - Between Fair and Poor
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	9
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Local Sound System	Does not Exist
Scoreboard	Inspected
Instance	East side of the field
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	No deficiencies recorded
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	Does not Exist
LOCKER ROOM	Does not Exist
TOILET ROOM - STAFF	Does not Exist
TOILET ROOM - STUDENT	Does not Exist
AUXILIARY SIGNAL/BELL SYSTEM	Does not Exist
EMERGENCY DC STANDBY BATTERY POWER	Does not Exist
EMERGENCY GENERATOR SET	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2017 - 2018

Electrical Inspection

K541

Question	Response
EMERGENCY LIGHT/EXIT LIGHT PANEL	Does not Exist
EMERGENCY LIGHTING	Does not Exist
EXIT LIGHT	Does not Exist
EXIT/EMERGENCY LIGHT	Does not Exist
FIRE ALARM SYSTEM	Does not Exist
GROUNDING SYSTEM	Does not Exist
LAN	Does not Exist
MOTOR CONTROL CENTER	Does not Exist
MOTOR STARTER/CONTACTOR	Does not Exist
PANEL BOARD	Does not Exist
PUBLIC ADDRESS SYSTEM	Does not Exist
SECURITY	Does not Exist
SERVICE SWITCH	Does not Exist
SWITCHBOARD	Does not Exist
TELEPHONE SYSTEM	Does not Exist
TRANSFORMER	Does not Exist
TV SYSTEM	Does not Exist