

**NYC Department of Education**  
**Building Condition Assessment Survey 2017 - 2018**

Electrical Inspection

K555

**Asset: BKLYN COLL ACAD (AT BKLYN COLL)-K, 2900 BEDFORD AVENUE, New York, 11210**

Inspection Id	Inspection Type	Time In	Last Edited
EE : K555	Electrical	2018-04-16 12:22 PM	2018-04-16 2:14 PM

Asset Data

Question	Answer
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	No
Water Penetration in Electrical Room?	No
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Fire Alarm System, IPDVS/CCTV System
	Years: 2017
	Systems: Computer Lab (Raceway With Receptacles), Molded Case Circuit Breaker Panel Board
	Years: 2011
	Systems: LAN
	Years: 2009
	Systems: Interior Lighting
	Years: 1995

**DEDICATED INTERCOMS IN FIRE RESCUE AREAS**

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	No

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
No condition recorded								

Inspection

Question	Response
<b>Electrical</b>	
<b>AUDITORIUM</b>	Does not Exist
<b>CAFETERIA</b>	Does not Exist
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	Inspected
<b>Lighting</b>	Inspected
Does a Chandelier exist?	No
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Does not Exist
<b>Surface Mounted</b>	Does not Exist
<b>Recessed Mounted</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	Does not Exist
<b>Lighting Fixture - Incandescent</b>	Does not Exist
<b>Lighting Fixture - LED</b>	Does not Exist
<b>COMPUTER LAB</b>	Inspected
Instance on Room 0301D	Inspected
Power Panel	Yes
<b>Lighting</b>	Inspected
Instance on Room 0301D	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
Instance on Room 0301D	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2017 - 2018**

Electrical Inspection

K555

Question	Response
<b>COMPUTER LAB</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	Does not Exist
Instance on Room 0301D	Does not Exist
<b>Surface Mounted</b>	Does not Exist
Instance on Room 0301D	Does not Exist
<b>Recessed Mounted</b>	Inspected
Instance on Room 0301D	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
Instance on Room 0301D	Does not Exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 0301D	Does not Exist
<b>Lighting Fixture - LED</b>	
Instance on Room 0301D	Does not Exist
<b>Raceway With Receptacles</b>	Inspected
Instance on Room 0301D	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>GYMNASIUM</b>	Does not Exist
<b>KITCHEN</b>	Does not Exist
<b>LIBRARY</b>	Does not Exist
<b>LOCKER ROOM</b>	Does not Exist
<b>MULTIPURPOSE ROOM</b>	Does not Exist
<b>SCIENCE DEMO ROOM</b>	Does not Exist
<b>SCIENCE LAB</b>	Does not Exist
<b>SCIENCE PREP ROOM</b>	Does not Exist
<b>SWIMMING POOL</b>	Does not Exist
<b>TOILET ROOM - STAFF</b>	Does not Exist
<b>TOILET ROOM - STUDENT</b>	Does not Exist
<b>AUXILIARY SIGNAL/BELL SYSTEM</b>	Does not Exist
<b>EMERGENCY DC STANDBY BATTERY POWER</b>	Does not Exist
<b>EMERGENCY GENERATOR SET</b>	Does not Exist
<b>EMERGENCY LIGHT/EXIT LIGHT PANEL</b>	Does not Exist
<b>EMERGENCY LIGHTING</b>	Inspected
<b>Battery Pack</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Non Battery Pack</b>	Does not Exist
<b>EXIT LIGHT</b>	Inspected
<b>Battery Pack</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Non Battery Pack</b>	Does not Exist
<b>EXIT/EMERGENCY LIGHT</b>	Does not Exist
<b>CITY FIRE ALARM SYSTEM</b>	Does not Exist

**NYC Department of Education  
Building Condition Assessment Survey 2017 - 2018**

Electrical Inspection

K555

<b>Question</b>	<b>Response</b>
<b>FIRE ALARM SYSTEM</b>	Inspected
Replacement Quantity	8,000
Replacement Uom	S.F.
<b>Bell/Horn</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Strobe</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Manual Pull Station</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Fan Shutdown Control</b>	Does not Exist
<b>Duct Smoke Detector</b>	Does not Exist
<b>Area Smoke Detector</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>CO Detector</b>	Does not Exist
<b>Heat Detector</b>	Does not Exist
<b>Elevator Recall</b>	Does not Exist
<b>Magnetic Door Holder/Contactor</b>	Does not Exist
<b>Fused Cutout Panel</b>	Does not Exist
<b>Fire Alarm Digital Communicator</b>	Does not Exist
<b>Main Panel</b>	Does not Exist
<b>Sub-Panel</b>	Does not Exist
<b>Remote Annunciator</b>	Does not Exist
<b>Sprinkler Flow/Air Pressure Switch</b>	Does not Exist
<b>Tamper Flow Switch/Chain</b>	Does not Exist
<b>GROUNDING SYSTEM</b>	Does not Exist
<b>INTERCOM SYSTEM</b>	Does not Exist
<b>LAN</b>	Inspected
<b>Local Distribution Frame (I/LDF)</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Main Equipment Rack (MDF)</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>LIGHTNING PROTECTION</b>	Does not Exist
<b>MOTOR CONTROL CENTER</b>	Does not Exist
<b>MOTOR STARTER/CONTACTOR</b>	Does not Exist
<b>PANEL BOARD</b>	Inspected
<b>Fused Disconnect Switch Type</b>	Does not Exist
<b>Fused Knife Switch Type</b>	Does not Exist
<b>Fused Toggle Switch Type</b>	Does not Exist
<b>Molded Case Circuit Breaker Type</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>PUBLIC ADDRESS SYSTEM</b>	Does not Exist

**NYC Department of Education**  
**Building Condition Assessment Survey 2017 - 2018**

Electrical Inspection

K555

<b>Question</b>	<b>Response</b>
<b>SECURITY</b>	Inspected
<b>IPDVS/CCTV System</b>	Inspected
Replacement Quantity	8,000
Replacement Uom	S.F.
Installation Year	2017
Source of Installation	Custodial Staff
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Intrusion Alarm System</b>	Does not Exist
<b>Lighting - Security</b>	Does not Exist
<b>SERVICE SWITCH</b>	Does not Exist
<b>SWITCHBOARD</b>	Does not Exist
<b>TELEPHONE SYSTEM</b>	Inspected
<b>PBX/Intercom</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Standard</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>TRANSFORMER</b>	Does not Exist
<b>TV SYSTEM</b>	Inspected
Cable System Exist?	Yes
Operational?	Yes
<b>Main Equipment Rack</b>	Does not Exist