

**NYC Department of Education
Building Condition Assessment Survey 2017 - 2018**

Mechanical Inspection

K849

Asset: P.S. 134 - BROOKLYN, 4001 18 AVENUE, New York, 11218

Inspection Id	Inspection Type	Time In	Last Edited
ME : K849	Mechanical	2018-04-02 12:27 PM	2018-04-09 4:46 PM

Asset Data

Question	Answer
Are there fuel tanks?	Yes
Total # of above ground tanks	1
Total capacity of all above ground tanks in gal.	5000
Total # of below ground tanks	0
Total capacity of all below ground tanks in gal.	0
Total # of water main service entries to the asset	2
MERs/Fan Rooms Locations	None
Are there any spaces with Missing or Defective CO Detectors?	No
Are there any Emergency Stop Switches with Missing Hammers?	No
Are there any Painted/Obstructed Sprinkler Heads?	Yes
Location(s)	Room B06
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: MDF Room - Dedicated A/C Equipment (Window A/C)
	Years: 2016
	Systems: F&T/Steam Drip Traps; Terminal Unit Thermostatic Traps
	Years: 2014
	Systems: Climate Control System - Temperature Control Thermostats, Terminal Unit Control Valves
	Years: 2011
	Systems: Water Services
	Years: 2010

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
No condition recorded								

Inspection

Question	Response
Mechanical	
AIR CONDITIONING	Does not Exist
CENTRAL ACID WASTE NEUTRALIZING TANK	Does not Exist
CLIMATE CONTROL SYSTEM	Inspected
BMS	Does not Exist
Pneumatic System	Inspected
Instance	Throughout
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Deficiency	DEFECTIVE TERMINAL UNIT CONTROL VALVE
Deficiency Location/Instance	Gymnasium
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2

NYC Department of Education
Building Condition Assessment Survey 2017 - 2018

Mechanical Inspection

K849

Question	Response
CLIMATE CONTROL SYSTEM	
Pneumatic System	
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Hybrid System	Does not Exist
Electric System	Does not Exist
COMPACTOR	Does not Exist
CONVEYING	Does not Exist
DOMESTIC WATER SYSTEM	Inspected
Domestic Cold Water System	Inspected
Gravity System	Does not Exist
Pressure Booster System	Does not Exist
Water Service	Inspected
Instance	Basement Music Room
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	WATER MAIN: MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	Basement Music Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance	Cafeteria
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	WATER MAIN: MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	Cafeteria
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Domestic Hot Water System	Inspected
Domestic Hot Water Remote Storage Tank	Does not Exist
Domestic Water Heat Exchanger	Does not Exist
Electric Domestic Water Heater	Does not Exist
Gas Fired Domestic Water Heater	Inspected
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH

**NYC Department of Education
Building Condition Assessment Survey 2017 - 2018**

Mechanical Inspection

K849

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Hot Water System	
Gas Fired Domestic Water Heater	
Instance Manufacturer	Precision
Equipment	N/A
Capacity/Size Quantity	400
Capacity/Size UOM	MBH Input
Capacity/Size2 Quantity	400
Capacity/Size2 UOM	Gallons
Source of Capacity/Size	Inspector Estimate
Installation Year	2001
Source of Installation	Documented
Deficiency	No deficiencies recorded
Oil Fired Domestic Water Heater	Does not Exist
Domestic Water Distribution Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
DRAIN/WASTE/VENT AND STORM SYSTEM	Inspected
Interior Storm Piping	Does not Exist
Sewage/Waste/Vent Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sewage Ejector Pump	Does not Exist
Sump Pump	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	Does not Exist
FIXTURES	Inspected
Staff And Other	Inspected
Janitor Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE FLUSHOMETER VALVE
Deficiency Location/Instance	3rd Floor Teacher's Toilet Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo 1	No photo recorded
Violations	No violations recorded.
Urinal	Does not Exist
Student	Inspected

NYC Department of Education
Building Condition Assessment Survey 2017 - 2018

Mechanical Inspection

K849

Question	Response
FIXTURES	
Student	
Drinking Fountain	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Locker Room Shower	Does not Exist
Sink And Fountain Combo Unit	Does not Exist
Toilet	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Urinal	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
GAS FIRED FURNACE	Does not Exist
GAS SERVICE	Inspected
Gas Distribution Piping	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Gas Meter Room Exhaust Fan	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas Meter Room Vent	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Gas Pressure Booster	Does not Exist
CO/Gas Leak Detection	Inspected
Instance	Boiler Room, Gas Meter Room
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Installation Year	2001
Source of Installation	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Boiler Room, Gas Meter Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Deficiency Photo	No photo recorded
Violations	No violations recorded.
HEATING	Inspected
Heating Coil In Ductwork	Does not Exist
Hydronic Heating	Does not Exist
Radiator/Convactor/Fin Tube	Inspected
Condition	3 - Fair

NYC Department of Education
Building Condition Assessment Survey 2017 - 2018

Mechanical Inspection

K849

Question	Response
HEATING	
Radiator/Convactor/Fin Tube	
Deficiency	RADIATOR/CONVECTOR: MISSING GUARD/SHIELD
Deficiency Location/Instance	Room 301
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Steam Heating	Inspected
F&T/Steam Drip Trap	
Condition	Inspected
Deficiency	1 - Good
Deficiency	No deficiencies recorded
MER Steam and Condensate Piping	
Condition	Does not Exist
Steam Condensate Return Piping	
Condition	Inspected
Deficiency	3 - Fair
Deficiency	No deficiencies recorded
Steam Condensate Return Pumping System	
Condition	Inspected
Deficiency	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Steam Piping	
Condition	Inspected
Deficiency	3 - Fair
Deficiency	DEFECTIVE/LEAKS
Deficiency Location/Instance	Basement Boy's Toilet Room, Basement Music Room
Deficiency Quantity	30
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Terminal Unit Thermostatic Trap	
Condition	Inspected
Deficiency	1 - Good
Deficiency	No deficiencies recorded
Steam supplied by External Sources	
Condition	Does not Exist
Unit Heater/Cabinet Heater	
Condition	Inspected
Deficiency	2 - Between Good and Fair
Deficiency	No deficiencies recorded
HEATING PLANT	
Replacement Quantity	Inspected
Replacement Uom	4,128
Instance on Basement	MBH Net
Burner Type	Inspected
Heating Plant Oil Number	Dual Fuel (Gas/Oil)
	2
Boiler Auxiliaries	
Instance on Basement	Inspected
Boiler Auxiliary Piping	
Instance on Basement	Inspected

NYC Department of Education
Building Condition Assessment Survey 2017 - 2018

Mechanical Inspection

K849

Question	Response
HEATING PLANT	
Boiler Auxiliaries	
Boiler Auxiliary Piping	
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Boiler Emergency Stop Switch	
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Boiler Feedwater System	
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Boiler Feedwater Treatment(Automatic)	
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Boiler Flue Exhaust	
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Boiler Make-up Water Backflow Preventer	
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Boiler Room Steam And Condensate Piping	
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Boiler Safety Valve	
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Boiler System	
Instance on Basement	Inspected
Coal-fired Boiler	
Instance on Basement	Does not Exist
Hot Water Boiler	
Instance on Basement	Does not Exist
Modular Boiler	
Instance on Basement	Does not Exist
Steam Boiler	
Instance on Basement	Inspected
Instance	Boiler Room
Instance Condition	2 - Between Good and Fair
Instance Quantity	2,064
Instance Quantity Uom	MBH Net
Instance Manufacturer	A. L. Eastmond & Sons Inc.
Equipment	9165-01
Capacity/Size Quantity	2,064

NYC Department of Education
Building Condition Assessment Survey 2017 - 2018

Mechanical Inspection

K849

Question	Response
HEATING PLANT	
Boiler System	
Steam Boiler	
Capacity/Size UOM	MBH Net
Source of Capacity/Size	Documented
Installation Year	2001
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Boiler Room
Instance Condition	2 - Between Good and Fair
Instance Quantity	2,064
Instance Quantity Uom	MBH Net
Instance Manufacturer	A. L. Eastmond & Sons Inc.
Equipment	9165-02
Capacity/Size Quantity	2,064
Capacity/Size UOM	MBH Net
Source of Capacity/Size	Documented
Installation Year	2001
Source of Installation	Documented
Deficiency	DEFECTIVE AUXILIARY (GAUGES, GASKETS ETC.)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	LEAKY/PLUGGED TUBES
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Fuel System	Inspected
Instance on Basement	Inspected
Boiler Fresh Air Louver/Damper	
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Burner/Burner Control Panel	
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Fuel Oil Storage/Supply System	
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2017 - 2018

Mechanical Inspection

K849

Question	Response
HEATING PLANT	Inspected
Fuel System	
Gas Trains And Vent At The Boiler	
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Enclosed IDF Room	Does not Exist
KITCHEN	Inspected
Instance on Basement	Inspected
CO Detector	Not Required
Instance on Basement	Not Required
Gas System	Does not Exist
Instance on Basement	Does not Exist
Grease Trap	Inspected
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood	Does not Exist
Instance on Basement	Does not Exist
Hood Exhaust Ductwork	Does not Exist
Instance on Basement	Does not Exist
Hood Exhaust Fan	Does not Exist
Instance on Basement	Does not Exist
Hood Fire Suppression System	Does not Exist
Instance on Basement	Does not Exist
Hot Water Temperature Booster	Does not Exist
Instance on Basement	Does not Exist
Kitchen Sink	Inspected
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
MDF Room	Inspected
Instance on Room 200	Inspected
Dedicated A/C Equipment	Inspected
Instance on Room 200	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	Inspected
Instance on Room 301	Inspected
Alternative use	Yes
Acid Waste Neutralizing Tank	Does not Exist
Instance on Room 301	Does not Exist
CO Detector	Not Required
Instance on Room 301	Not Required
Emergency Shower	Does not Exist
Instance on Room 301	Does not Exist
Eye Wash	Does not Exist
Instance on Room 301	Does not Exist
Hood Exhaust Ductwork	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2017 - 2018

Mechanical Inspection

K849

Question	Response
SCIENCE DEMO ROOM	
Hood Exhaust Ductwork	Does not Exist
Instance on Room 301	Does not Exist
Hood Exhaust Fan	Does not Exist
Instance on Room 301	Does not Exist
Fixed Laboratory Hood	Does not Exist
Instance on Room 301	Does not Exist
Laboratory Sink	Inspected
Instance on Room 301	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Make-up Air Unit	Does not Exist
Instance on Room 301	Does not Exist
SCIENCE LAB	Does not Exist
SCIENCE PREP ROOM	Does not Exist
SPRINKLERS, STANDPIPE, FIRE SYSTEM	Inspected
Dry Sprinkler Alarm Valve Assembly	Does not Exist
Wet Sprinkler Alarm Valve Assembly	Does not Exist
Fire Booster Pump Assembly	Does not Exist
Roof Tank	Does not Exist
Siamese Connection	Does not Exist
Sprinkler Head	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Room B06
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Sprinkler Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Standpipe System	Does not Exist
Water Gong	Does not Exist
SWIMMING POOL	Does not Exist
VENTILATION	Inspected
Exhaust Fan	Inspected
Approximate Total # of Fans	1-25
Condition	3 - Fair
Deficiency	No deficiencies recorded
Heating And Ventilating Unit	Does not Exist
Metal Ductwork	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Supply Fan	Does not Exist
Unit Ventilator	Inspected

NYC Department of Education
Building Condition Assessment Survey 2017 - 2018

Mechanical Inspection

K849

Question	Response
VENTILATION	
Unit Ventilator	
Condition	3 - Fair
Deficiency	No deficiencies recorded