

NYC Department of Education
Building Condition Assessment Survey 2017 - 2018

Electrical Inspection

K866

Asset: I.S. 364 AX (POOL&GYM)-BROOKLYN, 1540 VAN SICLEN AVE, New York, 11239

Inspection Id	Inspection Type	Time In	Last Edited
EE : K866	Electrical	2017-11-16 11:20 AM	2017-11-28 2:21 PM

Asset Data

Question	Answer
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	No
Water Penetration in Electrical Room?	No
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Swimming Pool
	Years: Under Construction
	Systems: Exit/Emergency Light
	Years: 2012
	Systems: Motor Starters
	Years: 2011
	Systems: Gymnasium, Toilet Rooms
	Years: 2007
	Systems: Interior Lighting
	Years: 1997
	Systems: Fire Alarm System
	Years: 1996

DEDICATED INTERCOMS IN FIRE RESCUE AREAS

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	No

Priority Condition

Priority Condition Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
No condition recorded								

Inspection

Question	Response
Electrical	
AUDITORIUM	Does not Exist
CAFETERIA	Does not Exist
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	Inspected
Lighting	Inspected
Does a Chandelier exist?	No
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not Exist
Lighting Fixture - HID	Does not Exist
Lighting Fixture - Incandescent	Does not Exist
Lighting Fixture - LED	Does not Exist
COMPUTER LAB	Does not Exist
GYMNASIUM	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2017 - 2018**

Electrical Inspection

K866

Question	Response
GYMNASIUM	
Instance on 1st Floor	Inspected
Lighting	Inspected
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Does not Exist
Lighting Fixture - HID	
Instance on 1st Floor	Inspected
Pendant Mounted	Inspected
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Surface Mounted	Does not Exist
Instance on 1st Floor	Does not Exist
Recessed Mounted	Does not Exist
Instance on 1st Floor	Does not Exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not Exist
Lighting Fixture - LED	
Instance on 1st Floor	Does not Exist
Local Sound System	Does not Exist
Instance on 1st Floor	Does not Exist
Projection System	Does not Exist
Instance on 1st Floor	Does not Exist
Scoreboard	Inspected
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Theater Lighting System	Does not Exist
Instance on 1st Floor	Does not Exist
KITCHEN	Does not Exist
LIBRARY	Does not Exist
LOCKER ROOM	Does not Exist
MULTIPURPOSE ROOM	Does not Exist
SCIENCE DEMO ROOM	Does not Exist
SCIENCE LAB	Does not Exist
SCIENCE PREP ROOM	Does not Exist
SWIMMING POOL	Inspected
Instance on 1st Floor - Main	Under Construction
Instance on 1st Floor - Training	Under Construction
TOILET ROOM - STAFF	Does not Exist

**NYC Department of Education
Building Condition Assessment Survey 2017 - 2018**

Electrical Inspection

K866

Question	Response
TOILET ROOM - STUDENT	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not Exist
Surface Mounted	Does not Exist
Recessed Mounted	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not Exist
Lighting Fixture - Incandescent	Does not Exist
Lighting Fixture - LED	Does not Exist
AUXILIARY SIGNAL/BELL SYSTEM	Does not Exist
EMERGENCY DC STANDBY BATTERY POWER	Does not Exist
EMERGENCY GENERATOR SET	Does not Exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Does not Exist
EMERGENCY LIGHTING	Inspected
Battery Pack	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Does not Exist
EXIT LIGHT	Does not Exist
EXIT/EMERGENCY LIGHT	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
CITY FIRE ALARM SYSTEM	Does not Exist
FIRE ALARM SYSTEM	Inspected
Replacement Quantity	14,000
Replacement Uom	S.F.
Bell/Horn	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Strobe	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Manual Pull Station	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Fan Shutdown Control	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Duct Smoke Detector	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Area Smoke Detector	Does not Exist
CO Detector	Does not Exist
Heat Detector	Does not Exist
Elevator Recall	Does not Exist
Magnetic Door Holder/Contactor	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2017 - 2018

Electrical Inspection

K866

Question	Response
FIRE ALARM SYSTEM	
Fused Cutout Panel	Does not Exist
Fire Alarm Digital Communicator	Does not Exist
Main Panel	Does not Exist
Sub-Panel	Does not Exist
Remote Annunciator	Does not Exist
Sprinkler Flow/Air Pressure Switch	Does not Exist
Tamper Flow Switch/Chain	Does not Exist
GROUNDING SYSTEM	Does not Exist
INTERCOM SYSTEM	Does not Exist
LAN	Does not Exist
LIGHTNING PROTECTION	Does not Exist
MOTOR CONTROL CENTER	Does not Exist
MOTOR STARTER/CONTACTOR	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
PANEL BOARD	Does not Exist
PUBLIC ADDRESS SYSTEM	Does not Exist
SECURITY	Does not Exist
SERVICE SWITCH	Does not Exist
SWITCHBOARD	Does not Exist
TELEPHONE SYSTEM	Does not Exist
TRANSFORMER	Does not Exist
TV SYSTEM	Does not Exist