

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M005

School: P.S. 5 - MANHATTAN, 3703 TENTH AVENUE, MANHATTAN, NY, 10034

InspectionId	Inspection Type	Time In	Last Edited
1170	ELECTRICAL	2019-01-04 09:21AM	2019-06-20 11:05AM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Intrusion Alarm System Years: 2015 Systems: Exit Lights (Battery Pack) Years: 2012 Systems: Intercom System (Elevator) Years: 2011 Systems: Security Lights, Intercom (Holding Room) Years: 2009 Systems: LAN Years: 2006 Systems: All Other Electrical Systems and Components Years: 1993 Systems: Telephone System Years: 2018 Systems: Fire Alarm System Years: 2017 Systems: Gymnasium (LED Lighting) Years: 2016
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	Yes
Water Penetration In Electrical Room?	No

DEDICATED INTERCOMS IN FIRE RESCUE AREAS

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	No

Priority Condition

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image
No condition recorded							

Inspection

Question	Response
Electrical	
ATHLETIC FIELD	Does not exist
AUDITORIUM	
Instance on 2nd Floor	Inspected
House Lighting	
Instance on 2nd Floor	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	
Instance on 2nd Floor	Inspected
Pendant Mounted	
Instance on 2nd Floor	Does not exist
Recessed Mounted	
Instance on 2nd Floor	Does not exist
Surface Mounted	
Instance on 2nd Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M005

Question	Response
AUDITORIUM	
House Lighting	
Lighting Fixture - HID	
Instance on 2nd Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 2nd Floor	Inspected
Pendant Mounted	
Instance on 2nd Floor	Does not exist
Recessed Mounted	
Instance on 2nd Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on 2nd Floor	Does not exist
Lighting Fixture - LED	
Instance on 2nd Floor	Does not exist
Local Sound System	
Instance on 2nd Floor	Inspected
Instance Condition	3- Fair
Installation Year	1993
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Auditorium-2nd Floor
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Projection System	
Instance on 2nd Floor	Does not exist
Theater Lighting System	
Instance on 2nd Floor	Inspected
Dimming System	
Instance on 2nd Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Theater Lighting	
Instance on 2nd Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
AUXILIARY SIGNAL/BELL SYSTEM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
CAFETERIA	
Instance on 1st Floor - Student	Inspected
Instance on 1st Floor - Staff	Inspected
Lighting	
Instance on 1st Floor - Student	Inspected
Instance on 1st Floor - Staff	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor - Student	Inspected
Instance on 1st Floor - Staff	Inspected
Pendant Mounted	

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M005

Question	Response
CAFETERIA	
Lighting	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Instance on 1st Floor - Student	Does not exist
Instance on 1st Floor - Staff	Does not exist
Recessed Mounted	
Instance on 1st Floor - Student	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on 1st Floor - Staff	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on 1st Floor - Student	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on 1st Floor - Staff	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on 1st Floor - Student	Does not exist
Instance on 1st Floor - Staff	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor - Student	Does not exist
Instance on 1st Floor - Staff	Does not exist
Lighting Fixture - LED	
Instance on 1st Floor - Student	Does not exist
Instance on 1st Floor - Staff	Does not exist
Local Sound System	
Instance on 1st Floor - Student	Inspected
Instance Condition	3- Fair
Installation Year	1993
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Cafeteria-1st Floor - Student
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 1st Floor - Staff	Does not exist
Projection System	
Instance on 1st Floor - Student	Does not exist
Instance on 1st Floor - Staff	Does not exist
Theater Lighting System	
Instance on 1st Floor - Student	Does not exist
Instance on 1st Floor - Staff	Does not exist
CITY FIRE ALARM SYSTEM	
Condition	3- Fair
Deficiency	No deficiencies recorded
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
Lighting	Inspected

NYC Department of Education
Building Condition Assessment Survey 2018-2019

Electrical Inspection

M005

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
Lighting	
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	
Pendant Mounted	
Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Does not exist
COMPUTER LAB	
Instance on Room 423	Inspected
Power Panel?	Yes
Lighting	
Instance on Room 423	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 423	Inspected
Pendant Mounted	
Instance on Room 423	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 423	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Room 423	Does not exist
Lighting Fixture - HID	
Instance on Room 423	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 423	Does not exist
Lighting Fixture - LED	
Instance on Room 423	Does not exist
Raceway With Receptacles	
Instance on Room 423	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY DC STANDBY BATTERY POWER	
	Does not exist
EMERGENCY GENERATOR SET	
Automatic Transfer Switch (ATS)	
Instance	Penthouse 1
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ASCO
EquipmentId	ATS#4
Capacity/Size Quantity	260

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M005

Question	Response
EMERGENCY GENERATOR SET	
Automatic Transfer Switch (ATS)	
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1993
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Electrical Room 15
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ASCO
EquipmentId	ATS#2
Capacity/Size Quantity	400
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1993
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Elevator Machine Room 10
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ASCO
EquipmentId	ATS#3
Capacity/Size Quantity	400
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1993
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Fire Pump Room 21
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Master Control Systems
EquipmentId	Automatic Transfer Switch
Capacity/Size Quantity	15
Capacity/Size UOM	HP
Source of Capacity/Size	Nameplate
Installation Year	1993
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Battery Charger	Inspected
Instance	Penthouse 1
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	SENS
EquipmentId	Battery Charger
Capacity/Size Quantity	6
Capacity/Size UOM	AmpsDC
Capacity/Size 2 Quantity	24
Capacity/Size 2 UOM	VDC
Source of Capacity/Size	Nameplate
Installation Year	1993

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M005

Question	Response
EMERGENCY GENERATOR SET	
Battery Charger	
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Diesel	
	Inspected
Instance	Penthouse 1
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Kohler Power Systems
EquipmentId	Emergency Generator
Capacity/Size Quantity	313
Capacity/Size UOM	kVA
Capacity/Size 2 Quantity	250
Capacity/Size 2 UOM	kW
Capacity/Size 3 Quantity	867
Capacity/Size 3 UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1993
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Natural Gas	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Does not exist
EMERGENCY LIGHTING	Inspected
Battery Pack	
Condition	3- Fair
Deficiency	No deficiencies recorded
Non Battery Pack	
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT LIGHT	Inspected
Battery Pack	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Non Battery Pack	
Condition	3- Fair
Deficiency	FIXTURE NOT OPERATIONAL
Deficiency Location/Instance	Penthouse 2
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
EXIT/EMERGENCY LIGHT	Does not exist
FIRE ALARM SYSTEM	Inspected
Area Smoke Detector	
Condition	1- Good
Deficiency	No deficiencies recorded
Bell/Horn	
Condition	1- Good
Deficiency	No deficiencies recorded
CO Detector	
Condition	1- Good

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M005

Question	Response
FIRE ALARM SYSTEM	
CO Detector	
Deficiency	No deficiencies recorded
Duct Smoke Detector	
Condition	Inspected
Deficiency	1- Good
Elevator Recall	
Condition	No deficiencies recorded
Deficiency	Inspected
Fan Shutdown Control	
Condition	1- Good
Deficiency	No deficiencies recorded
Fire Alarm Digital Communicator	
Fused Cutout Panel	
Condition	Inspected
Deficiency	1- Good
Heat Detector	
Condition	No deficiencies recorded
Deficiency	Inspected
Magnetic Door Holder/Contactor	
Condition	1- Good
Deficiency	No deficiencies recorded
Main Panel	
Bell At Panel	
Fire Alarm Control Panel (Electronic)	
Instance	Inspected
Instance Condition	1st Floor Corridor By Custodian's Office - Room 101
Instance Quantity	1- Good
Instance Quantity Uom	1
Manufacturer	EACH
Model	Edwards System Technology
EquipmentId	EST
Capacity/Size Quantity	Fire Alarm Control
Capacity/Size UOM	16
Capacity/Size 2 Quantity	Zones
Capacity/Size 2 UOM	1
Source of Capacity/Size	Section(s)
Installation Year	Diagram
Source of Installation Year	2017
Deficiency	Documented
Fire Alarm Control Panel (Standard)	
Manual Pull Station	
Condition	Inspected
Deficiency	1- Good
Remote Annunciator	
Display Monitor	
Panel	
Condition	Does not exist
Deficiency	Inspected
Printer	
Condition	Inspected
Deficiency	4- Between Fair and Poor
Deficiency Location/Instance	PRINTER NOT OPERATIONAL
Deficiency Quantity	Custodian's Office
	1

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M005

Question	Response
FIRE ALARM SYSTEM	
Remote Annunciator	
Printer	
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
Punch Register	Does not exist
Sprinkler Flow/Air Pressure Switch	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Strobe	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Sub-Panel	Does not exist
Tamper Flow Switch/Chain	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	
Condition	3- Fair
Deficiency	No deficiencies recorded
GYMNASIUM	
Instance on 1st Floor	Inspected
Lighting	
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not exist
Recessed Mounted	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - LED	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Does not exist
Local Sound System	

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M005

Question	Response
GYMNASIUM	
Local Sound System	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Installation Year	1993
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Gymnasium-1st Floor
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Projection System	
Instance on 1st Floor	Does not exist
Scoreboard	
Instance on 1st Floor	Does not exist
Theater Lighting System	
Instance on 1st Floor	Does not exist
INTERCOM SYSTEM	
	Inspected
Elevator	
	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Holding Area	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
KITCHEN	
Instance on 1st Floor	Inspected
Lighting	
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not exist
Recessed Mounted	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on 1st Floor	Does not exist
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not exist
Recessed Mounted	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on 1st Floor	Does not exist
Lighting Fixture - LED	

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M005

Question	Response
KITCHEN	
Lighting	
Lighting Fixture - LED	
Instance on 1st Floor	Does not exist
LAN	Inspected
Local Distribution Frame (I/LDF)	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Main Equipment Rack (MDF)	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
LIBRARY	
Instance on Room 411/412	Inspected
Lighting	
Instance on Room 411/412	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 411/412	Inspected
Pendant Mounted	
Instance on Room 411/412	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 411/412	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Room 411/412	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Room 411/412	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 411/412	Does not exist
Lighting Fixture - LED	
Instance on Room 411/412	Does not exist
Projection System	
Instance on Room 411/412	Does not exist
Raceway With Receptacles	
Instance on Room 411/412	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
LIGHTNING PROTECTION	Does not exist
LOCKER ROOM	Does not exist
MOTOR CONTROL CENTER	Does not exist
MOTOR STARTER/CONTACTOR	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
MULTIPURPOSE ROOM	Does not exist
PANEL BOARD	Inspected
Fused Disconnect Switch Type	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fused Knife Switch Type	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M005

Question	Response
PANEL BOARD	
Fused Toggle Switch Type	Does not exist
Molded Case Circuit Breaker Type	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD COVER IS MISSING
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	PANEL BOARD DIRECTORY MISSING OR REQUIRES UPDATING
Deficiency Location/Instance	4th Floor By Staircase B
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
PUBLIC ADDRESS SYSTEM	Inspected
Instance	General Office - Room 109
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Bogen Multicom - 2000
Installation Year	1993
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	Does not exist
SCIENCE LAB	Does not exist
SCIENCE PREP ROOM	Does not exist
SECURITY	Inspected
Intrusion Alarm System	Inspected
Central Control Panel	Inspected
Instance	Custodian's Office - Room 101
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista 128BPT
Installation Year	2015
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Infrared Sensor	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Panic Switch	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Remote Annunciator	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Siren/Strobe	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M005

Question	Response
SECURITY	
Intrusion Alarm System	
Siren/Strobe	
Condition	1- Good
Deficiency	No deficiencies recorded
Ultrasonic Sensor	Does not exist
IPDVS/CCTV System	Does not exist
Lighting - Security	Inspected
Condition	2- Between Good and Fair
Replacement Quantity	67
Replacement Uom	EACH
Deficiency	No deficiencies recorded
SERVICE SWITCH	Inspected
Instance	Electrical Room 15
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Siemens
EquipmentId	Service Disconnect
Capacity/Size Quantity	4000
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1993
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
SWIMMING POOL	Does not exist
SWITCHBOARD	Inspected
Number of Spares	3
Air Circuit Breaker Type	Does not exist
Fused Disconnect Switch Type	Inspected
Instance	Electrical Room 15
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Siemens
EquipmentId	N/A
Capacity/Size Quantity	4000
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	4
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Nameplate
Installation Year	1993
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Penthouse 1
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Siemens
EquipmentId	Generator Panel
Capacity/Size Quantity	1200
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	1
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Nameplate

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M005

Question	Response
SWITCHBOARD	
Fused Disconnect Switch Type	
Installation Year	1993
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fused Knife Switch Type	Does not exist
Molded Case Circuit Breaker Type	Does not exist
TELEPHONE SYSTEM	
PBX/Intercom	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Standard	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
TOILET ROOM - STAFF	
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Does not exist
TOILET ROOM - STUDENT	
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Does not exist
TRANSFORMER	
	Does not exist
TV SYSTEM	
	Does not exist