

**NYC Department of Education  
Building Condition Assessment Survey 2018-2019**

**Electrical Inspection**

**M042**

**School:** P.S. 42 - MANHATTAN, 71 HESTER STREET, MANHATTAN, NY, 10002

InspectionId	Inspection Type	Time In	Last Edited
2454	ELECTRICAL	2019-02-13 09:12AM	2019-03-26 08:35AM

**Asset Data**

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Telephone System, LAN System Years: 2015 Systems: Interior Fluorescents Lights, Emergency Light/Exit Lights in Boiler Room Years: 2013 Systems: Intrusion Alarm System - Central Control Panel Years: 2010 Systems: Emergency Light/Exit Light Panel Years: 2009 Systems: Service Switch Years: 2005, 2009 Systems: Grounding System, Security Lights Years: 2005 Systems: Partial Switchboard Years: 2005 Systems: Public Address System, Local Sound Systems Years: 2002 Systems: Fused Disconnect Panelboards Years: 1996 Systems: Partial Circuit Breaker Type Panelboards Years: 2001, 2009, 2013
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	Yes
Water Penetration In Electrical Room?	No

**DEDICATED INTERCOMS IN FIRE RESCUE AREAS**

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	No

**Priority Condition**

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image
No condition recorded							

**Inspection**

Question	Response
<b>Electrical</b>	
<b>ATHLETIC FIELD</b>	Does not exist
<b>AUDITORIUM</b>	
Instance on 4th Floor	Inspected
<b>House Lighting</b>	
Instance on 4th Floor	Inspected
Does a Chandelier Exist?	No
<b>Lighting Fixture - Fluorescent</b>	
Instance on 4th Floor	Inspected
<b>Pendant Mounted</b>	
Instance on 4th Floor	Does not exist
<b>Recessed Mounted</b>	
Instance on 4th Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded

**NYC Department of Education  
Building Condition Assessment Survey 2018-2019**

**Electrical Inspection**

**M042**

Question	Response
<b>AUDITORIUM</b>	
<b>House Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Surface Mounted</b>	
Instance on 4th Floor	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on 4th Floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 4th Floor	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on 4th Floor	Does not exist
<b>Local Sound System</b>	
Instance on 4th Floor	Inspected
Instance Condition	3- Fair
Installation Year	2002
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Projection System</b>	
Instance on 4th Floor	Does not exist
<b>Theater Lighting System</b>	
Instance on 4th Floor	Inspected
<b>Dimming System</b>	
Instance on 4th Floor	Does not exist
<b>Theater Lighting</b>	
Instance on 4th Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	21
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>AUXILIARY SIGNAL/BELL SYSTEM</b>	
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>CAFETERIA</b>	
Instance on 1st Floor	Inspected
<b>Lighting</b>	
Instance on 1st Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st Floor	Inspected
<b>Pendant Mounted</b>	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Surface Mounted</b>	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
Instance on 1st Floor	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2018-2019**

**Electrical Inspection**

**M042**

Question	Response
<b>CAFETERIA</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on 1st Floor	Does not exist
<b>Local Sound System</b>	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Installation Year	2002
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Projection System</b>	
Instance on 1st Floor	Does not exist
<b>Theater Lighting System</b>	
Instance on 1st Floor	Does not exist
<b>CITY FIRE ALARM SYSTEM</b>	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
Condition	Inspected
<b>Lighting</b>	
Does a Chandelier Exist?	Inspected
Does a Chandelier Exist?	No
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
Condition	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Condition	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	
Condition	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
Condition	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Condition	Does not exist
<b>Lighting Fixture - LED</b>	
Condition	Does not exist
<b>COMPUTER LAB</b>	
Instance on Room 402	Inspected
Power Panel?	Yes
<b>Lighting</b>	
Instance on Room 402	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 402	Inspected
<b>Pendant Mounted</b>	
Instance on Room 402	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on Room 402	Does not exist
<b>Surface Mounted</b>	
Instance on Room 402	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 402	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 402	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2018-2019**

**Electrical Inspection**

**M042**

Question	Response
<b>COMPUTER LAB</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Incandescent</b>	
<b>Lighting Fixture - LED</b>	
Instance on Room 402	Does not exist
<b>Raceway With Receptacles</b>	
Instance on Room 402	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY DC STANDBY BATTERY POWER</b>	Does not exist
<b>EMERGENCY GENERATOR SET</b>	Does not exist
<b>EMERGENCY LIGHT/EXIT LIGHT PANEL</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY LIGHTING</b>	Inspected
<b>Battery Pack</b>	Inspected
Condition	3- Fair
Deficiency	BATTERY NOT OPERATIONAL
Deficiency Location/Instance	Gymnasium, Multipurpose Room, Auditorium, 1st Floor Exits 1, 5, 8 and 1A
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	REPLACE BATTERY
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 4
Violations	35322187Z
<b>Non Battery Pack</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>EXIT LIGHT</b>	Inspected
<b>Battery Pack</b>	Inspected
Condition	3- Fair
Deficiency	BATTERY NOT OPERATIONAL
Deficiency Location/Instance	Stairs 3B,4F
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE BATTERY
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Non Battery Pack</b>	Does not exist
<b>EXIT/EMERGENCY LIGHT</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>FIRE ALARM SYSTEM</b>	Inspected
<b>Area Smoke Detector</b>	Does not exist
<b>Bell/Horn</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>CO Detector</b>	Does not exist
<b>Duct Smoke Detector</b>	Does not exist
<b>Elevator Recall</b>	Does not exist
<b>Fan Shutdown Control</b>	Does not exist
<b>Fire Alarm Digital Communicator</b>	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2018-2019**

**Electrical Inspection**

**M042**

Question	Response
<b>FIRE ALARM SYSTEM</b>	
<b>Fused Cutout Panel</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Heat Detector</b>	Does not exist
<b>Magnetic Door Holder/Contactor</b>	Does not exist
<b>Main Panel</b>	Inspected
<b>Bell At Panel</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Electronic)</b>	Inspected
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards
Model	Custom 6500
EquipmentId	Fire Alarm Control
Capacity/Size Quantity	8
Capacity/Size UOM	Zones
Capacity/Size 2 Quantity	1
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Inspector Estimate
Installation Year	1978
Source of Installation Year	Inspector Estimate
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	74,000
Quantity Uom	S.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Fire Alarm Control Panel (Standard)</b>	Does not exist
<b>Manual Pull Station</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Remote Annunciator</b>	Does not exist
<b>Sprinkler Flow/Air Pressure Switch</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Strobe</b>	Does not exist
<b>Sub-Panel</b>	Inspected
<b>Bell At Panel</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Electronic)</b>	Does not exist
<b>Fire Alarm Control Panel (Standard)</b>	Inspected
Instance	Basement
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ACME
EquipmentId	Sprinkler Annunciator Control Board
Capacity/Size Quantity	2

**NYC Department of Education  
Building Condition Assessment Survey 2018-2019**

**Electrical Inspection**

**M042**

Question	Response
<b>FIRE ALARM SYSTEM</b>	
<b>Sub-Panel</b>	
<b>Fire Alarm Control Panel (Standard)</b>	
Capacity/Size UOM	Circuits
Source of Capacity/Size	Inspector Estimate
Installation Year	1978
Source of Installation Year	Inspector Estimate
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Basement
Deficiency Quantity	74,000
Quantity Uom	S.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Tamper Flow Switch/Chain</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>GROUNDING SYSTEM</b>	
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>GYMNASIUM</b>	
Instance on 5th Floor	Inspected
<b>Lighting</b>	
Instance on 5th Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on 5th Floor	Inspected
<b>Pendant Mounted</b>	
Instance on 5th Floor	Does not exist
<b>Recessed Mounted</b>	
Instance on 5th Floor	Does not exist
<b>Surface Mounted</b>	
Instance on 5th Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
Instance on 5th Floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 5th Floor	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on 5th Floor	Does not exist
<b>Local Sound System</b>	
Instance on 5th Floor	Inspected
Instance Condition	3- Fair
Installation Year	2002
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Projection System</b>	
Instance on 5th Floor	Does not exist
<b>Scoreboard</b>	
Instance on 5th Floor	Does not exist
<b>Theater Lighting System</b>	
Instance on 5th Floor	Does not exist
<b>INTERCOM SYSTEM</b>	
	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2018-2019**

**Electrical Inspection**

**M042**

Question	Response
<b>KITCHEN</b>	
Instance on 1st Floor	Inspected
<b>Lighting</b>	
Instance on 1st Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st Floor	Inspected
<b>Pendant Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Recessed Mounted</b>	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st Floor	Inspected
<b>Pendant Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Recessed Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Surface Mounted</b>	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - LED</b>	
Instance on 1st Floor	Does not exist
<b>LAN</b>	Inspected
<b>Local Distribution Frame (I/LDF)</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Main Equipment Rack (MDF)</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>LIBRARY</b>	
Instance on Room 314	Inspected
<b>Lighting</b>	
Instance on Room 314	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 314	Inspected
<b>Pendant Mounted</b>	
Instance on Room 314	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on Room 314	Does not exist
<b>Surface Mounted</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2018-2019**

**Electrical Inspection**

**M042**

<b>Question</b>	<b>Response</b>
<b>LIBRARY</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Surface Mounted</b>	
Instance on Room 314	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 314	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 314	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on Room 314	Does not exist
<b>Projection System</b>	
Instance on Room 314	Does not exist
<b>Raceway With Receptacles</b>	
Instance on Room 314	Does not exist
<b>LIGHTNING PROTECTION</b>	Does not exist
<b>LOCKER ROOM</b>	Does not exist
<b>MOTOR CONTROL CENTER</b>	Does not exist
<b>MOTOR STARTER/CONTACTOR</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>MULTIPURPOSE ROOM</b>	
Instance on 1st Floor	Inspected
<b>Lighting</b>	
Instance on 1st Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st Floor	Inspected
<b>Pendant Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Recessed Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Surface Mounted</b>	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on 1st Floor	Does not exist
<b>Local Sound System</b>	
Instance on 1st Floor	Does not exist
<b>Projection System</b>	
Instance on 1st Floor	Does not exist
<b>Theater Lighting System</b>	
Instance on 1st Floor	Does not exist
<b>PANEL BOARD</b>	Inspected
<b>Fused Disconnect Switch Type</b>	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Boiler Room area
Deficiency Quantity	1



**NYC Department of Education  
Building Condition Assessment Survey 2018-2019**

**Electrical Inspection**

**M042**

Question	Response
<b>PANEL BOARD</b>	
<b>Fused Disconnect Switch Type</b>	
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Fused Knife Switch Type</b>	Does not exist
<b>Fused Toggle Switch Type</b>	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Molded Case Circuit Breaker Type</b>	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Corridor of 1st thru 5th Floors, Boiler Room area, Kitchen
Deficiency Quantity	12
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>PUBLIC ADDRESS SYSTEM</b>	Inspected
Instance	Room 209
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Rauland TC2100
Installation Year	2002
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>SCIENCE DEMO ROOM</b>	Does not exist
<b>SCIENCE LAB</b>	Does not exist
<b>SCIENCE PREP ROOM</b>	Does not exist
<b>SECURITY</b>	Inspected
<b>Intrusion Alarm System</b>	Inspected
<b>Central Control Panel</b>	Inspected
Instance	Custodian's Office
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista - 128BP
Installation Year	2010
Source of Installation Year	Documented
Deficiency	PANEL NOT CONNECTED TO DOE CENTRAL STATION
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REWIRE
Urgency of Action	PRIORITY 4

**NYC Department of Education  
Building Condition Assessment Survey 2018-2019**

**Electrical Inspection**

**M042**

Question	Response
<b>SECURITY</b>	
<b>Intrusion Alarm System</b>	
<b>Central Control Panel</b>	
Purpose of Action	LEVEL 3
Violations	No violations recorded
<b>Infrared Sensor</b>	
Condition	Inspected
Deficiency	No deficiencies recorded
<b>Panic Switch</b>	
Condition	Inspected
Deficiency	No deficiencies recorded
<b>Remote Annunciator</b>	
Condition	Inspected
Deficiency	No deficiencies recorded
<b>Siren/Strobe</b>	
Condition	Inspected
Deficiency	No deficiencies recorded
<b>Ultrasonic Sensor</b>	
	Does not exist
<b>IPDVS/CCTV System</b>	
	Does not exist
<b>Lighting - Security</b>	
Condition	Inspected
Replacement Quantity	2- Between Good and Fair
Replacement Uom	17
Deficiency	EACH
Deficiency Location/Instance	TIME CLOCK NOT OPERATIONAL
Deficiency Quantity	Outside Electrical Room
Quantity Uom	1
Potential Action	EACH
Urgency of Action	REPLACE
Purpose of Action	PRIORITY 3
Violations	LEVEL 3
	No violations recorded
<b>SERVICE SWITCH</b>	
Instance	Inspected
Instance Condition	Electrical Meter Room
Instance Quantity	2- Between Good and Fair
Instance Quantity Uom	1
Manufacturer	EACH
EquipmentId	Siemens
Capacity/Size Quantity	Service Switch #1
Capacity/Size UOM	1600
Source of Capacity/Size	Amps
Installation Year	Nameplate
Source of Installation Year	2005
Deficiency	Documented
	No deficiencies recorded
Instance	Electrical Meter Room
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Atlas
EquipmentId	Service Switch #2
Capacity/Size Quantity	800
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	2009
Source of Installation Year	Documented

**NYC Department of Education  
Building Condition Assessment Survey 2018-2019**

**Electrical Inspection**

**M042**

<b>Question</b>	<b>Response</b>
<b>SERVICE SWITCH</b>	
Deficiency	No deficiencies recorded
Instance	Corridor next to Supply Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Square D
EquipmentId	Kitchen Light Panel
Capacity/Size Quantity	200
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1978
Source of Installation Year	Inspector Estimate
Deficiency	No deficiencies recorded
Instance	Electrical Room
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Pringle
EquipmentId	N/A
Capacity/Size Quantity	1600
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	2003
Source of Installation Year	Inspector Estimate
Deficiency	No deficiencies recorded
Instance	Electrical Room
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	General Electric
EquipmentId	Emergency Lighting Panel Disc. Switch
Capacity/Size Quantity	400
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	2003
Source of Installation Year	Inspector Estimate
Deficiency	No deficiencies recorded
Instance	Electrical Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	I.T.E.
EquipmentId	CDP Main Switch
Capacity/Size Quantity	200
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1978
Source of Installation Year	Inspector Estimate
Deficiency	No deficiencies recorded
<b>SWIMMING POOL</b>	Does not exist
<b>SWITCHBOARD</b>	Inspected
Number of Spares	1
<b>Air Circuit Breaker Type</b>	Does not exist
<b>Fused Disconnect Switch Type</b>	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2018-2019**

**Electrical Inspection**

**M042**

Question	Response
<b>SWITCHBOARD</b>	
<b>Fused Disconnect Switch Type</b>	
Instance	Electrical Meter Room
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Siemens
EquipmentId	MDP#2
Capacity/Size Quantity	1200
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	1
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Nameplate
Installation Year	2003
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Electrical Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Federal Pacific Electric
EquipmentId	N/A
Capacity/Size Quantity	1600
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	2
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Service Switch Size
Installation Year	1978
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Fused Knife Switch Type</b>	Does not exist
<b>Molded Case Circuit Breaker Type</b>	Does not exist
<b>TELEPHONE SYSTEM</b>	Inspected
<b>PBX/Intercom</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Standard</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>TOILET ROOM - STAFF</b>	Inspected
<b>Lighting</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Inspected
<b>Pendant Mounted</b>	Does not exist
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair

**NYC Department of Education  
Building Condition Assessment Survey 2018-2019**

**Electrical Inspection**

**M042**

Question	Response
<b>TOILET ROOM - STAFF</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Incandescent</b>	
<b>Surface Mounted</b>	
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - LED</b>	Does not exist
<b>TOILET ROOM - STUDENT</b>	Inspected
<b>Lighting</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Inspected
<b>Pendant Mounted</b>	Does not exist
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - LED</b>	Does not exist
<b>TRANSFORMER</b>	Does not exist
<b>TV SYSTEM</b>	Inspected
Cable System Exist?	Yes
Operational?	Yes
<b>Main Equipment Rack</b>	Does not exist