

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M072

School: P.S. 72 - MANHATTAN, 131 EAST 104 STREET, MANHATTAN, NY, 10029

InspectionId	Inspection Type	Time In	Last Edited
1459	ELECTRICAL	2019-01-15 09:13AM	2019-05-13 07:48AM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Intrusion Alarm System Years: 1995 Systems: Public Address System Years: 2000 Systems: Emergency Light/Exit Light Panel Years: 2001 Systems: Fire Alarm System, Auxiliary Signal/Bell System, Telephone System, LAN Years: 2007 Systems: Exit/Emergency Lights Years: 2012 Systems: Interior Fluorescent Lighting, LED Lighting in Auditorium, Battery Pack Exit Lights, Partial Non-Battery Pack Emergency Lighting Years: 2015 Systems: Auditorium - Local Sound System, Projection System, and Theater Lighting System, Science Rooms 507 and 508 (Including Lighting), Cafeteria - Local Sound System Years: 2017 Systems: Partial Molded Case Circuit Breaker Type Panel Boards Years: 2017, 2011, 1999 Systems: Security Lights Years: 2016
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	Yes
Water Penetration In Electrical Room?	No

DEDICATED INTERCOMS IN FIRE RESCUE AREAS

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	No

Priority Condition

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image	
		No condition recorded						

Inspection

Question	Response
Electrical	
ATHLETIC FIELD	Does not exist
AUDITORIUM	
Instance on 1st Floor	Inspected
House Lighting	
Instance on 1st Floor	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M072

Question	Response
AUDITORIUM	
House Lighting	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Does not exist
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - LED	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not exist
Recessed Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Local Sound System	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Installation Year	2017
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Projection System	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Is the projector on a cart or installed on the ceiling?	Ceiling
Deficiency	No deficiencies recorded
Theater Lighting System	
Instance on 1st Floor	Inspected
Dimming System	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Theater Lighting	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
AUXILIARY SIGNAL/BELL SYSTEM	
Condition	Inspected
	3- Fair
Deficiency	No deficiencies recorded
CAFETERIA	
Instance on 1st Floor	Inspected
Lighting	
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not exist
Recessed Mounted	

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M072

Question	Response
CAFETERIA	
Lighting	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - LED	
Instance on 1st Floor	Does not exist
Local Sound System	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Installation Year	2017
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Projection System	
Instance on 1st Floor	Does not exist
Theater Lighting System	
Instance on 1st Floor	Does not exist
CITY FIRE ALARM SYSTEM	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
Lighting	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	
Pendant Mounted	
Condition	Inspected
Deficiency	1- Good
Deficiency	No deficiencies recorded
Recessed Mounted	
Condition	Does not exist
Surface Mounted	
Condition	Inspected
Deficiency	1- Good
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Condition	Does not exist
Lighting Fixture - Incandescent	
Condition	Does not exist
Lighting Fixture - LED	
Condition	Does not exist
COMPUTER LAB	
Instance on Room 410	Inspected
Power Panel?	No
Lighting	
Instance on Room 410	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 410	Inspected
Pendant Mounted	
Instance on Room 410	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Recessed Mounted	

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M072

Question	Response
COMPUTER LAB	
Lighting	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Instance on Room 410	Does not exist
Surface Mounted	
Instance on Room 410	Does not exist
Lighting Fixture - HID	
Instance on Room 410	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 410	Does not exist
Lighting Fixture - LED	
Instance on Room 410	Does not exist
Raceway With Receptacles	
Instance on Room 410	Does not exist
EMERGENCY DC STANDBY BATTERY POWER	Does not exist
EMERGENCY GENERATOR SET	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
EMERGENCY LIGHTING	Inspected
Battery Pack	Inspected
Condition	3- Fair
Deficiency	FIXTURE NOT OPERATIONAL
Deficiency Location/Instance	Lexington Avenue Side Vestibule
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
Non Battery Pack	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
EXIT LIGHT	Inspected
Battery Pack	Inspected
Condition	1- Good
Deficiency	FIXTURE NOT OPERATIONAL
Deficiency Location/Instance	Field on Roof, 5th Floor Corridor by Stairwells B and C
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT/EMERGENCY LIGHT	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
FIRE ALARM SYSTEM	Inspected
Area Smoke Detector	Inspected
Condition	2- Between Good and Fair

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M072

Question	Response
FIRE ALARM SYSTEM	
Area Smoke Detector	
Deficiency	No deficiencies recorded
Bell/Horn	
Condition	Inspected
Deficiency	2- Between Good and Fair
CO Detector	
Deficiency	No deficiencies recorded
CO Detector	
Condition	Does not exist
Duct Smoke Detector	
Condition	Inspected
Deficiency	2- Between Good and Fair
Elevator Recall	
Deficiency	No deficiencies recorded
Fan Shutdown Control	
Condition	Does not exist
Deficiency	Inspected
Fire Alarm Digital Communicator	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Fused Cutout Panel	
Condition	Inspected
Deficiency	2- Between Good and Fair
Heat Detector	
Condition	Inspected
Deficiency	2- Between Good and Fair
Magnetic Door Holder/Contactor	
Deficiency	No deficiencies recorded
Main Panel	
Bell At Panel	
Condition	Does not exist
Deficiency	Inspected
Fire Alarm Control Panel (Electronic)	
Instance	2- Between Good and Fair
Instance Condition	1st Floor Corridor by Schoolyard Entrance
Instance Quantity	2- Between Good and Fair
Instance Quantity Uom	1
Manufacturer	EACH
Model	Edwards System Technology
EquipmentId	EST 2
Capacity/Size Quantity	Fire Alarm Control Panel
Capacity/Size UOM	16
Capacity/Size 2 Quantity	Zones
Capacity/Size 2 UOM	1
Source of Capacity/Size	Section(s)
Installation Year	Diagram
Source of Installation Year	2007
Deficiency	Documented
Fire Alarm Control Panel (Standard)	
Deficiency	No deficiencies recorded
Manual Pull Station	
Condition	Does not exist
Deficiency	Inspected
Remote Annunciator	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Display Monitor	
Condition	Does not exist
Panel	
Condition	Inspected
Deficiency	2- Between Good and Fair
Printer	
Condition	No deficiencies recorded
Deficiency	Inspected
Deficiency	5- Poor
Deficiency	PRINTER NOT OPERATIONAL

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M072

Question	Response
FIRE ALARM SYSTEM	
Remote Annunciator	
Printer	
Deficiency Location/Instance	Custodian's Office
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
Punch Register	
	Does not exist
Sprinkler Flow/Air Pressure Switch	
	Does not exist
Strobe	
	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Sub-Panel	
	Does not exist
Tamper Flow Switch/Chain	
	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
GYMNASIUM	
Instance on 2nd Floor	Inspected
Lighting	
Instance on 2nd Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 2nd Floor	Inspected
Pendant Mounted	
Instance on 2nd Floor	Does not exist
Recessed Mounted	
Instance on 2nd Floor	Does not exist
Surface Mounted	
Instance on 2nd Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on 2nd Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 2nd Floor	Does not exist
Lighting Fixture - LED	
Instance on 2nd Floor	Does not exist
Local Sound System	
Instance on 2nd Floor	Does not exist
Projection System	
Instance on 2nd Floor	Does not exist
Scoreboard	
Instance on 2nd Floor	Does not exist
Theater Lighting System	
Instance on 2nd Floor	Does not exist
INTERCOM SYSTEM	
	Does not exist
KITCHEN	
Instance on 1st Floor	Inspected
Lighting	

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M072

Question	Response
KITCHEN	
Lighting	
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not exist
Recessed Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - LED	
Instance on 1st Floor	Does not exist
LAN	Inspected
Local Distribution Frame (I/LDF)	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Main Equipment Rack (MDF)	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
LIBRARY	
Instance on Rooms 511, 512	Inspected
Lighting	
Instance on Rooms 511, 512	Inspected
Lighting Fixture - Fluorescent	
Instance on Rooms 511, 512	Inspected
Pendant Mounted	
Instance on Rooms 511, 512	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Rooms 511, 512	Does not exist
Surface Mounted	
Instance on Rooms 511, 512	Does not exist
Lighting Fixture - HID	
Instance on Rooms 511, 512	Does not exist
Lighting Fixture - Incandescent	
Instance on Rooms 511, 512	Does not exist
Lighting Fixture - LED	
Instance on Rooms 511, 512	Does not exist
Projection System	
Instance on Rooms 511, 512	Does not exist
Raceway With Receptacles	
Instance on Rooms 511, 512	Does not exist
LIGHTNING PROTECTION	Does not exist
LOCKER ROOM	Does not exist
MOTOR CONTROL CENTER	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M072

Question	Response
MOTOR STARTER/CONTACTOR	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
MULTIPURPOSE ROOM	Does not exist
PANEL BOARD	Inspected
Fused Disconnect Switch Type	Does not exist
Fused Knife Switch Type	Does not exist
Fused Toggle Switch Type	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Boiler Room MER
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Molded Case Circuit Breaker Type	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD COVER IS MISSING
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	PANEL BOARD DIRECTORY MISSING OR REQUIRES UPDATING
Deficiency Location/Instance	Kitchen, Cafeteria, Rooms 202 and 406
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	NO SPARE
Deficiency Location/Instance	Cafeteria, Kitchen, Gymnasium, Corridor by Rooms 506 and 508
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	REPLACE PANEL BOARD
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Cafeteria, Kitchen, Corridors on 2nd, 3rd, 4th, and 5th Floors
Deficiency Quantity	8
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	NO SPARE
Deficiency Location/Instance	Penthouse #3
Deficiency Quantity	1
Quantity Uom	EACH

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M072

Question	Response
PANEL BOARD	
Molded Case Circuit Breaker Type	
Potential Action	INSTALL NEW PANEL BOARD
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
PUBLIC ADDRESS SYSTEM	
	Inspected
Instance	1st Floor - Main Office
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Rauland Telecenter System 21
Installation Year	2000
Source of Installation Year	Documented
Deficiency	CLOCK NOT OPERATIONAL
Deficiency Location/Instance	Classrooms and Corridors
Deficiency Quantity	18
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
SCIENCE DEMO ROOM	
Instance on Room 407	Inspected
Power Panel?	No
Alternative Use	Yes
Emergency Gas Shut-Off Valve	
Instance on Room 407	Does not exist
Emergency Shut-Off Power	
Instance on Room 407	Does not exist
Lighting	
Instance on Room 407	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 407	Inspected
Pendant Mounted	
Instance on Room 407	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 407	Does not exist
Surface Mounted	
Instance on Room 407	Does not exist
Lighting Fixture - HID	
Instance on Room 407	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 407	Does not exist
Lighting Fixture - LED	
Instance on Room 407	Does not exist
Power Supply	
Instance on Room 407	Does not exist
Projection System	
Instance on Room 407	Does not exist
SCIENCE LAB	
Instance on Room 507	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M072

Question	Response
SCIENCE LAB	
Power Panel?	No
Alternative Use	No
Emergency Gas Shut-Off Valve	
Instance on Room 507	Does not exist
Emergency Shut-Off Power	
Instance on Room 507	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Lighting	
Instance on Room 507	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 507	Inspected
Pendant Mounted	
Instance on Room 507	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 507	Does not exist
Surface Mounted	
Instance on Room 507	Does not exist
Lighting Fixture - HID	
Instance on Room 507	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 507	Does not exist
Lighting Fixture - LED	
Instance on Room 507	Inspected
Pendant Mounted	
Instance on Room 507	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 507	Does not exist
Surface Mounted	
Instance on Room 507	Does not exist
Power Supply	
Instance on Room 507	Inspected
Instructor Unit	
Instance on Room 507	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Meter Demonstration Unit	
Instance on Room 507	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Student Unit	
Instance on Room 507	Does not exist
Projection System	
Instance on Room 507	Does not exist
SCIENCE PREP ROOM	
Instance on Room 508	Inspected
Power Panel?	Yes
Alternative Use	No

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M072

Question	Response
SCIENCE PREP ROOM	
Emergency Gas Shut-Off Valve	
Instance on Room 508	Does not exist
Emergency Shut-Off Power	
Instance on Room 508	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Lighting	
Instance on Room 508	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 508	Inspected
Pendant Mounted	
Instance on Room 508	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 508	Does not exist
Surface Mounted	
Instance on Room 508	Does not exist
Lighting Fixture - HID	
Instance on Room 508	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 508	Does not exist
Lighting Fixture - LED	
Instance on Room 508	Does not exist
Power Supply	
Instance on Room 508	Does not exist
SECURITY	Inspected
Intrusion Alarm System	Inspected
Central Control Panel	Inspected
Instance	Custodian's Office
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista - 50P
Installation Year	1995
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Infrared Sensor	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Panic Switch	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Remote Annunciator	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Siren/Strobe	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Ultrasonic Sensor	Does not exist
IPDVS/CCTV System	Does not exist
Lighting - Security	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M072

Question	Response
SECURITY	
Lighting - Security	
Condition	1- Good
Replacement Quantity	18
Replacement Uom	EACH
Deficiency	No deficiencies recorded
SERVICE SWITCH	
	Inspected
Instance	Basement - Main Electrical Meter Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Metropolitan
EquipmentId	AC Service Switch
Capacity/Size Quantity	800
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1961
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Basement - Main Electrical Meter Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Basement - Main Electrical Meter Room
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	General Electric
EquipmentId	EMERG MAIN CUT OFF
Capacity/Size Quantity	400
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	2010
Source of Installation Year	Inspector Estimate
Deficiency	No deficiencies recorded
SWIMMING POOL	
	Does not exist
SWITCHBOARD	
	Inspected
Number of Spares	3
Air Circuit Breaker Type	Does not exist
Fused Disconnect Switch Type	Inspected
Instance	Basement - Electrical Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Metropolitan Electric
EquipmentId	N/A
Capacity/Size Quantity	400
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	1
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Nameplate
Installation Year	1972
Source of Installation Year	Documented

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M072

Question	Response
SWITCHBOARD	
Fused Disconnect Switch Type	
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Basement - Electrical Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Fused Knife Switch Type	
Instance	Inspected
Instance Condition	Basement - Electrical Board Room
Instance Quantity	3- Fair
Instance Quantity Uom	1
Manufacturer	EACH
EquipmentId	N/A
Capacity/Size Quantity	N/A
Capacity/Size UOM	800
Capacity/Size 2 Quantity	Amps Total
Capacity/Size 2 UOM	2
Source of Capacity/Size	Section(s)
Installation Year	Service Switch Size
Source of Installation Year	1961
Deficiency	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Basement - Electrical Board Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Molded Case Circuit Breaker Type	
Does not exist	
TELEPHONE SYSTEM	
Inspected	
PBX/Intercom	
Inspected	
Condition	3- Fair
Deficiency	No deficiencies recorded
Standard	
Inspected	
Condition	3- Fair
Deficiency	No deficiencies recorded
TOILET ROOM - STAFF	
Inspected	
Lighting	
Inspected	
Lighting Fixture - Fluorescent	
Inspected	
Pendant Mounted	
Inspected	
Condition	1- Good
Deficiency	No deficiencies recorded
Recessed Mounted	
Does not exist	
Surface Mounted	
Inspected	
Condition	1- Good
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Does not exist	
Lighting Fixture - Incandescent	
Does not exist	
Lighting Fixture - LED	
Does not exist	
TOILET ROOM - STUDENT	
Inspected	
Lighting	
Inspected	

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M072

Question	Response
TOILET ROOM - STUDENT	
Lighting	
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Does not exist
TRANSFORMER	Does not exist
TV SYSTEM	Inspected
Cable System Exist?	Yes
Operational?	No
Main Equipment Rack	Does not exist