

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M081

School: MID MAN ADULT LRNG CTR (81) - M, 212 W 120TH ST, MANHATTAN, NY, 10027

| InspectionId | Inspection Type | Time In | Last Edited |
|--------------|-----------------|--------------------|--------------------|
| 777 | ELECTRICAL | 2018-12-14 09:09AM | 2018-12-19 08:33AM |

Asset Data

| Question | Answer |
|---|--|
| Have any Systems/Major Building Components been upgraded? | Systems: Computer Lab Room 201 (Raceway With Receptacles) Years: 2014 Systems: Auditorium (Local Sound System, Projection System) Years: 2013 Systems: Service Switch, Switchboard, Grounding System Years: 2011 Systems: Telephone System Years: 2008 Systems: Fire Alarm System, Auxiliary Signal/Bell System Years: 2005 Systems: Interior Fluorescent Lighting Years: 2004 Systems: LAN Years: 2003 Systems: Partial Motor Starters Years: 1999, 2011 Systems: Partial Molded Case Circuit Breaker Panel Board Years: 1987, 2001, 2011 Systems: Partial Security Lights Years: 2014 Systems: LED Lighting Years: 2018 Systems: Public Address Systems Years: 2008, 2017 Systems: Intrusion Alarm System Years: 2000 Systems: Emergency Light/Exit Light Panel Years: 2003 |
| Type of Service | Below Ground |
| Does Interactive Whiteboard (IWB) Exist? | Yes |
| Water Penetration In Electrical Room? | No |

DEDICATED INTERCOMS IN FIRE RESCUE AREAS

| Question | Response |
|---|----------|
| Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building? | No |

Priority Condition

| Exist Last Year? | Priority Category | Condition Description | Component Affected | Location Description | Person(s) Notified | Person(s) Title | Photo Image |
|------------------|---|-----------------------|--------------------------------|-----------------------|--------------------|-----------------|----------------|
| Yes | Fire Alarm System - Defective | N/A | Fire Alarm System - Main Panel | Main Entrance Lobby | Alcindor Fernandes | Fireman | No Photo Taken |
| Yes | Local Sound System - Not Connected to Public Address System | N/A | Local Sound System | Auditorium | Alcindor Fernandes | Fireman | No Photo Taken |
| Yes | Exposed Electrical Wires | N/A | Raceway With Receptacles | Computer Lab Room 303 | Alcindor Fernandes | Fireman | No Photo Taken |

Inspection

| Question | Response |
|-------------------|----------------|
| Electrical | |
| ATHLETIC FIELD | Does not exist |

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M081

| Question | Response |
|---|--|
| AUDITORIUM | |
| Instance on Basement | Inspected |
| House Lighting | |
| Instance on Basement | Inspected |
| Does a Chandelier Exist? | Yes |
| Lighting Fixture - Fluorescent | |
| Instance on Basement | Does not exist |
| Lighting Fixture - HID | |
| Instance on Basement | Does not exist |
| Lighting Fixture - Incandescent | |
| Instance on Basement | Inspected |
| Pendant Mounted | |
| Instance on Basement | Inspected |
| Instance Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Recessed Mounted | |
| Instance on Basement | Does not exist |
| Surface Mounted | |
| Instance on Basement | Inspected |
| Instance Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Lighting Fixture - LED | |
| Instance on Basement | Does not exist |
| Local Sound System | |
| Instance on Basement | Inspected |
| Instance Condition | 2- Between Good and Fair |
| Installation Year | 2013 |
| Source of Installation Year | Custodial Staff |
| Deficiency | NOT CONNECTED TO PUBLIC ADDRESS SYSTEM |
| Deficiency Quantity | 1 |
| Quantity Uom | EACH |
| Potential Action | INSTALL CONNECTION |
| Urgency of Action | PRIORITY 5 |
| Purpose of Action | LEVEL 6 |
| Violations | No violations recorded |
| Projection System | |
| Instance on Basement | Inspected |
| Instance Condition | 1- Good |
| Is the projector on a cart or installed on the ceiling? | Cart |
| Deficiency | No deficiencies recorded |
| Theater Lighting System | |
| Instance on Basement | Does not exist |
| AUXILIARY SIGNAL/BELL SYSTEM | |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| CAFETERIA | |
| Instance on Room 108 | Inspected |
| Lighting | |
| Instance on Room 108 | Inspected |
| Lighting Fixture - Fluorescent | |
| Instance on Room 108 | Inspected |
| Pendant Mounted | |
| Instance on Room 108 | Inspected |
| Instance Condition | 3- Fair |

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M081

| Question | Response |
|--|--------------------------|
| CAFETERIA | |
| Lighting | |
| Lighting Fixture - Fluorescent | |
| Pendant Mounted | |
| Deficiency | No deficiencies recorded |
| Recessed Mounted | |
| Instance on Room 108 | Does not exist |
| Surface Mounted | |
| Instance on Room 108 | Does not exist |
| Lighting Fixture - HID | |
| Instance on Room 108 | Does not exist |
| Lighting Fixture - Incandescent | |
| Instance on Room 108 | Does not exist |
| Lighting Fixture - LED | |
| Instance on Room 108 | Does not exist |
| Local Sound System | |
| Instance on Room 108 | Does not exist |
| Projection System | |
| Instance on Room 108 | Does not exist |
| Theater Lighting System | |
| Instance on Room 108 | Does not exist |
| CITY FIRE ALARM SYSTEM | |
| Condition | Inspected |
| Deficiency | 3- Fair |
| Deficiency | No deficiencies recorded |
| CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE | |
| Condition | Inspected |
| Lighting | |
| Does a Chandelier Exist? | No |
| Lighting Fixture - Fluorescent | |
| Pendant Mounted | |
| Condition | Inspected |
| Deficiency | 3- Fair |
| Deficiency | No deficiencies recorded |
| Recessed Mounted | |
| Condition | Inspected |
| Deficiency | 3- Fair |
| Deficiency | No deficiencies recorded |
| Surface Mounted | |
| Condition | Inspected |
| Deficiency | 3- Fair |
| Deficiency | No deficiencies recorded |
| Lighting Fixture - HID | |
| Condition | Does not exist |
| Lighting Fixture - Incandescent | |
| Condition | Does not exist |
| Lighting Fixture - LED | |
| Pendant Mounted | |
| Condition | Inspected |
| Deficiency | 1- Good |
| Deficiency | No deficiencies recorded |
| Recessed Mounted | |
| Condition | Does not exist |
| Surface Mounted | |
| Condition | Does not exist |
| COMPUTER LAB | |
| Instance on Rooms 303, 215 | Inspected |
| Power Panel? | No |
| Instance on Rooms 208, 217 | Inspected |
| Power Panel? | Yes |
| Instance on Room 201 | Inspected |
| Power Panel? | Yes |
| Lighting | |

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M081

| Question | Response |
|---|--------------------------|
| COMPUTER LAB | |
| Lighting | |
| Instance on Rooms 303, 215 | Inspected |
| Instance on Rooms 208, 217 | Inspected |
| Instance on Room 201 | Inspected |
| Lighting Fixture - Fluorescent | |
| Instance on Rooms 303, 215 | Inspected |
| Instance on Rooms 208, 217 | Inspected |
| Instance on Room 201 | Inspected |
| Pendant Mounted | |
| Instance on Rooms 303, 215 | Inspected |
| Instance Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Instance on Rooms 208, 217 | Inspected |
| Instance Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Instance on Room 201 | Inspected |
| Instance Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Recessed Mounted | |
| Instance on Rooms 303, 215 | Does not exist |
| Instance on Rooms 208, 217 | Does not exist |
| Instance on Room 201 | Does not exist |
| Surface Mounted | |
| Instance on Rooms 303, 215 | Does not exist |
| Instance on Rooms 208, 217 | Does not exist |
| Instance on Room 201 | Does not exist |
| Lighting Fixture - HID | |
| Instance on Rooms 303, 215 | Does not exist |
| Instance on Rooms 208, 217 | Does not exist |
| Instance on Room 201 | Does not exist |
| Lighting Fixture - Incandescent | |
| Instance on Rooms 303, 215 | Does not exist |
| Instance on Rooms 208, 217 | Does not exist |
| Instance on Room 201 | Does not exist |
| Lighting Fixture - LED | |
| Instance on Rooms 303, 215 | Does not exist |
| Instance on Rooms 208, 217 | Does not exist |
| Instance on Room 201 | Does not exist |
| Raceway With Receptacles | |
| Instance on Rooms 303, 215 | Inspected |
| Instance Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Instance on Rooms 208, 217 | Inspected |
| Instance Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Instance on Room 201 | Inspected |
| Instance Condition | 1- Good |
| Deficiency | No deficiencies recorded |
| EMERGENCY DC STANDBY BATTERY POWER | Does not exist |
| EMERGENCY GENERATOR SET | Does not exist |
| EMERGENCY LIGHT/EXIT LIGHT PANEL | Inspected |
| Condition | 3- Fair |

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M081

| Question | Response |
|---|--------------------------------------|
| EMERGENCY LIGHT/EXIT LIGHT PANEL | |
| Deficiency | LESS THAN 20% SPARE CIRCUIT BREAKERS |
| Deficiency Location/Instance | Boiler Room |
| Deficiency Quantity | 1 |
| Quantity Uom | EACH |
| Potential Action | INSTALL NEW PANEL BOARD |
| Urgency of Action | PRIORITY 5 |
| Purpose of Action | LEVEL 2 |
| Violations | No violations recorded |
| EMERGENCY LIGHTING | |
| | Inspected |
| Battery Pack | Inspected |
| Condition | 3- Fair |
| Deficiency | BATTERY NOT OPERATIONAL |
| Deficiency Location/Instance | Basement Corridor, Boiler Room |
| Deficiency Quantity | 6 |
| Quantity Uom | EACH |
| Potential Action | REPLACE BATTERY |
| Urgency of Action | PRIORITY 5 |
| Purpose of Action | LEVEL 2 |
| Violations | No violations recorded |
| Non Battery Pack | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| EXIT LIGHT | |
| | Inspected |
| Battery Pack | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Non Battery Pack | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| EXIT/EMERGENCY LIGHT | |
| | Does not exist |
| FIRE ALARM SYSTEM | |
| | Inspected |
| Area Smoke Detector | Inspected |
| Condition | 2- Between Good and Fair |
| Deficiency | No deficiencies recorded |
| Bell/Horn | Inspected |
| Condition | 2- Between Good and Fair |
| Deficiency | No deficiencies recorded |
| CO Detector | Inspected |
| Condition | 2- Between Good and Fair |
| Deficiency | No deficiencies recorded |
| Duct Smoke Detector | Inspected |
| Condition | 2- Between Good and Fair |
| Deficiency | No deficiencies recorded |
| Elevator Recall | Does not exist |
| Fan Shutdown Control | Inspected |
| Condition | 2- Between Good and Fair |
| Deficiency | No deficiencies recorded |
| Fire Alarm Digital Communicator | Does not exist |
| Fused Cutout Panel | Inspected |
| Condition | 2- Between Good and Fair |
| Deficiency | No deficiencies recorded |
| Heat Detector | Inspected |
| Condition | 2- Between Good and Fair |

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M081

| Question | Response |
|--|---------------------------|
| FIRE ALARM SYSTEM | |
| Heat Detector | |
| Deficiency | No deficiencies recorded |
| Magnetic Door Holder/Contactor | Does not exist |
| Main Panel | Inspected |
| Bell At Panel | Inspected |
| Condition | 2- Between Good and Fair |
| Deficiency | No deficiencies recorded |
| Fire Alarm Control Panel (Electronic) | Inspected |
| Instance | Main Entrance Lobby |
| Instance Condition | 3- Fair |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Manufacturer | Edwards System Technology |
| Model | EST 2 |
| EquipmentId | Fire Alarm Control Panel |
| Capacity/Size Quantity | 16 |
| Capacity/Size UOM | Zones |
| Capacity/Size 2 Quantity | 1 |
| Capacity/Size 2 UOM | Section(s) |
| Source of Capacity/Size | Diagram |
| Installation Year | 2005 |
| Source of Installation Year | Documented |
| Deficiency | PANEL DEFECTIVE |
| Deficiency Quantity | 1 |
| Quantity Uom | EACH |
| Potential Action | REPAIR |
| Urgency of Action | PRIORITY 5 |
| Purpose of Action | LEVEL 6 |
| Violations | E499344 |
| Fire Alarm Control Panel (Standard) | Does not exist |
| Manual Pull Station | Inspected |
| Condition | 2- Between Good and Fair |
| Deficiency | No deficiencies recorded |
| Remote Annunciator | Inspected |
| Display Monitor | Does not exist |
| Panel | Inspected |
| Condition | 2- Between Good and Fair |
| Deficiency | No deficiencies recorded |
| Printer | Inspected |
| Condition | 5- Poor |
| Deficiency | PRINTER NOT OPERATIONAL |
| Deficiency Location/Instance | Custodian's Office |
| Deficiency Quantity | 1 |
| Quantity Uom | EACH |
| Potential Action | REPLACE |
| Urgency of Action | PRIORITY 5 |
| Purpose of Action | LEVEL 2 |
| Violations | No violations recorded |
| Punch Register | Does not exist |
| Sprinkler Flow/Air Pressure Switch | Inspected |
| Condition | 2- Between Good and Fair |
| Deficiency | No deficiencies recorded |
| Strobe | Inspected |
| Condition | 2- Between Good and Fair |

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M081

| Question | Response |
|---|--------------------------|
| FIRE ALARM SYSTEM | |
| Strobe | |
| Deficiency | No deficiencies recorded |
| Sub-Panel | Does not exist |
| Tamper Flow Switch/Chain | Inspected |
| Condition | 2- Between Good and Fair |
| Deficiency | No deficiencies recorded |
| GROUNDING SYSTEM | Inspected |
| Condition | 2- Between Good and Fair |
| Deficiency | No deficiencies recorded |
| GYMNASIUM | Does not exist |
| INTERCOM SYSTEM | Does not exist |
| KITCHEN | Does not exist |
| LAN | Inspected |
| Local Distribution Frame (I/LDF) | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Main Equipment Rack (MDF) | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| LIBRARY | Does not exist |
| LIGHTNING PROTECTION | Does not exist |
| LOCKER ROOM | Does not exist |
| MOTOR CONTROL CENTER | Does not exist |
| MOTOR STARTER/CONTACTOR | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| MULTIPURPOSE ROOM | |
| Instance on 1st Floor | Inspected |
| Lighting | |
| Instance on 1st Floor | Inspected |
| Lighting Fixture - Fluorescent | |
| Instance on 1st Floor | Inspected |
| Pendant Mounted | |
| Instance on 1st Floor | Does not exist |
| Recessed Mounted | |
| Instance on 1st Floor | Does not exist |
| Surface Mounted | |
| Instance on 1st Floor | Inspected |
| Instance Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Lighting Fixture - HID | |
| Instance on 1st Floor | Does not exist |
| Lighting Fixture - Incandescent | |
| Instance on 1st Floor | Does not exist |
| Lighting Fixture - LED | |
| Instance on 1st Floor | Does not exist |
| Local Sound System | |
| Instance on 1st Floor | Does not exist |
| Projection System | |
| Instance on 1st Floor | Does not exist |
| Theater Lighting System | |

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M081

| Question | Response |
|---|--|
| MULTIPURPOSE ROOM | |
| Theater Lighting System | |
| Instance on 1st Floor | Does not exist |
| PANEL BOARD | |
| | Inspected |
| Fused Disconnect Switch Type | Does not exist |
| Fused Knife Switch Type | Does not exist |
| Fused Toggle Switch Type | Does not exist |
| Molded Case Circuit Breaker Type | Inspected |
| Condition | 2- Between Good and Fair |
| Deficiency | PANEL BOARD BEYOND USEFUL LIFE |
| Deficiency Location/Instance | Corridors, Multipurpose Room |
| Deficiency Quantity | 10 |
| Quantity Uom | EACH |
| Potential Action | REPLACE-UPGRADE |
| Urgency of Action | PRIORITY 1 |
| Purpose of Action | LEVEL 2 |
| Violations | No violations recorded |
| Deficiency | PANEL BOARD DIRECTORY MISSING OR REQUIRES UPDATING |
| Deficiency Location/Instance | Multipurpose Room |
| Deficiency Quantity | 1 |
| Quantity Uom | EACH |
| Potential Action | MAINTENANCE |
| Urgency of Action | PRIORITY 2 |
| Purpose of Action | LEVEL 2 |
| Violations | No violations recorded |
| PUBLIC ADDRESS SYSTEM | |
| | Inspected |
| Instance | General Office - Room 111 |
| Instance Condition | 2- Between Good and Fair |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Model | |
| Installation Year | 2008 |
| Source of Installation Year | Custodial Staff |
| Deficiency | No deficiencies recorded |
| Instance | General Office - Room 401 |
| Instance Condition | 1- Good |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Model | |
| Installation Year | 2017 |
| Source of Installation Year | Inspector Estimate |
| Deficiency | No deficiencies recorded |
| SCIENCE DEMO ROOM | |
| Instance on Rooms 211, 311 | Inspected |
| Power Panel? | No |
| Alternative Use | Yes |
| Emergency Gas Shut-Off Valve | |
| Instance on Rooms 211, 311 | Does not exist |
| Emergency Shut-Off Power | |
| Instance on Rooms 211, 311 | Does not exist |
| Lighting | |
| Instance on Rooms 211, 311 | Inspected |
| Lighting Fixture - Fluorescent | |

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M081

| Question | Response |
|--|--------------------------------|
| SCIENCE DEMO ROOM | |
| Lighting | |
| Lighting Fixture - Fluorescent | |
| Instance on Rooms 211, 311 | Inspected |
| Pendant Mounted | |
| Instance on Rooms 211, 311 | Inspected |
| Instance Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Recessed Mounted | |
| Instance on Rooms 211, 311 | Does not exist |
| Surface Mounted | |
| Instance on Rooms 211, 311 | Does not exist |
| Lighting Fixture - HID | |
| Instance on Rooms 211, 311 | Does not exist |
| Lighting Fixture - Incandescent | |
| Instance on Rooms 211, 311 | Does not exist |
| Lighting Fixture - LED | |
| Instance on Rooms 211, 311 | Does not exist |
| Power Supply | |
| Instance on Rooms 211, 311 | Does not exist |
| Projection System | |
| Instance on Rooms 211, 311 | Does not exist |
| SCIENCE LAB | |
| Does not exist | |
| SCIENCE PREP ROOM | |
| Does not exist | |
| SECURITY | |
| Inspected | |
| Intrusion Alarm System | |
| Inspected | |
| Central Control Panel | |
| Inspected | |
| Instance | Custodian's Office - Room 100A |
| Instance Condition | 3- Fair |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Model | N/A |
| Installation Year | 2000 |
| Source of Installation Year | Inspector Estimate |
| Deficiency | No deficiencies recorded |
| Infrared Sensor | |
| Inspected | |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Panic Switch | |
| Inspected | |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Remote Annunciator | |
| Inspected | |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Siren/Strobe | |
| Inspected | |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Ultrasonic Sensor | |
| Does not exist | |
| IPDVS/CCTV System | |
| Does not exist | |
| Lighting - Security | |
| Inspected | |
| Condition | 3- Fair |
| Replacement Quantity | 12 |
| Replacement Uom | EACH |

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M081

| Question | Response |
|---|-------------------------------------|
| SECURITY | |
| Lighting - Security | |
| Deficiency | LIGHTING FIXTURE BEYOND USEFUL LIFE |
| Deficiency Location/Instance | Building Perimeters |
| Deficiency Quantity | 9 |
| Quantity Uom | EACH |
| Potential Action | REPLACE-UPGRADE |
| Urgency of Action | PRIORITY 1 |
| Purpose of Action | LEVEL 3 |
| Violations | No violations recorded |
| SERVICE SWITCH | |
| | Inspected |
| Instance | Electrical Meter Room 004A |
| Instance Condition | 2- Between Good and Fair |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Manufacturer | All City Switchboard |
| EquipmentId | Service Switch #1 |
| Capacity/Size Quantity | 1600 |
| Capacity/Size UOM | Amps |
| Source of Capacity/Size | Nameplate |
| Installation Year | 2011 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |
| SWIMMING POOL | |
| | Does not exist |
| SWITCHBOARD | |
| | Inspected |
| Number of Spares | 4 |
| Air Circuit Breaker Type | |
| | Does not exist |
| Fused Disconnect Switch Type | |
| | Inspected |
| Instance | Boiler Room |
| Instance Condition | 2- Between Good and Fair |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Manufacturer | Siemens |
| EquipmentId | MDP Section #1,2,3 |
| Capacity/Size Quantity | 1600 |
| Capacity/Size UOM | Amps Total |
| Capacity/Size 2 Quantity | 3 |
| Capacity/Size 2 UOM | Section(s) |
| Source of Capacity/Size | Service Switch Size |
| Installation Year | 2011 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |
| Fused Knife Switch Type | |
| | Does not exist |
| Molded Case Circuit Breaker Type | |
| | Does not exist |
| TELEPHONE SYSTEM | |
| | Inspected |
| PBX/Intercom | |
| | Inspected |
| Condition | 2- Between Good and Fair |
| Deficiency | No deficiencies recorded |
| Standard | |
| | Inspected |
| Condition | 2- Between Good and Fair |
| Deficiency | No deficiencies recorded |
| TOILET ROOM - STAFF | |
| | Inspected |
| Lighting | |
| | Inspected |
| Lighting Fixture - Fluorescent | |
| | Inspected |
| Pendant Mounted | |
| | Inspected |

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M081

| Question | Response |
|--|--------------------------|
| TOILET ROOM - STAFF | |
| Lighting | |
| Lighting Fixture - Fluorescent | |
| Pendant Mounted | |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Recessed Mounted | Does not exist |
| Surface Mounted | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Lighting Fixture - HID | Does not exist |
| Lighting Fixture - Incandescent | Does not exist |
| Lighting Fixture - LED | Does not exist |
| TOILET ROOM - STUDENT | Inspected |
| Lighting | Inspected |
| Lighting Fixture - Fluorescent | Inspected |
| Pendant Mounted | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Recessed Mounted | Does not exist |
| Surface Mounted | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Lighting Fixture - HID | Does not exist |
| Lighting Fixture - Incandescent | Does not exist |
| Lighting Fixture - LED | Does not exist |
| TRANSFORMER | Does not exist |
| TV SYSTEM | Does not exist |