

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M263

School: P.S./I.S. 263 - MANHATTAN, 202 SHERMAN AVENUE, MANHATTAN, NY, 10034

InspectionId	Inspection Type	Time In	Last Edited
1192	ELECTRICAL	2019-01-04 08:50AM	2019-06-25 07:32PM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: IPDVS/CCTV System Years: 2018 Systems: City Fire Alarm System Years: 2017 Systems: All Other Electrical Systems and Components Years: 2010
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	Yes
Water Penetration In Electrical Room?	No

DEDICATED INTERCOMS IN FIRE RESCUE AREAS

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	Yes
Are dedicated intercoms available in all of these spaces for use during a fire?	Yes
Are all dedicated intercoms operational?	Yes

Priority Condition

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image
No	Water Leaks onto Electrical Equipment	N/A	Lighting Fixture	Room 510	Charles Harvey	Custodian	No Photo Taken

Inspection

Question	Response
Electrical	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Does not exist
AUXILIARY SIGNAL/BELL SYSTEM	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
CAFETERIA	
Instance on Cellar	Inspected
Lighting	
Instance on Cellar	Inspected
Lighting Fixture - Fluorescent	
Instance on Cellar	Inspected
Pendant Mounted	
Instance on Cellar	Does not exist
Recessed Mounted	
Instance on Cellar	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Cellar	Does not exist
Lighting Fixture - HID	
Instance on Cellar	Does not exist
Lighting Fixture - Incandescent	
Instance on Cellar	Does not exist
Lighting Fixture - LED	
Instance on Cellar	Does not exist
Local Sound System	

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M263

Question	Response
CAFETERIA	
Local Sound System	
Instance on Cellar	Inspected
Instance Condition	2- Between Good and Fair
Installation Year	2010
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Projection System	
Instance on Cellar	Does not exist
Theater Lighting System	
Instance on Cellar	Does not exist
CITY FIRE ALARM SYSTEM	
Condition	Inspected
Deficiency	1- Good
Deficiency	No deficiencies recorded
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
Lighting	
Does a Chandelier Exist?	Inspected
	No
Lighting Fixture - Fluorescent	
Pendant Mounted	
Condition	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Condition	Inspected
Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Condition	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
	Does not exist
Lighting Fixture - Incandescent	
	Inspected
Pendant Mounted	
	Does not exist
Recessed Mounted	
Condition	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	
	Does not exist
Lighting Fixture - LED	
	Does not exist
COMPUTER LAB	
Instance on Rooms 420 A/B, 524	Inspected
Power Panel?	No
Lighting	
Instance on Rooms 420 A/B, 524	Inspected
Lighting Fixture - Fluorescent	
Instance on Rooms 420 A/B, 524	Inspected
Pendant Mounted	
Instance on Rooms 420 A/B, 524	Does not exist
Recessed Mounted	
Instance on Rooms 420 A/B, 524	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M263

Question	Response
COMPUTER LAB	
Lighting	
Lighting Fixture - Fluorescent	
Surface Mounted	
Instance on Rooms 420 A/B, 524	Does not exist
Lighting Fixture - HID	
Instance on Rooms 420 A/B, 524	Does not exist
Lighting Fixture - Incandescent	
Instance on Rooms 420 A/B, 524	Does not exist
Lighting Fixture - LED	
Instance on Rooms 420 A/B, 524	Does not exist
Raceway With Receptacles	
Instance on Rooms 420 A/B, 524	Does not exist
EMERGENCY DC STANDBY BATTERY POWER	Does not exist
EMERGENCY GENERATOR SET	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
EMERGENCY LIGHTING	Inspected
Battery Pack	Inspected
Condition	2- Between Good and Fair
Deficiency	FIXTURE NOT OPERATIONAL
Deficiency Location/Instance	Main Entrance Lobby, 3rd Floor Corridor By Staircase A, 4th Floor By Staircase A, 1st Floor Corridor
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
Non Battery Pack	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
EXIT LIGHT	Inspected
Battery Pack	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
EXIT/EMERGENCY LIGHT	Does not exist
FIRE ALARM SYSTEM	Inspected
Area Smoke Detector	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Bell/Horn	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
CO Detector	Does not exist
Duct Smoke Detector	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Elevator Recall	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M263

Question	Response
FIRE ALARM SYSTEM	
Elevator Recall	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Fan Shutdown Control	
Condition	Inspected
Deficiency	2- Between Good and Fair
Fire Alarm Digital Communicator	
Instance	Inspected
Instance Condition	Telecom Room 206
Instance Quantity	2- Between Good and Fair
Instance Quantity Uom	1
Manufacturer	EACH
EquipmentId	Silent Knight
Capacity/Size Quantity	DACT Communicator
Capacity/Size UOM	5
Source of Capacity/Size	Zones
Installation Year	Inspector Estimate
Source of Installation Year	2010
Deficiency	Documented
Deficiency	No deficiencies recorded
Fused Cutout Panel	
Condition	Inspected
Deficiency	2- Between Good and Fair
Deficiency	No deficiencies recorded
Heat Detector	
Condition	Inspected
Deficiency	2- Between Good and Fair
Deficiency	No deficiencies recorded
Magnetic Door Holder/Contactor	
Condition	Inspected
Deficiency	2- Between Good and Fair
Deficiency	No deficiencies recorded
Main Panel	
Condition	Inspected
Bell At Panel	
Condition	Inspected
Deficiency	2- Between Good and Fair
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	
Instance	Inspected
Instance Condition	Main Entrance Lobby
Instance Quantity	2- Between Good and Fair
Instance Quantity Uom	1
Manufacturer	EACH
Model	General Electric
EquipmentId	EST 2
Capacity/Size Quantity	Fire Alarm Control
Capacity/Size UOM	16
Capacity/Size 2 Quantity	Zones
Capacity/Size 2 UOM	1
Source of Capacity/Size	Section(s)
Installation Year	Inspector Estimate
Source of Installation Year	2010
Deficiency	Documented
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	
Condition	Does not exist
Manual Pull Station	
Condition	Inspected
Deficiency	2- Between Good and Fair
Deficiency	No deficiencies recorded
Remote Annunciator	
Condition	Inspected
Display Monitor	
Condition	Does not exist

NYC Department of Education
Building Condition Assessment Survey 2018-2019

Electrical Inspection

M263

Question	Response
FIRE ALARM SYSTEM	
Remote Annunciator	
Panel	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Printer	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Punch Register	Does not exist
Sprinkler Flow/Air Pressure Switch	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Strobe	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Sub-Panel	Does not exist
Tamper Flow Switch/Chain	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
GYMNASIUM	
Instance on Cellar	Inspected
Lighting	
Instance on Cellar	Inspected
Lighting Fixture - Fluorescent	
Instance on Cellar	Inspected
Pendant Mounted	
Instance on Cellar	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Cellar	Does not exist
Surface Mounted	
Instance on Cellar	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Cellar	Does not exist
Lighting Fixture - Incandescent	
Instance on Cellar	Does not exist
Lighting Fixture - LED	
Instance on Cellar	Does not exist
Local Sound System	
Instance on Cellar	Inspected
Instance Condition	2- Between Good and Fair
Installation Year	2010
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Projection System	
Instance on Cellar	Inspected
Instance Condition	2- Between Good and Fair

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M263

Question	Response
GYMNASIUM	
Projection System	
Is the projector on a cart or installed on the ceiling?	Ceiling
Deficiency	No deficiencies recorded
Scoreboard	
Instance on Cellar	Does not exist
Theater Lighting System	
Instance on Cellar	Inspected
Dimming System	
Instance on Cellar	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Theater Lighting	
Instance on Cellar	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
INTERCOM SYSTEM	
	Inspected
Elevator	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Holding Area	
	Does not exist
KITCHEN	
Instance on Cellar	Inspected
Lighting	
Instance on Cellar	Inspected
Lighting Fixture - Fluorescent	
Instance on Cellar	Inspected
Pendant Mounted	
Instance on Cellar	Does not exist
Recessed Mounted	
Instance on Cellar	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Cellar	Does not exist
Lighting Fixture - HID	
Instance on Cellar	Does not exist
Lighting Fixture - Incandescent	
Instance on Cellar	Does not exist
Lighting Fixture - LED	
Instance on Cellar	Does not exist
LAN	
	Inspected
Local Distribution Frame (I/LDF)	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Main Equipment Rack (MDF)	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LIBRARY	
Instance on Room 301	Inspected
Lighting	
Instance on Room 301	Inspected
Lighting Fixture - Fluorescent	

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M263

Question	Response
LIBRARY	
Lighting	
Lighting Fixture - Fluorescent	
Instance on Room 301	Inspected
Pendant Mounted	
Instance on Room 301	Does not exist
Recessed Mounted	
Instance on Room 301	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Room 301	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Room 301	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 301	Does not exist
Lighting Fixture - LED	
Instance on Room 301	Does not exist
Projection System	
Instance on Room 301	Does not exist
Raceway With Receptacles	
Instance on Room 301	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LIGHTNING PROTECTION	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LOCKER ROOM	
Instance on Rooms C14 - Boys, C12 - Girls	Inspected
Alternative Use	Yes
Lighting	
Instance on Rooms C14 - Boys, C12 - Girls	Inspected
Lighting Fixture - Fluorescent	
Instance on Rooms C14 - Boys, C12 - Girls	Inspected
Pendant Mounted	
Instance on Rooms C14 - Boys, C12 - Girls	Does not exist
Recessed Mounted	
Instance on Rooms C14 - Boys, C12 - Girls	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Rooms C14 - Boys, C12 - Girls	Does not exist
Lighting Fixture - HID	
Instance on Rooms C14 - Boys, C12 - Girls	Does not exist
Lighting Fixture - Incandescent	
Instance on Rooms C14 - Boys, C12 - Girls	Does not exist
Lighting Fixture - LED	
Instance on Rooms C14 - Boys, C12 - Girls	Does not exist
MOTOR CONTROL CENTER	Does not exist
MOTOR STARTER/CONTACTOR	Inspected
Condition	2- Between Good and Fair

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M263

Question	Response
MOTOR STARTER/CONTACTOR	
Deficiency	No deficiencies recorded
MULTIPURPOSE ROOM	Does not exist
PANEL BOARD	Inspected
Fused Disconnect Switch Type	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Fused Knife Switch Type	Does not exist
Fused Toggle Switch Type	Does not exist
Molded Case Circuit Breaker Type	Inspected
Condition	2- Between Good and Fair
Deficiency	PANEL BOARD DIRECTORY MISSING OR REQUIRES UPDATING
Deficiency Location/Instance	Electrical Closet - 5th Floor
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
PUBLIC ADDRESS SYSTEM	Inspected
Instance	Telecom Room 206
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Rauland MPA 250
Installation Year	2010
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	Does not exist
SCIENCE LAB	
Instance on Room 202	Inspected
Power Panel?	Yes
Alternative Use	Yes
Instance on Room 502	Inspected
Power Panel?	Yes
Alternative Use	No
Emergency Gas Shut-Off Valve	
Instance on Room 202	Does not exist
Instance on Room 502	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Emergency Shut-Off Power	
Instance on Room 202	Does not exist
Instance on Room 502	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting	
Instance on Room 202	Inspected
Instance on Room 502	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 202	Inspected
Instance on Room 502	Inspected

NYC Department of Education
Building Condition Assessment Survey 2018-2019

Electrical Inspection

M263

Question	Response
SCIENCE LAB	
Lighting	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Instance on Room 202	Does not exist
Instance on Room 502	Does not exist
Recessed Mounted	
Instance on Room 202	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 502	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Room 202	Does not exist
Instance on Room 502	Does not exist
Lighting Fixture - HID	
Instance on Room 202	Does not exist
Instance on Room 502	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 202	Does not exist
Instance on Room 502	Does not exist
Lighting Fixture - LED	
Instance on Room 202	Does not exist
Instance on Room 502	Does not exist
Power Supply	
Instance on Room 202	Does not exist
Instance on Room 502	Inspected
Instructor Unit	
Instance on Room 502	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Meter Demonstration Unit	
Instance on Room 502	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Student Unit	
Instance on Room 502	Does not exist
Projection System	
Instance on Room 202	Does not exist
Instance on Room 502	Does not exist
SCIENCE PREP ROOM	
Instance on Room 202A	Inspected
Power Panel?	No
Alternative Use	Yes
Instance on Room 502A	Inspected
Power Panel?	No
Alternative Use	No
Emergency Gas Shut-Off Valve	
Instance on Room 202A	Does not exist
Instance on Room 502A	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M263

Question	Response
SCIENCE PREP ROOM	
Emergency Shut-Off Power	
Instance on Room 202A	Does not exist
Instance on Room 502A	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting	
Instance on Room 202A	Inspected
Instance on Room 502A	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 202A	Inspected
Instance on Room 502A	Inspected
Pendant Mounted	
Instance on Room 202A	Does not exist
Instance on Room 502A	Does not exist
Recessed Mounted	
Instance on Room 202A	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 502A	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Room 202A	Does not exist
Instance on Room 502A	Does not exist
Lighting Fixture - HID	
Instance on Room 202A	Does not exist
Instance on Room 502A	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 202A	Does not exist
Instance on Room 502A	Does not exist
Lighting Fixture - LED	
Instance on Room 202A	Does not exist
Instance on Room 502A	Does not exist
Power Supply	
Instance on Room 202A	Does not exist
Instance on Room 502A	Does not exist
SECURITY	
Intrusion Alarm System	
Central Control Panel	
Instance	Custodian's Office - Room 112
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista - 128BP
Installation Year	2010
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Infrared Sensor	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Panic Switch	
Condition	2- Between Good and Fair

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M263

Question	Response
SECURITY	
Intrusion Alarm System	
Panic Switch	
Deficiency	No deficiencies recorded
Remote Annunciator	
Condition	Inspected
Deficiency	2- Between Good and Fair
Siren/Strobe	
Condition	Inspected
Deficiency	2- Between Good and Fair
Ultrasonic Sensor	
Deficiency	No deficiencies recorded
IPDVS/CCTV System	
Condition	Does not exist
Installation Year	Inspected
Source of Installation Year	1- Good
Deficiency	2018
Deficiency	Documented
Deficiency	No deficiencies recorded
Lighting - Security	
Condition	Inspected
Replacement Quantity	2- Between Good and Fair
Replacement Uom	30
Deficiency	EACH
Deficiency	No deficiencies recorded
SERVICE SWITCH	
Instance	Inspected
Instance Condition	Electrical Room C05
Instance Quantity	2- Between Good and Fair
Instance Quantity Uom	1
Manufacturer	EACH
EquipmentId	Cutler Hammer
Capacity/Size Quantity	SSW#1 3000A Service Disconnect
Capacity/Size UOM	3000
Source of Capacity/Size	Amps
Installation Year	Nameplate
Source of Installation Year	2010
Deficiency	Documented
Deficiency	No deficiencies recorded
Instance	Electrical Room C05
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Cutler Hammer
EquipmentId	SSW#2 2000A Service Disconnect
Capacity/Size Quantity	2000
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	2010
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Electrical Room C05
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Cutler Hammer
EquipmentId	SSW#3 400A Fire Pump Switch
Capacity/Size Quantity	400
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

M263

Question	Response
SERVICE SWITCH	
Installation Year	2010
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
SWIMMING POOL	Does not exist
SWITCHBOARD	Inspected
Number of Spares	15
Air Circuit Breaker Type	Does not exist
Fused Disconnect Switch Type	Inspected
Instance	Electrical Room C05
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Cutler Hammer
EquipmentId	HDB Section # 1, 2, 3 3000A
Capacity/Size Quantity	3000
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	3
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Nameplate
Installation Year	2010
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Electrical Room C05
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Cutler Hammer
EquipmentId	MDB Section #1, 2 2000A
Capacity/Size Quantity	2000
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	2
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Nameplate
Installation Year	2010
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fused Knife Switch Type	Does not exist
Molded Case Circuit Breaker Type	Does not exist
TELEPHONE SYSTEM	Inspected
PBX/Intercom	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Standard	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
TOILET ROOM - STAFF	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	Does not exist
Lighting Fixture - HID	Does not exist

NYC Department of Education
Building Condition Assessment Survey 2018-2019

Electrical Inspection

M263

Question	Response
TOILET ROOM - STAFF	
Lighting	
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Does not exist
TOILET ROOM - STUDENT	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	Does not exist
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Does not exist
TRANSFORMER	Does not exist
TV SYSTEM	Inspected
Cable System Exist?	Yes
Operational?	Yes
Main Equipment Rack	Does not exist