

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Mechanical Inspection

M267




School: P.S. 59 (MEETH) - MANHATTAN, 213 EAST 63 STREET, MANHATTAN, NY, 10065

InspectionId	Inspection Type	Time In	Last Edited
1046	MECHANICAL	2018-12-28 08:09AM	2019-01-24 01:39AM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: MDF Room - Dedicated A/C Equipment (1 of 2, DX Split System) Years: 2018
Are there fuel tanks?	Yes
Total # of above ground tanks	1
Total capacity of all above ground tanks in gal.	275
Total # of below ground tanks	0
Total capacity of all below ground tanks in gal.	0
Total # of water main service entries to the asset	2
MERs/Fan Rooms Locations	Fire Pump Room C03, Steam Room C05, Gas Meter/Ejector Pump Room C015; MERs C14B, 701, 703, 801, 803
Are there any Painted/Obstructed Sprinkler Heads?	Room 602B (obstructed, 2)
Are there any Emergency Stop Switches with Missing Hammers?	No components

Priority Condition

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image
No	Defective Sprinkler/Standpipe System	Fire Booster Pump Controller in fault	Fire Booster Pump Assembly	Fire Pump Room C03	Angelo Simoncini	Fireman	
No	Defective CO/Gas Leak Detection	Defective Sensor	CO/Gas Leak Detection	Gas Meter / Ejector Pump Room C015	Angelo Simoncini	Fireman	
No	Defective Fire/Smoke Damper	(1)	Metal Ductwork	1st Floor	Angelo Simoncini	Fireman	

Inspection

Question	Response
Mechanical	
AIR CONDITIONING	Inspected
Chilled Water System	Does not exist
Condenser Water Distribution: Piping, Pumps and Auxiliaries	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Cooling Coil in Ductwork	Does not exist
Cooling Tower	Inspected
Instance	Roof
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Baltimore Air Coil (BAC)

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Mechanical Inspection

M267

Question	Response
AIR CONDITIONING	
Cooling Tower	
EquipmentId	CT-1
Capacity/Size Quantity	100
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	2008
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Roof
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Baltimore Air Coil (BAC)
EquipmentId	CT-2
Capacity/Size Quantity	100
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	2008
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Dry Cooler	Does not exist
DX Split System	Inspected
Indoor Unit	Inspected
Condition	3- Fair
Deficiency	UP TO 5 TONS:DEFECTIVE
Deficiency Location/Instance	Kitchen - Storage Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Outdoor Unit	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Packaged / Rooftop Unit	Inspected
Instance	MER C14B
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Mammoth
EquipmentId	AC-1
Capacity/Size Quantity	21
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	2008
Source of Installation Year	Documented
Source of Heating	Steam
Deficiency	No deficiencies recorded
Instance	Room 109
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Mammoth
EquipmentId	AC-2

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Mechanical Inspection

M267

Question	Response
AIR CONDITIONING	
Packaged / Rooftop Unit	
Capacity/Size Quantity	5
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	2008
Source of Installation Year	Documented
Source of Heating	Steam
Deficiency	UP TO 20 TONS:DEFECTIVE UNIT
Deficiency Location/Instance	Room 109
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Room 106
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Mammoth
EquipmentId	AC-3
Capacity/Size Quantity	5
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	2008
Source of Installation Year	Documented
Source of Heating	Steam
Deficiency	UP TO 20 TONS:DEFECTIVE UNIT
Deficiency Location/Instance	Room 106
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	MER 703
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Mammoth
EquipmentId	AC-4
Capacity/Size Quantity	36
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	2008
Source of Installation Year	Documented
Source of Heating	Steam
Deficiency	No deficiencies recorded
Instance	MER 701
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Mammoth
EquipmentId	AC-5
Capacity/Size Quantity	40

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Mechanical Inspection

M267

Question	Response
AIR CONDITIONING	
Packaged / Rooftop Unit	
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	2008
Source of Installation Year	Documented
Source of Heating	Steam
Deficiency	OVER 20 TONS:DEFECTIVE UNIT
Deficiency Location/Instance	MER 701
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	MER 803
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Mammoth
EquipmentId	AC-6
Capacity/Size Quantity	23
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	2008
Source of Installation Year	Documented
Source of Heating	Steam
Deficiency	No deficiencies recorded
Instance	Roof
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	McQuay
EquipmentId	AC-7
Capacity/Size Quantity	36
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	2008
Source of Installation Year	Documented
Source of Heating	Steam
Deficiency	No deficiencies recorded
Instance	MER 801
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Mammoth
EquipmentId	AC-8
Capacity/Size Quantity	15
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	2008
Source of Installation Year	Documented
Source of Heating	Steam
Deficiency	UP TO 20 TONS:DEFECTIVE EVAP FAN
Deficiency Location/Instance	MER 801
Deficiency Quantity	1
Quantity Uom	EACH

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Mechanical Inspection

M267

Question	Response
AIR CONDITIONING	
Packaged / Rooftop Unit	
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Packaged Terminal A/C	Inspected
Condition	3- Fair
Deficiency	DEFECTIVE
Deficiency Location/Instance	Elevator Machine Room 802
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Refrigerant Piping	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Return Fan	Inspected
Condition	2- Between Good and Fair
Deficiency	DEFECTIVE
Deficiency Location/Instance	MER 801 / RF #8-1
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
CENTRAL ACID WASTE NEUTRALIZING TANK	Does not exist
CLIMATE CONTROL SYSTEM	Inspected
BMS	Inspected
Instance	Throughout
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	0-20%
Installation Year	2008
Source of Installation Year	Documented
Deficiency	DEFECTIVE SYSTEM
Deficiency Location/Instance	Throughout
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Electric System	Does not exist
Hybrid System	Does not exist
Pneumatic System	Does not exist
COMPACTOR	Does not exist
CONVEYING	Inspected
Ash Hoist	Does not exist
Dumbwaiter	Does not exist
Elevator	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Mechanical Inspection

M267

Question	Response
CONVEYING	
Elevator	
Condition	2- Between Good and Fair
Are all the existing elevators operable?	No
Deficiency	No deficiencies recorded
Escalator	Does not exist
Non-auditorium Handicap Lift - Stair	Does not exist
Non-auditorium Handicap Lift - Vertical	Does not exist
Sidewalk Elevator	Does not exist
DOMESTIC WATER SYSTEM	
Domestic Cold Water System	Inspected
Gravity System	Does not exist
Pressure Booster System	Inspected
Electric Pressure Booster System	Inspected
Instance	Fire Pump Room C03
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Federal Pump
EquipmentId	N/A
Capacity/Size Quantity	2
Capacity/Size UOM	Total # Pumps
Capacity/Size 2 Quantity	20
Capacity/Size 2 UOM	Total Pumps HP
Source of Capacity/Size	Documented
Installation Year	2008
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Hydraulic/Pneumatic Booster System	Does not exist
Water Service	Inspected
Instance	Fire Pump Room C03
Instance Condition	1- Good
Instance Quantity	2
Instance Quantity Uom	EACH
Deficiency	No deficiencies recorded
Domestic Hot Water System	Inspected
Domestic Hot Water Remote Storage Tank	Does not exist
Domestic Water Heat Exchanger	Inspected
Condition	3- Fair
Deficiency	FLANGE/TUBE BUNDLE LEAKS
Deficiency Location/Instance	Steam Room C05 (1 of 2)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	Steam Room C05 (1 of 2)
Deficiency Quantity	150
Quantity Uom	S.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Mechanical Inspection

M267

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Hot Water System	
Electric Domestic Water Heater	Does not exist
Gas Fired Domestic Water Heater	Does not exist
Oil Fired Domestic Water Heater	Does not exist
Domestic Water Distribution Piping	Inspected
Condition	1- Good
Deficiency	DEFECTIVE DOMESTIC HOT WATER CIRCULATING PUMP
Deficiency Location/Instance	Steam Room C05
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	DEFECTIVE ISOLATION VALVE
Deficiency Location/Instance	Fire Pump Room C03 (mixing valve)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	DEFECTIVE BACKFLOW PREVENTER
Deficiency Location/Instance	Room 514A
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
DRAIN/WASTE/VENT AND STORM SYSTEM	Inspected
Interior Storm Piping	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Sewage Ejector Pump	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Sewage/Waste/Vent Piping	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Sump Pump	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	Does not exist
Enclosed IDF Room	
Instance on Rooms C02A, 508A	Inspected
Dedicated A/C Equipment	
Instance on Rooms C02A, 508A	Inspected
Instance Condition	3- Fair
Deficiency	DEFECTIVE
Deficiency Location/Instance	Rooms C02A, 508A
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Mechanical Inspection

M267

Question	Response
Enclosed IDF Room	
Dedicated A/C Equipment	
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
FIXTURES	Inspected
Staff And Other	Inspected
Janitor Sink	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Urinal	Does not exist
Student	Inspected
Drinking Fountain	Inspected
Condition	2- Between Good and Fair
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	2nd Floor Corridor near Elevator
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lavatory/Sink	Inspected
Condition	2- Between Good and Fair
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	Toilet Rooms 105, 302, 304, 402, 404, 502, 603, 605
Deficiency Quantity	8
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Locker Room Shower	Does not exist
Sink And Fountain Combo Unit	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Urinal	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
GAS FIRED FURNACE	Does not exist
GAS SERVICE	Inspected
CO/Gas Leak Detection	Inspected
Instance	Gas Meter / Ejector Pump Room C015

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Mechanical Inspection

M267

Question	Response
GAS SERVICE	
CO/Gas Leak Detection	
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Installation Year	2008
Source of Installation Year	Documented
Deficiency	DEFECTIVE SENSOR
Deficiency Location/Instance	Gas Meter / Ejector Pump Room C015
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
Gas Distribution Piping	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Gas Meter Room Exhaust Fan	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Gas Meter Room Vent	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Gas Pressure Booster	Does not exist
HEATING	Inspected
Heating Coil In Ductwork	Does not exist
Hydronic Heating	Inspected
Backflow Preventer	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Hot Water Heat Exchanger	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Hydronic Hot Water Distribution: Piping, Pumps and Auxiliaries	Inspected
Condition	1- Good
Deficiency	PUMP:DEFECTIVE MOTOR
Deficiency Location/Instance	Steam Room C05
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Radiator/Convactor/Fin Tube	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Steam Heating	Inspected
F&T/Steam Drip Trap	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
MER Steam and Condensate Piping	Inspected
Condition	2- Between Good and Fair
Deficiency	DEFECTIVE/LEAKS

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Mechanical Inspection

M267

Question	Response
HEATING	
Steam Heating	
MER Steam and Condensate Piping	
Deficiency Location/Instance	Steam Room C05
Deficiency Quantity	10
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Steam Condensate Return Piping	
Condition	Inspected
Deficiency	1- Good
Deficiency	No deficiencies recorded
Steam Condensate Return Pumping System	
Condition	Inspected
Deficiency	2- Between Good and Fair
Deficiency	No deficiencies recorded
Steam Piping	
Condition	Inspected
Condition	1- Good
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	Corridor near Room 106
Deficiency Quantity	10
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Terminal Unit Thermostatic Trap	
Condition	Does not exist
Steam supplied by External Sources	
Condition	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Unit Heater/Cabinet Heater	
Condition	Inspected
Condition	2- Between Good and Fair
Deficiency	DEFECTIVE
Deficiency Location/Instance	MER 801
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
HEATING PLANT	
Condition	Does not exist
KITCHEN	
Instance on Cellar	Inspected
CO Detector	
Instance on Cellar	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Gas System	
Instance on Cellar	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Grease Trap	
Instance on Cellar	Inspected
Instance Condition	5- Poor

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Mechanical Inspection

M267

Question	Response
KITCHEN	
Grease Trap	
Deficiency	DEFECTIVE/CLOGGED
Deficiency Location/Instance	Kitchen
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Hood	
Instance on Cellar	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Hood Exhaust Ductwork	
Instance on Cellar	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Hood Exhaust Fan	
Instance on Cellar	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Hood Fire Suppression System	
Instance on Cellar	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Hot Water Temperature Booster	
Instance on Cellar	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Kitchen Sink	
Instance on Cellar	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
MDF Room	
Instance on Room 208	Inspected
Dedicated A/C Equipment	
Instance on Room 208	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	
	Does not exist
SCIENCE LAB	
Instance on Room 514	Inspected
Alternative Use	No
Acid Waste Neutralizing Tank	
Instance on Room 514	Does not exist
CO Detector	
Instance on Room 514	Not required
Emergency Shower	
Instance on Room 514	Does not exist
Eye Wash	
Instance on Room 514	Does not exist
Fixed Laboratory Hood	

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Mechanical Inspection

M267

Question	Response
SCIENCE LAB	
Fixed Laboratory Hood	
Instance on Room 514	Does not exist
Hood Exhaust Ductwork	
Instance on Room 514	Does not exist
Hood Exhaust Fan	
Instance on Room 514	Does not exist
Laboratory Sink	
Instance on Room 514	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	Room 514
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Make-up Air Unit	
Instance on Room 514	Does not exist
SCIENCE PREP ROOM	
Instance on Room 514A	Inspected
Alternative Use	Yes
Acid Waste Neutralizing Tank	
Instance on Room 514A	Does not exist
CO Detector	
Instance on Room 514A	Not required
Emergency Shower	
Instance on Room 514A	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Eye Wash	
Instance on Room 514A	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Fixed Laboratory Hood	
Instance on Room 514A	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Hood Exhaust Ductwork	
Instance on Room 514A	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Hood Exhaust Fan	
Instance on Room 514A	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Laboratory Sink	
Instance on Room 514A	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Make-up Air Unit	
Instance on Room 514A	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Mechanical Inspection

M267

Question	Response
SPRINKLERS, STANDPIPE, FIRE SYSTEM	Inspected
Dry Sprinkler Alarm Valve Assembly	Does not exist
Fire Booster Pump Assembly	Inspected
Condition	3- Fair
Deficiency	DEFECTIVE FIRE BOOSTER PUMP CONTROLLER
Deficiency Location/Instance	Fire Pump Room C03
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
Roof Tank	Does not exist
Siamese Connection	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Sprinkler Head	Inspected
Condition	2- Between Good and Fair
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Room 602B (obstructed, 2)
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
Sprinkler Piping	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Standpipe System	Inspected
Hose Valve Assembly	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Piping	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Water Gong	Does not exist
Wet Sprinkler Alarm Valve Assembly	Does not exist
SWIMMING POOL	Does not exist
VENTILATION	Inspected
Exhaust Fan	Inspected
Condition	2- Between Good and Fair
Approximate Total # of Fans	1-25
Deficiency	No deficiencies recorded
Heating And Ventilating Unit	Does not exist
Metal Ductwork	Inspected
Condition	1- Good
Deficiency	DEFECTIVE FIRE/SMOKE DAMPER
Deficiency Location/Instance	1st Floor
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded

NYC Department of Education
Building Condition Assessment Survey 2018-2019

Mechanical Inspection

M267

Question	Response
VENTILATION	
Supply Fan	Does not exist
Unit Ventilator	Does not exist