

NYC Department of Education
Building Condition Assessment Survey 2017 - 2018

Electrical Inspection

Q063

Asset: P.S. 63 - QUEENS, 90-15 SUTTER AVENUE, New York, 11417

Inspection Id	Inspection Type	Time In	Last Edited
EE : Q063	Electrical	2017-10-18 9:13 AM	2017-11-07 1:33 PM

Asset Data

Question	Answer
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	Yes
Water Penetration in Electrical Room?	No
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Auditorium (Except Lighting)
	Years: 2017
	Systems: IPDVC/CCTV System
	Years: 2015
	Systems: LAN, Intrusion Alarm System (Remote Annunciator)
	Years: 2014
	Systems: Partial Emergency Lighting (Battery Pack)
	Years: 2012
	Systems: Pendant and Surface Fluorescent Lighting, Gymnasium (HID Lighting)
	Years: 2008
	Systems: Local Sound System (Except Auditorium)
	Years: 2005
	Systems: Most Security Lights
	Years: 2000, 2015
	Systems: Fire Alarm System, Recessed Fluorescent Lighting, Service Switch, Switchboard
	Years: 2000
	Systems: Most Fused Disconnect Switch Type Panel Board
	Years: 1999
	Systems: Intrusion Alarm System
	Years: 1996
	Systems: Public Address System
	Years: 1990
	Systems: Partial Molded Case Circuit Breaker Panel Board
	Years: 1989, 1999

DEDICATED INTERCOMS IN FIRE RESCUE AREAS

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	No

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
Yes	Fire Alarm System - Components Not Operational	N/A	FIRE ALARM SYSTEM Elevator Recall	Elevator - Device ID: 4P1036	Aleksandr Brener	Custodian	Sent to DSF	
Yes	Fire Alarm System - Defective	N/A	FIRE ALARM SYSTEM Main Panel Fire Alarm Control Panel (Electronic)	1st Corridor	Aleksandr Brener	Custodian	Sent to DSF	

Inspection

Question	Response
----------	----------

NYC Department of Education
Building Condition Assessment Survey 2017 - 2018

Electrical Inspection

Q063

Question	Response
Electrical	
AUDITORIUM	Inspected
Instance on 1st Floor	Inspected
House Lighting	Inspected
Does a Chandelier exist?	No
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Pendant Mounted	Inspected
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not Exist
Instance on 1st Floor	Does not Exist
Lighting Fixture - HID	
Instance on 1st Floor	Does not Exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not Exist
Lighting Fixture - LED	
Instance on 1st Floor	Does not Exist
Local Sound System	Inspected
Instance on 1st Floor	Inspected
Installation Year	2017
Source of Installation	Custodial Staff
Condition	1 - Good
Deficiency	No deficiencies recorded
Projection System	Inspected
Is the projector on a cart or installed on the ceiling?	Ceiling
Instance on 1st Floor	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Theater Lighting System	Inspected
Instance on 1st Floor	Inspected
Dimming System	
Instance on 1st Floor	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Theater Lighting	
Instance on 1st Floor	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
CAFETERIA	Inspected
Instance on 1st Floor	Inspected
Lighting	Inspected
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	

**NYC Department of Education
Building Condition Assessment Survey 2017 - 2018**

Electrical Inspection

Q063

Question	Response
CAFETERIA	
Lighting	
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not Exist
Surface Mounted	
Instance on 1st Floor	Does not Exist
Recessed Mounted	
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on 1st Floor	Does not Exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not Exist
Lighting Fixture - LED	
Instance on 1st Floor	Does not Exist
Local Sound System	
Instance on 1st Floor	Inspected
Installation Year	2005
Source of Installation	Custodial Staff
Condition	3 - Fair
Deficiency	No deficiencies recorded
Projection System	
Instance on 1st Floor	Does not Exist
Theater Lighting System	
Instance on 1st Floor	Does not Exist
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
Lighting	
Does a Chandelier exist?	No
Lighting Fixture - Fluorescent	
Pendant Mounted	
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Lighting Fixture - Incandescent	
Lighting Fixture - LED	
COMPUTER LAB	
Instance on Room 407A	Inspected
Power Panel	Yes
Lighting	
Instance on Room 407A	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2017 - 2018**

Electrical Inspection

Q063

Question	Response
COMPUTER LAB	
Lighting	
Lighting Fixture - Fluorescent	
Instance on Room 407A	Inspected
Pendant Mounted	
Instance on Room 407A	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Room 407A	Does not Exist
Recessed Mounted	
Instance on Room 407A	Does not Exist
Lighting Fixture - HID	
Instance on Room 407A	Does not Exist
Lighting Fixture - Incandescent	
Instance on Room 407A	Does not Exist
Lighting Fixture - LED	
Instance on Room 407A	Does not Exist
Raceway With Receptacles	
Instance on Room 407A	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
GYMNASIUM	
Instance on 1st Floor	Inspected
Lighting	
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not Exist
Surface Mounted	
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on 1st Floor	Does not Exist
Lighting Fixture - HID	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on 1st Floor	Does not Exist
Recessed Mounted	
Instance on 1st Floor	Does not Exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not Exist
Lighting Fixture - LED	

**NYC Department of Education
Building Condition Assessment Survey 2017 - 2018**

Electrical Inspection

Q063

Question	Response
GYMNASIUM	
Lighting	Inspected
Lighting Fixture - LED	
Instance on 1st Floor	Does not Exist
Local Sound System	Inspected
Instance on 1st Floor	Inspected
Installation Year	2005
Source of Installation	Custodial Staff
Condition	3 - Fair
Deficiency	No deficiencies recorded
Projection System	Does not Exist
Instance on 1st Floor	Does not Exist
Scoreboard	Does not Exist
Instance on 1st Floor	Does not Exist
Theater Lighting System	Does not Exist
Instance on 1st Floor	Does not Exist
KITCHEN	Inspected
Instance on 1st Floor	Inspected
Lighting	Inspected
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Pendant Mounted	Does not Exist
Instance on 1st Floor	Does not Exist
Surface Mounted	Does not Exist
Instance on 1st Floor	Does not Exist
Recessed Mounted	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on 1st Floor	Does not Exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not Exist
Lighting Fixture - LED	
Instance on 1st Floor	Does not Exist
LIBRARY	Inspected
Instance on Room 311	Inspected
Lighting	Inspected
Instance on Room 311	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 311	Inspected
Pendant Mounted	Inspected
Instance on Room 311	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	Does not Exist
Instance on Room 311	Does not Exist
Recessed Mounted	Does not Exist

**NYC Department of Education
Building Condition Assessment Survey 2017 - 2018**

Electrical Inspection

Q063

Question	Response
LIBRARY	
Lighting	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Instance on Room 311	Does not Exist
Lighting Fixture - HID	
Instance on Room 311	Does not Exist
Lighting Fixture - Incandescent	
Instance on Room 311	Does not Exist
Lighting Fixture - LED	
Instance on Room 311	Does not Exist
Raceway With Receptacles	
Instance on Room 311	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Projection System	
Instance on Room 311	Does not Exist
LOCKER ROOM	
MULTIPURPOSE ROOM	
Instance on 1st Floor - East	Inspected
Instance on 1st Floor - West	Inspected
Lighting	
Instance on 1st Floor - West	Inspected
Instance on 1st Floor - East	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor - West	Inspected
Instance on 1st Floor - East	Inspected
Pendant Mounted	
Instance on 1st Floor - West	Does not Exist
Instance on 1st Floor - East	Does not Exist
Surface Mounted	
Instance on 1st Floor - West	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Instance on 1st Floor - East	Does not Exist
Recessed Mounted	
Instance on 1st Floor - West	Does not Exist
Instance on 1st Floor - East	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on 1st Floor - West	Does not Exist
Instance on 1st Floor - East	Does not Exist
Lighting Fixture - Incandescent	
Instance on 1st Floor - West	Does not Exist
Instance on 1st Floor - East	Does not Exist
Lighting Fixture - LED	
Instance on 1st Floor - West	Does not Exist
Instance on 1st Floor - East	Does not Exist

**NYC Department of Education
Building Condition Assessment Survey 2017 - 2018**

Electrical Inspection

Q063

Question	Response
MULTIPURPOSE ROOM	
Local Sound System	Inspected
Instance on 1st Floor - West	Inspected
Installation Year	2005
Source of Installation	Custodial Staff
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on 1st Floor - East	Inspected
Installation Year	2005
Source of Installation	Custodial Staff
Condition	3 - Fair
Deficiency	No deficiencies recorded
Projection System	Does not Exist
Instance on 1st Floor - West	Does not Exist
Instance on 1st Floor - East	Does not Exist
Theater Lighting System	Does not Exist
Instance on 1st Floor - West	Does not Exist
Instance on 1st Floor - East	Does not Exist
SCIENCE DEMO ROOM	Does not Exist
SCIENCE LAB	Does not Exist
SCIENCE PREP ROOM	Does not Exist
SWIMMING POOL	Does not Exist
TOILET ROOM - STAFF	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not Exist
Lighting Fixture - Incandescent	Does not Exist
Lighting Fixture - LED	Does not Exist
TOILET ROOM - STUDENT	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2017 - 2018

Electrical Inspection

Q063

Question	Response
TOILET ROOM - STUDENT	Inspected
Lighting	
Lighting Fixture - HID	Does not Exist
Lighting Fixture - Incandescent	Does not Exist
Lighting Fixture - LED	Does not Exist
AUXILIARY SIGNAL/BELL SYSTEM	Inspected
Replacement Quantity	114,000
Replacement Uom	S.F.
Condition	3 - Fair
Deficiency	No deficiencies recorded
EMERGENCY DC STANDBY BATTERY POWER	Does not Exist
EMERGENCY GENERATOR SET	Does not Exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Inspected
Condition	3 - Fair
Deficiency	PANEL BOARD DIRECTORY MISSING OR REQUIRES UPDATING
Deficiency Location/Instance	Electrical Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
EMERGENCY LIGHTING	Inspected
Battery Pack	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
EXIT LIGHT	Inspected
Battery Pack	Inspected
Condition	3 - Fair
Deficiency	BATTERY NOT OPERATIONAL
Deficiency Location/Instance	Auditorium
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE BATTERY
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Non Battery Pack	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
EXIT/EMERGENCY LIGHT	Does not Exist
CITY FIRE ALARM SYSTEM	Inspected
Condition	3 - Fair

NYC Department of Education
Building Condition Assessment Survey 2017 - 2018

Electrical Inspection

Q063

Question	Response
CITY FIRE ALARM SYSTEM	Inspected
Deficiency	No deficiencies recorded
FIRE ALARM SYSTEM	Inspected
Replacement Quantity	114,000
Replacement Uom	S.F.
Bell/Horn	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Strobe	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Manual Pull Station	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Fan Shutdown Control	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Duct Smoke Detector	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Area Smoke Detector	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
CO Detector	Does not Exist
Heat Detector	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Elevator Recall	Inspected
Condition	4 - Between Fair and Poor
Deficiency	SYSTEM NOT OPERATIONAL
Deficiency Location/Instance	Eleveator Machine Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Magnetic Door Holder/Contactor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Fused Cutout Panel	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Fire Alarm Digital Communicator	Does not Exist
Main Panel	Inspected
Bell At Panel	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2017 - 2018**

Electrical Inspection

Q063

Question	Response
FIRE ALARM SYSTEM	Inspected
Main Panel	
Fire Alarm Control Panel (Electronic)	
Instance	1st Corridor
Instance Condition	4 - Between Fair and Poor
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Edwards
Equipment	Fire Alarm Control Panel
Model	N/A
Capacity/Size Quantity	8
Capacity/Size UOM	Zones
Capacity/Size2 Quantity	1
Capacity/Size2 UOM	Section(S)
Source of Capacity/Size	Diagram
Installation Year	2000
Source of Installation	Documented
Deficiency	SYSTEM DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR SYSTEM
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Fire Alarm Control Panel (Standard)	Does not Exist
Sub-Panel	Does not Exist
Remote Annunciator	Inspected
Display Monitor	Does not Exist
Panel	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Printer	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Punch Register	Does not Exist
Sprinkler Flow/Air Pressure Switch	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Tamper Flow Switch/Chain	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
INTERCOM SYSTEM	Inspected
Elevator	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2017 - 2018

Electrical Inspection

Q063

Question	Response
INTERCOM SYSTEM	Inspected
Holding Area	Does not Exist
LAN	Inspected
Local Distribution Frame (I/LDF)	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Main Equipment Rack (MDF)	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
LIGHTNING PROTECTION	Does not Exist
MOTOR CONTROL CENTER	Does not Exist
MOTOR STARTER/CONTACTOR	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
PANEL BOARD	Inspected
Fused Disconnect Switch Type	Inspected
Condition	2 - Between Good and Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Boiler Room, 1st Floor Corridor - By Rooms 118, 121
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Fused Knife Switch Type	Does not Exist
Fused Toggle Switch Type	Inspected
Condition	3 - Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Molded Case Circuit Breaker Type	Inspected
Condition	2 - Between Good and Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Corridor near Auditorium, Corridor near Rooms (459, 360, 214, 260, 162), Main Entrance Lobby
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded

**NYC Department of Education
Building Condition Assessment Survey 2017 - 2018**

Electrical Inspection

Q063

Question	Response
PANEL BOARD	
Molded Case Circuit Breaker Type	
Violations	No violations recorded.
Deficiency	NO SPARE
Deficiency Location/Instance	Corridor near Rooms 407, 307, 253, 214
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE PANEL BOARD
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	NO SPARE
Deficiency Location/Instance	Room 110
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL NEW PANEL BOARD
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
PUBLIC ADDRESS SYSTEM	
	Inspected
Replacement Quantity	114,000
Replacement Uom	S.F.
Instance	General Office
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	N/A
Installation Year	1990
Source of Installation	Custodial Staff
Deficiency	CLOCK NOT OPERATIONAL
Deficiency Location/Instance	Corridors, Classrooms
Deficiency Quantity	50
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
SECURITY	
	Inspected
IPDVS/CCTV System	
	Inspected
Replacement Quantity	114,000
Replacement Uom	S.F.
Installation Year	2015
Source of Installation	Custodial Staff
Condition	1 - Good
Deficiency	No deficiencies recorded
Intrusion Alarm System	
	Inspected

NYC Department of Education
Building Condition Assessment Survey 2017 - 2018

Electrical Inspection

Q063

Question	Response
SECURITY	
Intrusion Alarm System	
Replacement Quantity	114,000
Replacement Uom	S.F.
Central Control Panel	
	Inspected
Instance	Room 163
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista - 50P
Installation Year	1996
Source of Installation	Custodial Staff
Deficiency	No deficiencies recorded
Infrared Sensor	
	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Panic Switch	
	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Remote Annunciator	
	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Siren/Strobe	
	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Ultrasonic Sensor	
	Does not Exist
Lighting - Security	
	Inaccessible
SERVICE SWITCH	
	Inspected
Instance	Electrical Meter Room
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	All City Switchboard
Equipment	N/A
Capacity/Size Quantity	3,000
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	2000
Source of Installation	Documented
Deficiency	No deficiencies recorded
SWITCHBOARD	
	Inspected
Number of Spares	1
Air Circuit Breaker Type	
	Does not Exist
Fused Disconnect Switch Type	
	Inspected
Instance	Electrical Room
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	All City Switchboard

**NYC Department of Education
Building Condition Assessment Survey 2017 - 2018**

Electrical Inspection

Q063

Question	Response
SWITCHBOARD	
Fused Disconnect Switch Type	
Equipment	N/A
Capacity/Size Quantity	3,000
Capacity/Size UOM	Amps Total
Capacity/Size2 Quantity	4
Capacity/Size2 UOM	Section(S)
Source of Capacity/Size	Service Switch Size
Installation Year	2000
Source of Installation	Documented
Deficiency	No deficiencies recorded
Fused Knife Switch Type	Does not Exist
Molded Case Circuit Breaker Type	Does not Exist
TELEPHONE SYSTEM	
PBX/Intercom	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Standard	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
TRANSFORMER	
TV SYSTEM	Inspected
Cable System Exist?	Yes
Operational?	Yes
Main Equipment Rack	Does not Exist