

**NYC Department of Education**  
**Building Condition Assessment Survey 2018 - 2019**

Electrical Inspection

Q121

**Asset:** P.S. 121 - QUEENS, 126-10 109 AVENUE, New York, 11420

Inspection Id	Inspection Type	Time In	Last Edited
EE : Q121	Electrical	2019-03-15 8:48 AM	2019-03-22 8:38 AM

Asset Data

Question	Answer
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	Yes
Water Penetration in Electrical Room?	No
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Auditorium
	Years: Under Construction
	Systems: Most Emergency Lighting (Battery Pack)
	Years: 2016, 2018
	Systems: Telephone System, LAN, Public Address System (Amplifier)
	Years: 2016
	Systems: Fire Alarm System, Interior Fluorescent Lighting, Gymnasium (LED Lighting)
	Years: 2014
	Systems: Gymnasium (Scoreboard)
	Years: 2013
	Systems: Public Address System, Local Sound System, Auxiliary Signal/Bell System
	Years: 2011
	Systems: Exit/Emergency Light, Exit Lights, Computer Lab - Room 519 (Raceway with Receptacles)
	Years: 2008
	Systems: Partial Fused Disconnect Switch Type Panel Board, Emergency Light/Exit Light Panel, Intrusion Alarm System, Security Lights
	Years: 2000
	Systems: Partial Molded Case Circuit Breaker Panel Board
	Years: 1990, 2000, 2006, 2019

**DEDICATED INTERCOMS IN FIRE RESCUE AREAS**

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	No

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
Yes	Water Leaks onto Electrical Equipment	N/A	Lighting Fixture	Corridor by Room 552	John Griffith	Custodian	Sent to DSF	

Inspection

Question	Response
<b>Electrical</b>	
<b>AUDITORIUM</b>	Inspected
Instance on 1st Floor	Under Construction
<b>CAFETERIA</b>	Inspected
Instance on 1st Floor	Inspected
<b>Lighting</b>	Inspected
Instance on 1st Floor	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2018 - 2019**

Electrical Inspection

Q121

Question	Response
<b>CAFETERIA</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st Floor	Inspected
<b>Pendant Mounted</b>	
Instance on 1st Floor	Does not Exist
<b>Surface Mounted</b>	
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on 1st Floor	Does not Exist
<b>Lighting Fixture - HID</b>	
Instance on 1st Floor	Does not Exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st Floor	Does not Exist
<b>Lighting Fixture - LED</b>	
Instance on 1st Floor	Does not Exist
<b>Local Sound System</b>	
Instance on 1st Floor	Inspected
Installation Year	2011
Source of Installation	Custodial Staff
Condition	2 - Between Good and Fair
Deficiency	MICROPHONE / JACK NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>Projection System</b>	
Instance on 1st Floor	Does not Exist
<b>Theater Lighting System</b>	
Instance on 1st Floor	Does not Exist
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>Lighting</b>	Inspected
Does a Chandelier exist?	Yes
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
	Does not Exist

**NYC Department of Education  
Building Condition Assessment Survey 2018 - 2019**

Electrical Inspection

Q121

<b>Question</b>	<b>Response</b>
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Incandescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Does not Exist
<b>Lighting Fixture - LED</b>	Does not Exist
<b>COMPUTER LAB</b>	Inspected
Instance on Room 519	Inspected
Power Panel	Yes
<b>Lighting</b>	Inspected
Instance on Room 519	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 519	Inspected
<b>Pendant Mounted</b>	Inspected
Instance on Room 519	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	Does not Exist
Instance on Room 519	Does not Exist
<b>Recessed Mounted</b>	Does not Exist
Instance on Room 519	Does not Exist
<b>Lighting Fixture - HID</b>	
Instance on Room 519	Does not Exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 519	Does not Exist
<b>Lighting Fixture - LED</b>	
Instance on Room 519	Does not Exist
<b>Raceway With Receptacles</b>	Inspected
Instance on Room 519	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>GYMNASIUM</b>	Inspected
Instance on 3rd Floor	Inspected
<b>Lighting</b>	Inspected
Instance on 3rd Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on 3rd Floor	Does not Exist
<b>Lighting Fixture - HID</b>	
Instance on 3rd Floor	Does not Exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 3rd Floor	Does not Exist
<b>Lighting Fixture - LED</b>	
Instance on 3rd Floor	Inspected
<b>Pendant Mounted</b>	Inspected

**NYC Department of Education**  
**Building Condition Assessment Survey 2018 - 2019**

Electrical Inspection

Q121

Question	Response
<b>GYMNASIUM</b>	
<b>Lighting</b>	
<b>Lighting Fixture - LED</b>	
<b>Pendant Mounted</b>	Inspected
Instance on 3rd Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	Does not Exist
Instance on 3rd Floor	Does not Exist
<b>Recessed Mounted</b>	Does not Exist
Instance on 3rd Floor	Does not Exist
<b>Local Sound System</b>	Inspected
Instance on 3rd Floor	Inspected
Installation Year	2011
Source of Installation	Custodial Staff
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Projection System</b>	Does not Exist
Instance on 3rd Floor	Does not Exist
<b>Scoreboard</b>	Inspected
Instance on 3rd Floor	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Theater Lighting System</b>	Does not Exist
Instance on 3rd Floor	Does not Exist
<b>KITCHEN</b>	
Instance on 1st Floor	Inspected
<b>Lighting</b>	Inspected
Instance on 1st Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st Floor	Inspected
<b>Pendant Mounted</b>	Does not Exist
Instance on 1st Floor	Does not Exist
<b>Surface Mounted</b>	Inspected
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Inspected
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
Instance on 1st Floor	Does not Exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st Floor	Does not Exist
<b>Lighting Fixture - LED</b>	
Instance on 1st Floor	Does not Exist
<b>LIBRARY</b>	
Instance on Room 407	Inspected
<b>Lighting</b>	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2018 - 2019**

Electrical Inspection

Q121

<b>Question</b>	<b>Response</b>
<b>LIBRARY</b>	
<b>Lighting</b>	
Instance on Room 407	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 407	Inspected
<b>Pendant Mounted</b>	Inspected
Instance on Room 407	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	Does not Exist
Instance on Room 407	Does not Exist
<b>Recessed Mounted</b>	Does not Exist
Instance on Room 407	Does not Exist
<b>Lighting Fixture - HID</b>	
Instance on Room 407	Does not Exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 407	Does not Exist
<b>Lighting Fixture - LED</b>	
Instance on Room 407	Does not Exist
<b>Raceway With Receptacles</b>	Does not Exist
Instance on Room 407	Does not Exist
<b>Projection System</b>	Does not Exist
Instance on Room 407	Does not Exist
<b>LOCKER ROOM</b>	Does not Exist
<b>MULTIPURPOSE ROOM</b>	Does not Exist
<b>SCIENCE DEMO ROOM</b>	Does not Exist
<b>SCIENCE LAB</b>	Does not Exist
<b>SCIENCE PREP ROOM</b>	Does not Exist
<b>SWIMMING POOL</b>	Does not Exist
<b>TOILET ROOM - STAFF</b>	Inspected
<b>Lighting</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Does not Exist
<b>Lighting Fixture - HID</b>	Does not Exist
<b>Lighting Fixture - Incandescent</b>	Does not Exist
<b>Lighting Fixture - LED</b>	Does not Exist
<b>TOILET ROOM - STUDENT</b>	Inspected
<b>Lighting</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded

**NYC Department of Education  
Building Condition Assessment Survey 2018 - 2019**

Electrical Inspection

Q121

Question	Response
<b>TOILET ROOM - STUDENT</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Surface Mounted</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Does not Exist
<b>Lighting Fixture - HID</b>	Does not Exist
<b>Lighting Fixture - Incandescent</b>	Does not Exist
<b>Lighting Fixture - LED</b>	Does not Exist
<b>AUXILIARY SIGNAL/BELL SYSTEM</b>	Inspected
Replacement Quantity	79,000
Replacement Uom	S.F.
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY DC STANDBY BATTERY POWER</b>	Does not Exist
<b>EMERGENCY GENERATOR SET</b>	Does not Exist
<b>EMERGENCY LIGHT/EXIT LIGHT PANEL</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	LESS THAN 20% SPARE CIRCUIT BREAKERS
Deficiency Location/Instance	Electrical Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL NEW PANEL BOARD
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>EMERGENCY LIGHTING</b>	Inspected
<b>Battery Pack</b>	Inspected
Condition	1 - Good
Deficiency	BATTERY NOT OPERATIONAL
Deficiency Location/Instance	Cafeteria, Gymnasium, Main Entrance Lobby
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPLACE BATTERY
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>Non Battery Pack</b>	Inspected
Condition	3 - Fair
Deficiency	FIXTURE LAMP NOT OPERATIONAL
Deficiency Location/Instance	Gymnasium
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2

**NYC Department of Education**  
**Building Condition Assessment Survey 2018 - 2019**

Electrical Inspection

Q121

Question	Response
<b>EMERGENCY LIGHTING</b>	Inspected
<b>Non Battery Pack</b>	Inspected
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>EXIT LIGHT</b>	Inspected
<b>Battery Pack</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Non Battery Pack</b>	Does not Exist
<b>EXIT/EMERGENCY LIGHT</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>CITY FIRE ALARM SYSTEM</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>FIRE ALARM SYSTEM</b>	Inspected
Replacement Quantity	79,000
Replacement Uom	S.F.
<b>Bell/Horn</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Strobe</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Manual Pull Station</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Fan Shutdown Control</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Duct Smoke Detector</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Area Smoke Detector</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>CO Detector</b>	Does not Exist
<b>Heat Detector</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Elevator Recall</b>	Does not Exist
<b>Magnetic Door Holder/Contactor</b>	Does not Exist
<b>Fused Cutout Panel</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Fire Alarm Digital Communicator</b>	Does not Exist
<b>Main Panel</b>	Inspected
<b>Bell At Panel</b>	Does not Exist
<b>Fire Alarm Control Panel (Electronic)</b>	Inspected

**NYC Department of Education**  
**Building Condition Assessment Survey 2018 - 2019**

Electrical Inspection

Q121

Question	Response
<b>FIRE ALARM SYSTEM</b>	
<b>Main Panel</b>	
<b>Fire Alarm Control Panel (Electronic)</b>	
Instance	Main Entrance Lobby
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Siemens
Equipment	Fire Alarm Control Panel
Model	XLS
Capacity/Size Quantity	8
Capacity/Size UOM	Zones
Capacity/Size2 Quantity	1
Capacity/Size2 UOM	Section(S)
Source of Capacity/Size	Diagram
Installation Year	2014
Source of Installation	Documented
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Standard)</b>	Does not Exist
<b>Sub-Panel</b>	Does not Exist
<b>Remote Annunciator</b>	Inspected
<b>Display Monitor</b>	Does not Exist
<b>Panel</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Printer</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Punch Register</b>	Does not Exist
<b>Sprinkler Flow/Air Pressure Switch</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Tamper Flow Switch/Chain</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>GROUNDING SYSTEM</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>INTERCOM SYSTEM</b>	Does not Exist
<b>LAN</b>	Inspected
<b>Local Distribution Frame (I/LDF)</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Main Equipment Rack (MDF)</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>LIGHTNING PROTECTION</b>	Does not Exist
<b>MOTOR CONTROL CENTER</b>	Does not Exist
<b>MOTOR STARTER/CONTACTOR</b>	Inspected



**NYC Department of Education  
Building Condition Assessment Survey 2018 - 2019**

Electrical Inspection

Q121

<b>Question</b>	<b>Response</b>
<b>MOTOR STARTER/CONTACTOR</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>PANEL BOARD</b>	Inspected
<b>Fused Disconnect Switch Type</b>	Inspected
Condition	3 - Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>Fused Knife Switch Type</b>	Does not Exist
<b>Fused Toggle Switch Type</b>	Inspected
Condition	3 - Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>Molded Case Circuit Breaker Type</b>	Inspected
Condition	3 - Fair
Deficiency	NO SPARE
Deficiency Location/Instance	Corridor by Rooms 353, 415
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE PANEL BOARD
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Kitchen, Cafeteria, Corridor by Rooms (211, 253, 261, 357, 407, 411, 417, 557), Basement - Mechanical Room
Deficiency Quantity	12
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>PUBLIC ADDRESS SYSTEM</b>	Inspected

**NYC Department of Education**  
**Building Condition Assessment Survey 2018 - 2019**

Electrical Inspection

Q121

<b>Question</b>	<b>Response</b>
<b>PUBLIC ADDRESS SYSTEM</b>	
Replacement Quantity	79,000
Replacement Uom	S.F.
Instance	General Office
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Biamp MPA 250
Installation Year	2011
Source of Installation	Custodial Staff
Deficiency	CLOCK NOT OPERATIONAL
Deficiency Location/Instance	Corridor by Room 518
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>SECURITY</b>	Inspected
<b>IPDVS/CCTV System</b>	Does not Exist
<b>Intrusion Alarm System</b>	Inspected
Replacement Quantity	79,000
Replacement Uom	S.F.
<b>Central Control Panel</b>	Inspected
Instance	Custodian's Office
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	4140 XMPT2
Installation Year	2000
Source of Installation	Inspector Estimate
Deficiency	No deficiencies recorded
<b>Infrared Sensor</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Panic Switch</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Remote Annunciator</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Siren/Stroke</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Ultrasonic Sensor</b>	Does not Exist
<b>Lighting - Security</b>	Inspected
Replacement Quantity	19
Replacement Uom	EACH

**NYC Department of Education**  
**Building Condition Assessment Survey 2018 - 2019**

Electrical Inspection

Q121

Question	Response
<b>SECURITY</b>	
<b>Lighting - Security</b>	
Condition	3 - Fair
Deficiency	TIME CLOCK NOT OPERATIONAL
Deficiency Location/Instance	Electrical Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 3
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>SERVICE SWITCH</b>	
	Inspected
Instance	Electrical Room
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Metropolitan
Equipment	Service Sw
Capacity/Size Quantity	1,600
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1970
Source of Installation	Inspector Estimate
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>SWITCHBOARD</b>	
	Inspected
Number of Spares	0
<b>Air Circuit Breaker Type</b>	Does not Exist
<b>Fused Disconnect Switch Type</b>	Inspected
Instance	Electrical Room
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Metropolitan Electric
Equipment	N/A
Capacity/Size Quantity	1,600
Capacity/Size UOM	Amps Total
Capacity/Size2 Quantity	3
Capacity/Size2 UOM	Section(S)
Source of Capacity/Size	Service Switch Size
Installation Year	1970

**NYC Department of Education**  
**Building Condition Assessment Survey 2018 - 2019**

Electrical Inspection

Q121

Question	Response
<b>SWITCHBOARD</b>	
<b>Fused Disconnect Switch Type</b>	
Source of Installation	Inspector Estimate
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>Fused Knife Switch Type</b>	Does not Exist
<b>Molded Case Circuit Breaker Type</b>	Does not Exist
<b>TELEPHONE SYSTEM</b>	
	Inspected
<b>PBX/Intercom</b>	
	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Standard</b>	
	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>TRANSFORMER</b>	
	Does not Exist
<b>TV SYSTEM</b>	
	Inspected
Cable System Exist?	Yes
Operational?	No
<b>Main Equipment Rack</b>	Does not Exist