

NYC Department of Education
Building Condition Assessment Survey 2018 - 2019

Electrical Inspection

Q378

Asset: PRE-K CENTER @ 46-16 76TH STREET - QUEENS, 46-16 76 STREET, New York, 11373

Inspection Id	Inspection Type	Time In	Last Edited
EE : Q378	Electrical	2019-02-25 8:07 AM	2019-03-04 4:20 PM

Asset Data

Question	Answer
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	Yes
Water Penetration in Electrical Room?	No
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: All Electrical Systems and Components
	Years: 2015

DEDICATED INTERCOMS IN FIRE RESCUE AREAS

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	No

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
No condition recorded								

Inspection

Question	Response
Electrical	
AUDITORIUM	Does not Exist
CAFETERIA	Does not Exist
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	Inspected
Lighting	Inspected
Does a Chandelier exist?	No
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Recessed Mounted	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not Exist
Lighting Fixture - Incandescent	Does not Exist
Lighting Fixture - LED	Inspected
Pendant Mounted	Does not Exist
Surface Mounted	Does not Exist
Recessed Mounted	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
COMPUTER LAB	Does not Exist
GYMNASIUM	Does not Exist
KITCHEN	Inspected
Instance on 1st Floor	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2018 - 2019**

Electrical Inspection

Q378

Question	Response
KITCHEN	
Lighting	Inspected
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Pendant Mounted	Does not Exist
Instance on 1st Floor	Does not Exist
Surface Mounted	Does not Exist
Instance on 1st Floor	Does not Exist
Recessed Mounted	Inspected
Instance on 1st Floor	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on 1st Floor	Does not Exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not Exist
Lighting Fixture - LED	
Instance on 1st Floor	Inspected
Pendant Mounted	Does not Exist
Instance on 1st Floor	Does not Exist
Surface Mounted	Does not Exist
Instance on 1st Floor	Does not Exist
Recessed Mounted	Inspected
Instance on 1st Floor	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
LIBRARY	Does not Exist
LOCKER ROOM	Does not Exist
MULTIPURPOSE ROOM	Inspected
Instance on 1st Floor	Inspected
Lighting	Inspected
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Pendant Mounted	Does not Exist
Instance on 1st Floor	Does not Exist
Surface Mounted	Does not Exist
Instance on 1st Floor	Does not Exist
Recessed Mounted	Inspected
Instance on 1st Floor	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on 1st Floor	Does not Exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not Exist
Lighting Fixture - LED	
Instance on 1st Floor	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2018 - 2019

Electrical Inspection

Q378

Question	Response
MULTIPURPOSE ROOM	
Local Sound System	Does not Exist
Instance on 1st Floor	Does not Exist
Projection System	Does not Exist
Instance on 1st Floor	Does not Exist
Theater Lighting System	Does not Exist
Instance on 1st Floor	Does not Exist
SCIENCE DEMO ROOM	Does not Exist
SCIENCE LAB	Does not Exist
SCIENCE PREP ROOM	Does not Exist
SWIMMING POOL	Does not Exist
TOILET ROOM - STAFF	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not Exist
Surface Mounted	Does not Exist
Recessed Mounted	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not Exist
Lighting Fixture - Incandescent	Does not Exist
Lighting Fixture - LED	Does not Exist
TOILET ROOM - STUDENT	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not Exist
Surface Mounted	Does not Exist
Recessed Mounted	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not Exist
Lighting Fixture - Incandescent	Does not Exist
Lighting Fixture - LED	Does not Exist
AUXILIARY SIGNAL/BELL SYSTEM	Inspected
Replacement Quantity	11,945
Replacement Uom	S.F.
Condition	1 - Good
Deficiency	No deficiencies recorded
EMERGENCY DC STANDBY BATTERY POWER	Does not Exist
EMERGENCY GENERATOR SET	Does not Exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Does not Exist
EMERGENCY LIGHTING	Inspected
Battery Pack	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Non Battery Pack	Does not Exist
EXIT LIGHT	Inspected
Battery Pack	Inspected

NYC Department of Education
Building Condition Assessment Survey 2018 - 2019

Electrical Inspection

Q378

Question	Response
EXIT LIGHT	Inspected
Battery Pack	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Non Battery Pack	Does not Exist
EXIT/EMERGENCY LIGHT	Does not Exist
CITY FIRE ALARM SYSTEM	Does not Exist
FIRE ALARM SYSTEM	Inspected
Replacement Quantity	11,945
Replacement Uom	S.F.
Bell/Horn	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Strobe	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Manual Pull Station	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Fan Shutdown Control	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Duct Smoke Detector	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Area Smoke Detector	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
CO Detector	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Heat Detector	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Elevator Recall	Does not Exist
Magnetic Door Holder/Contactor	Does not Exist
Fused Cutout Panel	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Fire Alarm Digital Communicator	Does not Exist
Main Panel	Inspected
Bell At Panel	Does not Exist
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Main Entrance Lobby
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Notifier
Equipment	Fire Alarm Control Panel
Model	N/A

**NYC Department of Education
Building Condition Assessment Survey 2018 - 2019**

Electrical Inspection

Q378

Question	Response
FIRE ALARM SYSTEM	
Main Panel	
Fire Alarm Control Panel (Electronic)	
Capacity/Size Quantity	8
Capacity/Size UOM	Zones
Capacity/Size2 Quantity	1
Capacity/Size2 UOM	Section(S)
Source of Capacity/Size	Inspector Estimate
Installation Year	2015
Source of Installation	Documented
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	Does not Exist
Sub-Panel	Does not Exist
Remote Annunciator	Inspected
Display Monitor	Does not Exist
Panel	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Printer	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Punch Register	Does not Exist
Sprinkler Flow/Air Pressure Switch	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Tamper Flow Switch/Chain	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
INTERCOM SYSTEM	Does not Exist
LAN	Inspected
Local Distribution Frame (I/LDF)	Does not Exist
Main Equipment Rack (MDF)	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
LIGHTNING PROTECTION	Does not Exist
MOTOR CONTROL CENTER	Does not Exist
MOTOR STARTER/CONTACTOR	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
PANEL BOARD	Inspected
Fused Disconnect Switch Type	Does not Exist
Fused Knife Switch Type	Does not Exist
Fused Toggle Switch Type	Does not Exist
Molded Case Circuit Breaker Type	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2018 - 2019

Electrical Inspection

Q378

Question	Response
PUBLIC ADDRESS SYSTEM	Inspected
Replacement Quantity	11,945
Replacement Uom	S.F.
Instance	Room 124A
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Biamp MPA 250
Installation Year	2015
Source of Installation	Documented
Deficiency	No deficiencies recorded
SECURITY	Inspected
IPDVS/CCTV System	Inspected
Replacement Quantity	11,945
Replacement Uom	S.F.
Installation Year	2015
Source of Installation	Documented
Condition	1 - Good
Deficiency	No deficiencies recorded
Intrusion Alarm System	Inspected
Replacement Quantity	11,945
Replacement Uom	S.F.
Central Control Panel	Inspected
Instance	Custodian's Office
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista - 128BPT
Installation Year	2015
Source of Installation	Documented
Deficiency	No deficiencies recorded
Infrared Sensor	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Panic Switch	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Remote Annunciator	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Siren/Strobe	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Ultrasonic Sensor	Does not Exist
Lighting - Security	Inspected
Replacement Quantity	5
Replacement Uom	EACH
Condition	1 - Good
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2018 - 2019

Electrical Inspection

Q378

Question	Response
SERVICE SWITCH	Inspected
Instance	Electrical Meter Room 118
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	All City Switchboard
Equipment	Main Service Disconnect
Capacity/Size Quantity	600
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	2015
Source of Installation	Documented
Deficiency	No deficiencies recorded
SWITCHBOARD	Inspected
Number of Spares	0
Air Circuit Breaker Type	Does not Exist
Fused Disconnect Switch Type	Does not Exist
Fused Knife Switch Type	Does not Exist
Molded Case Circuit Breaker Type	Inspected
Instance	Electrical Meter Room 118
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	All City Switchboard
Equipment	MDP
Capacity/Size Quantity	600
Capacity/Size UOM	Amps Total
Capacity/Size2 Quantity	1
Capacity/Size2 UOM	Section(S)
Source of Capacity/Size	Nameplate
Installation Year	2015
Source of Installation	Documented
Deficiency	No deficiencies recorded
TELEPHONE SYSTEM	Inspected
PBX/Intercom	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Standard	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
TRANSFORMER	Does not Exist
TV SYSTEM	Does not Exist