

**NYC Department of Education
Building Condition Assessment Survey 2017 - 2018**

Electrical Inspection

Q415

Asset: BENJAMIN N. CARDOZO HS - Q, 57-00 223 STREET, New York, 11364

Inspection Id	Inspection Type	Time In	Last Edited
EE : Q415	Electrical	2017-12-27 8:12 AM	2018-01-15 5:25 PM

Asset Data

Question	Answer
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	Yes
Water Penetration in Electrical Room?	No
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Intercom System (Elevator), Library (Raceway with Receptacles)
	Years: 2017
	Systems: LED Lighting
	Years: 2015
	Systems: Intrusion Alarm System (Except Panic Switch), Exit Lights (Battery Pack)
	Years: 2014
	Systems: Partial Molded Case Circuit Breaker Panel Board
	Years: 2010, 2007, 2005, 1986
	Systems: Fire Alarm System, Emergency Generator Set (Automatic Transfer Switches, Battery Charger), Telephone System, LAN
	Years: 2010
	Systems: IPDVS/CCTV System
	Years: 2007
	Systems: Local Sound System, Public Address System, Auditorium (Theater Lighting System)
	Years: 2005
	Systems: Fire Alarm System (Remote Annunciator)
	Years: 2000, 1997
	Systems: Emergency Light/Exit Light Panel
	Years: 2000
	Systems: Security Lights
	Years: 1995, 2010
	Systems: Pendant and Surface Fluorescent Lighting, Retrofitted Recessed Fluorescent Lighting , Science Demo Room B33 (Incandescent Lighting), Science Lab - Rooms B35, B39 (Incandescent Lighting)
	Years: 1995

DEDICATED INTERCOMS IN FIRE RESCUE AREAS

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	No

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
No condition recorded								

Inspection

Question	Response
Electrical	
AUDITORIUM	Inspected
Instance on 1st Floor	Inspected
House Lighting	Inspected
Does a Chandelier exist?	No

**NYC Department of Education
Building Condition Assessment Survey 2017 - 2018**

Electrical Inspection

Q415

Question	Response
AUDITORIUM	
House Lighting	
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Does not Exist
Lighting Fixture - HID	
Instance on 1st Floor	Does not Exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not Exist
Surface Mounted	
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Recessed Mounted	
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	32
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	103
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Lighting Fixture - LED	
Instance on 1st Floor	Does not Exist
Local Sound System	
Instance on 1st Floor	Inspected
Installation Year	2005
Source of Installation	Custodial Staff
Condition	3 - Fair
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2017 - 2018

Electrical Inspection

Q415

Question	Response
AUDITORIUM	
Projection System	Does not Exist
Instance on 1st Floor	Does not Exist
Theater Lighting System	Inspected
Instance on 1st Floor	Inspected
Dimming System	
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Theater Lighting	
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
CAFETERIA	
	Inspected
Instance on 1st Floor - Staff	Inspected
Instance on 1st Floor - Students	Inspected
Lighting	Inspected
Instance on 1st Floor - Students	Inspected
Instance on 1st Floor - Staff	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor - Students	Inspected
Instance on 1st Floor - Staff	Inspected
Pendant Mounted	Does not Exist
Instance on 1st Floor - Students	Does not Exist
Instance on 1st Floor - Staff	Does not Exist
Surface Mounted	Inspected
Instance on 1st Floor - Students	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on 1st Floor - Staff	Does not Exist
Recessed Mounted	Inspected
Instance on 1st Floor - Students	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on 1st Floor - Staff	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on 1st Floor - Students	Does not Exist
Instance on 1st Floor - Staff	Does not Exist
Lighting Fixture - Incandescent	
Instance on 1st Floor - Students	Does not Exist
Instance on 1st Floor - Staff	Does not Exist
Lighting Fixture - LED	
Instance on 1st Floor - Students	Does not Exist
Instance on 1st Floor - Staff	Does not Exist
Local Sound System	Inspected
Instance on 1st Floor - Students	Inspected
Installation Year	2005

NYC Department of Education
Building Condition Assessment Survey 2017 - 2018

Electrical Inspection

Q415

Question	Response
CAFETERIA	
Local Sound System	
Source of Installation	Custodial Staff
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on 1st Floor - Staff	Does not Exist
Projection System	Does not Exist
Instance on 1st Floor - Students	Does not Exist
Instance on 1st Floor - Staff	Does not Exist
Theater Lighting System	Does not Exist
Instance on 1st Floor - Students	Does not Exist
Instance on 1st Floor - Staff	Does not Exist
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
Lighting	Inspected
Does a Chandelier exist?	No
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not Exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Inspected
Condition	3 - Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	26
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Surface Mounted	Inspected
Condition	3 - Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Recessed Mounted	Inspected
Condition	3 - Fair

NYC Department of Education
Building Condition Assessment Survey 2017 - 2018

Electrical Inspection

Q415

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
Lighting	
Lighting Fixture - Incandescent	
Recessed Mounted	
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Lighting Fixture - LED	Does not Exist
COMPUTER LAB	
	Inspected
Instance on Room B37	Inspected
Power Panel	No
Instance on Rooms 243, 265, 346, 347, 353	Inspected
Power Panel	Yes
Instance on Room 348	Inspected
Power Panel	No
Lighting	
	Inspected
Instance on Room 348	Inspected
Instance on Rooms 243, 265, 346, 347, 353	Inspected
Instance on Room B37	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 348	Inspected
Instance on Rooms 243, 265, 346, 347, 353	Inspected
Instance on Room B37	Inspected
Pendant Mounted	
Instance on Room 348	Does not Exist
Instance on Rooms 243, 265, 346, 347, 353	Does not Exist
Instance on Room B37	Does not Exist
Surface Mounted	
	Inspected
Instance on Room 348	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on Rooms 243, 265, 346, 347, 353	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on Room B37	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
	Does not Exist
Instance on Room 348	Does not Exist
Instance on Rooms 243, 265, 346, 347, 353	Does not Exist
Instance on Room B37	Does not Exist
Lighting Fixture - HID	
Instance on Room 348	Does not Exist
Instance on Rooms 243, 265, 346, 347, 353	Does not Exist

**NYC Department of Education
Building Condition Assessment Survey 2017 - 2018**

Electrical Inspection

Q415

Question	Response
COMPUTER LAB	
Lighting	
Lighting Fixture - HID	
Instance on Room B37	Does not Exist
Lighting Fixture - Incandescent	
Instance on Room 348	Does not Exist
Instance on Rooms 243, 265, 346, 347, 353	Does not Exist
Instance on Room B37	Does not Exist
Lighting Fixture - LED	
Instance on Room 348	Does not Exist
Instance on Rooms 243, 265, 346, 347, 353	Does not Exist
Instance on Room B37	Does not Exist
Raceway With Receptacles	
	Inspected
Instance on Room 348	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on Rooms 243, 265, 346, 347, 353	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on Room B37	Does not Exist
GYMNASIUM	
	Inspected
Instance on 1st Floor - Boys	Inspected
Instance on 1st Floor - Girls	Inspected
Lighting	
	Inspected
Instance on 1st Floor - Girls	Inspected
Instance on 1st Floor - Boys	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor - Girls	Does not Exist
Instance on 1st Floor - Boys	Does not Exist
Lighting Fixture - HID	
Instance on 1st Floor - Girls	Does not Exist
Instance on 1st Floor - Boys	Does not Exist
Lighting Fixture - Incandescent	
Instance on 1st Floor - Girls	Does not Exist
Instance on 1st Floor - Boys	Does not Exist
Lighting Fixture - LED	
Instance on 1st Floor - Girls	Inspected
Instance on 1st Floor - Boys	Inspected
Pendant Mounted	
	Inspected
Instance on 1st Floor - Girls	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Instance on 1st Floor - Boys	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Surface Mounted	
	Does not Exist
Instance on 1st Floor - Girls	Does not Exist
Instance on 1st Floor - Boys	Does not Exist
Recessed Mounted	
	Does not Exist

**NYC Department of Education
Building Condition Assessment Survey 2017 - 2018**

Electrical Inspection

Q415

Question	Response
GYMNASIUM	
Lighting	Inspected
Lighting Fixture - LED	
Recessed Mounted	
Instance on 1st Floor - Girls	Does not Exist
Instance on 1st Floor - Boys	Does not Exist
Local Sound System	Inspected
Instance on 1st Floor - Girls	Inspected
Installation Year	2005
Source of Installation	Custodial Staff
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on 1st Floor - Boys	Inspected
Installation Year	2005
Source of Installation	Custodial Staff
Condition	3 - Fair
Deficiency	No deficiencies recorded
Projection System	Does not Exist
Instance on 1st Floor - Girls	Does not Exist
Instance on 1st Floor - Boys	Does not Exist
Scoreboard	Does not Exist
Instance on 1st Floor - Girls	Does not Exist
Instance on 1st Floor - Boys	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Theater Lighting System	Does not Exist
Instance on 1st Floor - Girls	Does not Exist
Instance on 1st Floor - Boys	Does not Exist
KITCHEN	Inspected
Instance on 1st Floor	Inspected
Lighting	Inspected
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Pendant Mounted	Does not Exist
Instance on 1st Floor	Does not Exist
Surface Mounted	Does not Exist
Instance on 1st Floor	Does not Exist
Recessed Mounted	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on 1st Floor	Does not Exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not Exist
Lighting Fixture - LED	
Instance on 1st Floor	Does not Exist
LIBRARY	Inspected

NYC Department of Education
Building Condition Assessment Survey 2017 - 2018

Electrical Inspection

Q415

Question	Response
LIBRARY	
Instance on Room 216	Inspected
Lighting	Inspected
Instance on Room 216	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 216	Inspected
Pendant Mounted	
Instance on Room 216	Does not Exist
Surface Mounted	
Instance on Room 216	Does not Exist
Recessed Mounted	
Instance on Room 216	Inspected
Condition	3 - Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Lighting Fixture - HID	
Instance on Room 216	Does not Exist
Lighting Fixture - Incandescent	
Instance on Room 216	Does not Exist
Lighting Fixture - LED	
Instance on Room 216	Does not Exist
Raceway With Receptacles	
Instance on Room 216	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Projection System	
Instance on Room 216	Does not Exist
LOCKER ROOM	
Instance on Rooms B55, B57, B59, 1st Floor - Visitors	Inspected
Alternative use	No
Instance on Room B67 - Boys	Inspected
Alternative use	No
Instance on Room B66 - Girls	Inspected
Alternative use	No
Lighting	Inspected
Instance on Room B66 - Girls	Inspected
Instance on Room B67 - Boys	Inspected
Instance on Rooms B55, B57, B59, 1st Floor - Visitors	Inspected
Lighting Fixture - Fluorescent	
Instance on Room B66 - Girls	Inspected
Instance on Room B67 - Boys	Inspected
Instance on Rooms B55, B57, B59, 1st Floor - Visitors	Inspected
Pendant Mounted	
	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2017 - 2018

Electrical Inspection

Q415

Question	Response
LOCKER ROOM	
Lighting	
Lighting Fixture - Fluorescent	
Pendant Mounted	Does not Exist
Instance on Room B66 - Girls	Does not Exist
Instance on Room B67 - Boys	Does not Exist
Instance on Rooms B55, B57, B59, 1st Floor - Visitors	Does not Exist
Surface Mounted	Inspected
Instance on Room B66 - Girls	Inspected
Condition	3 - Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance on Room B67 - Boys	Does not Exist
Instance on Rooms B55, B57, B59, 1st Floor - Visitors	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not Exist
Instance on Room B66 - Girls	Does not Exist
Instance on Room B67 - Boys	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on Rooms B55, B57, B59, 1st Floor - Visitors	Does not Exist
Lighting Fixture - HID	
Instance on Room B66 - Girls	Does not Exist
Instance on Room B67 - Boys	Does not Exist
Instance on Rooms B55, B57, B59, 1st Floor - Visitors	Does not Exist
Lighting Fixture - Incandescent	
Instance on Room B66 - Girls	Does not Exist
Instance on Room B67 - Boys	Inspected
Instance on Rooms B55, B57, B59, 1st Floor - Visitors	Does not Exist
Pendant Mounted	Does not Exist
Instance on Room B67 - Boys	Does not Exist
Surface Mounted	Inspected
Instance on Room B67 - Boys	Inspected
Condition	3 - Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.

**NYC Department of Education
Building Condition Assessment Survey 2017 - 2018**

Electrical Inspection

Q415

Question	Response
LOCKER ROOM	
Lighting	
Lighting Fixture - Incandescent	
Recessed Mounted	Does not Exist
Instance on Room B67 - Boys	Does not Exist
Lighting Fixture - LED	
Instance on Room B66 - Girls	Does not Exist
Instance on Room B67 - Boys	Does not Exist
Instance on Rooms B55, B57, B59, 1st Floor - Visitors	Does not Exist
MULTIPURPOSE ROOM	Inspected
Instance on Room B41	Inspected
Lighting	Inspected
Instance on Room B41	Inspected
Lighting Fixture - Fluorescent	
Instance on Room B41	Inspected
Pendant Mounted	Does not Exist
Instance on Room B41	Does not Exist
Surface Mounted	Inspected
Instance on Room B41	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not Exist
Instance on Room B41	Does not Exist
Lighting Fixture - HID	
Instance on Room B41	Does not Exist
Lighting Fixture - Incandescent	
Instance on Room B41	Does not Exist
Lighting Fixture - LED	
Instance on Room B41	Does not Exist
Local Sound System	Does not Exist
Instance on Room B41	Does not Exist
Projection System	Does not Exist
Instance on Room B41	Does not Exist
Theater Lighting System	Does not Exist
Instance on Room B41	Does not Exist
SCIENCE DEMO ROOM	Inspected
Instance on Room B33	Inspected
Power Panel	Yes
Alternative use	No
Instance on Rooms B55, B57, B59	Inspected
Power Panel	No
Alternative use	No
Instance on Room 260	Inspected
Power Panel	No
Alternative use	No
Lighting	Inspected
Instance on Room 260	Inspected
Instance on Rooms B55, B57, B59	Inspected
Instance on Room B33	Inspected
Lighting Fixture - Fluorescent	

**NYC Department of Education
Building Condition Assessment Survey 2017 - 2018**

Electrical Inspection

Q415

Question	Response
SCIENCE DEMO ROOM	
Lighting	
Lighting Fixture - Fluorescent	
Instance on Room 260	Inspected
Instance on Rooms B55, B57, B59	Inspected
Instance on Room B33	Inspected
Pendant Mounted	
Instance on Room 260	Does not Exist
Instance on Rooms B55, B57, B59	Does not Exist
Instance on Room B33	Does not Exist
Surface Mounted	
Instance on Room 260	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on Rooms B55, B57, B59	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on Room B33	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 260	Does not Exist
Instance on Rooms B55, B57, B59	Does not Exist
Instance on Room B33	Does not Exist
Lighting Fixture - HID	
Instance on Room 260	Does not Exist
Instance on Rooms B55, B57, B59	Does not Exist
Instance on Room B33	Does not Exist
Lighting Fixture - Incandescent	
Instance on Room 260	Inspected
Instance on Rooms B55, B57, B59	Inspected
Instance on Room B33	Inspected
Pendant Mounted	
Instance on Room 260	Does not Exist
Instance on Rooms B55, B57, B59	Does not Exist
Instance on Room B33	Does not Exist
Surface Mounted	
Instance on Room 260	Inspected
Condition	3 - Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance on Rooms B55, B57, B59	Inspected
Condition	3 - Fair

NYC Department of Education
Building Condition Assessment Survey 2017 - 2018

Electrical Inspection

Q415

Question	Response
SCIENCE DEMO ROOM	
Lighting	
Lighting Fixture - Incandescent	
Surface Mounted	
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance on Room B33	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 260	Does not Exist
Instance on Rooms B55, B57, B59	Does not Exist
Instance on Room B33	Does not Exist
Lighting Fixture - LED	
Instance on Room 260	Does not Exist
Instance on Rooms B55, B57, B59	Does not Exist
Instance on Room B33	Does not Exist
Projection System	
Instance on Room 260	Does not Exist
Instance on Rooms B55, B57, B59	Does not Exist
Instance on Room B33	Does not Exist
Emergency Gas Shut-Off Valve	
Instance on Room 260	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on Rooms B55, B57, B59	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on Room B33	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Emergency Shut-Off Power	
Instance on Room 260	Does not Exist
Instance on Rooms B55, B57, B59	Does not Exist
Instance on Room B33	Does not Exist
Power Supply	
Instance on Room 260	Inspected
Instance on Rooms B55, B57, B59	Inspected
Instance on Room B33	Inspected
Instructor Unit	
Instance on Room 260	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2017 - 2018

Electrical Inspection

Q415

Question	Response
SCIENCE DEMO ROOM	
Power Supply	
Instructor Unit	
Instance on Rooms B55, B57, B59	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on Room B33	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Meter Demonstration Unit	
Instance on Room 260	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on Rooms B55, B57, B59	Does not Exist
Instance on Room B33	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
SCIENCE LAB	
Instance on Rooms B35, B39	Inspected
Power Panel	Yes
Alternative use	No
Instance on Room 251	Inspected
Power Panel	Yes
Alternative use	Yes
Instance on Rooms 253, 257	Inspected
Power Panel	Yes
Alternative use	No
Instance on Room 255	Inspected
Power Panel	Yes
Alternative use	No
Lighting	Inspected
Instance on Room 255	Inspected
Instance on Rooms 253, 257	Inspected
Instance on Room 251	Inspected
Instance on Rooms B35, B39	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 255	Inspected
Instance on Rooms 253, 257	Inspected
Instance on Room 251	Inspected
Instance on Rooms B35, B39	Inspected
Pendant Mounted	
Instance on Room 255	Does not Exist
Instance on Rooms 253, 257	Does not Exist
Instance on Room 251	Does not Exist
Instance on Rooms B35, B39	Does not Exist
Surface Mounted	
Instance on Room 255	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on Rooms 253, 257	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2017 - 2018**

Electrical Inspection

Q415

Question	Response
SCIENCE LAB	
Lighting	
Lighting Fixture - Fluorescent	
Surface Mounted	
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on Room 251	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on Rooms B35, B39	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 255	Does not Exist
Instance on Rooms 253, 257	Does not Exist
Instance on Room 251	Does not Exist
Instance on Rooms B35, B39	Does not Exist
Lighting Fixture - HID	
Instance on Room 255	Does not Exist
Instance on Rooms 253, 257	Does not Exist
Instance on Room 251	Does not Exist
Instance on Rooms B35, B39	Does not Exist
Lighting Fixture - Incandescent	
Instance on Room 255	Inspected
Instance on Rooms 253, 257	Inspected
Instance on Room 251	Inspected
Instance on Rooms B35, B39	Inspected
Pendant Mounted	
Instance on Room 255	Does not Exist
Instance on Rooms 253, 257	Does not Exist
Instance on Room 251	Does not Exist
Instance on Rooms B35, B39	Does not Exist
Surface Mounted	
Instance on Room 255	Inspected
Condition	3 - Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance on Rooms 253, 257	Inspected
Condition	3 - Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE

NYC Department of Education
Building Condition Assessment Survey 2017 - 2018

Electrical Inspection

Q415

Question	Response
SCIENCE LAB	
Lighting	
Lighting Fixture - Incandescent	
Surface Mounted	
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance on Room 251	Inspected
Condition	3 - Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance on Rooms B35, B39	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 255	Does not Exist
Instance on Rooms 253, 257	Does not Exist
Instance on Room 251	Does not Exist
Instance on Rooms B35, B39	Does not Exist
Lighting Fixture - LED	
Instance on Room 255	Does not Exist
Instance on Rooms 253, 257	Does not Exist
Instance on Room 251	Does not Exist
Instance on Rooms B35, B39	Does not Exist
Emergency Gas Shut-Off Valve	
Instance on Room 255	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on Rooms 253, 257	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on Room 251	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on Rooms B35, B39	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Emergency Shut-Off Power	
Instance on Room 255	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on Rooms 253, 257	Inspected

NYC Department of Education
Building Condition Assessment Survey 2017 - 2018

Electrical Inspection

Q415

Question	Response
SCIENCE LAB	
Emergency Shut-Off Power	
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on Room 251	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on Rooms B35, B39	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Power Supply	
Instance on Room 255	Inspected
Instance on Rooms 253, 257	Inspected
Instance on Room 251	Inspected
Instance on Rooms B35, B39	Inspected
Instructor Unit	
Instance on Room 255	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on Rooms 253, 257	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on Room 251	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on Rooms B35, B39	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Student Unit	
Instance on Room 255	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on Rooms 253, 257	Does not Exist
Instance on Room 251	Does not Exist
Instance on Rooms B35, B39	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Meter Demonstration Unit	
Instance on Room 255	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on Rooms 253, 257	Does not Exist
Instance on Room 251	Does not Exist
Instance on Rooms B35, B39	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Projection System	
Instance on Room 255	Does not Exist
Instance on Rooms 253, 257	Does not Exist
Instance on Room 251	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2017 - 2018

Electrical Inspection

Q415

Question	Response
SCIENCE LAB	Inspected
Projection System	
Instance on Rooms B35, B39	Does not Exist
SCIENCE PREP ROOM	Inspected
Instance on Room 252	Inspected
Power Panel Alternative use	Yes No
Instance on Room 258	Inspected
Power Panel Alternative use	No No
Lighting	Inspected
Instance on Room 258	Inspected
Instance on Room 252	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 258	Inspected
Instance on Room 252	Inspected
Pendant Mounted	Does not Exist
Instance on Room 258	Does not Exist
Instance on Room 252	Does not Exist
Surface Mounted	Inspected
Instance on Room 258	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on Room 252	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not Exist
Instance on Room 258	Does not Exist
Instance on Room 252	Does not Exist
Lighting Fixture - HID	
Instance on Room 258	Does not Exist
Instance on Room 252	Does not Exist
Lighting Fixture - Incandescent	
Instance on Room 258	Inspected
Instance on Room 252	Inspected
Pendant Mounted	Does not Exist
Instance on Room 258	Does not Exist
Instance on Room 252	Does not Exist
Surface Mounted	Inspected
Instance on Room 258	Inspected
Condition	3 - Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.

NYC Department of Education
Building Condition Assessment Survey 2017 - 2018

Electrical Inspection

Q415

Question	Response
SCIENCE PREP ROOM	Inspected
Lighting	
Lighting Fixture - Incandescent	
Surface Mounted	
Instance on Room 252	Inspected
Condition	3 - Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Recessed Mounted	Does not Exist
Instance on Room 258	Does not Exist
Instance on Room 252	Does not Exist
Lighting Fixture - LED	
Instance on Room 258	Does not Exist
Instance on Room 252	Does not Exist
Emergency Gas Shut-Off Valve	Inspected
Instance on Room 258	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on Room 252	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Emergency Shut-Off Power	Does not Exist
Instance on Room 258	Does not Exist
Instance on Room 252	Does not Exist
Power Supply	Inspected
Instance on Room 258	Inspected
Instance on Room 252	Inspected
Instructor Unit	
Instance on Room 258	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on Room 252	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
SWIMMING POOL	Does not Exist
TOILET ROOM - STAFF	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not Exist
Surface Mounted	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Inspected

NYC Department of Education
Building Condition Assessment Survey 2017 - 2018

Electrical Inspection

Q415

Question	Response
TOILET ROOM - STAFF	
Lighting	
Lighting Fixture - Fluorescent	Inspected
Recessed Mounted	
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not Exist
Lighting Fixture - Incandescent	Does not Exist
Lighting Fixture - LED	Does not Exist
TOILET ROOM - STUDENT	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not Exist
Lighting Fixture - Incandescent	Does not Exist
Lighting Fixture - LED	Does not Exist
AUXILIARY SIGNAL/BELL SYSTEM	Inspected
Replacement Quantity	284,000
Replacement Uom	S.F.
Condition	3 - Fair
Deficiency	No deficiencies recorded
EMERGENCY DC STANDBY BATTERY POWER	Does not Exist
EMERGENCY GENERATOR SET	Inspected
Automatic Transfer Switch (ATS)	Inspected
Instance	Electrical Room
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	GE Zenith Controls
Equipment	N/A
Capacity/Size Quantity	200
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	2010
Source of Installation	Custodial Staff
Deficiency	No deficiencies recorded
Instance	Electrical Room
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	ASCO

**NYC Department of Education
Building Condition Assessment Survey 2017 - 2018**

Electrical Inspection

Q415

Question	Response
EMERGENCY GENERATOR SET	
Automatic Transfer Switch (ATS)	
Equipment	Fire Alarm ATS Switch
Capacity/Size Quantity	104
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	2010
Source of Installation	Custodial Staff
Deficiency	No deficiencies recorded
Battery Charger	Inspected
Instance	Electrical Room
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	SENS
Equipment	Battery Charger
Capacity/Size Quantity	3
Capacity/Size UOM	AmpsDC
Capacity/Size2 Quantity	12
Capacity/Size2 UOM	VDC
Source of Capacity/Size	Nameplate
Installation Year	2010
Source of Installation	Custodial Staff
Deficiency	No deficiencies recorded
Diesel	Does not Exist
Natural Gas	Inspected
Instance	Generator Room
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Cummins Onan
Equipment	Emergency Generator
Capacity/Size Quantity	50
Capacity/Size UOM	KVA
Capacity/Size2 Quantity	40
Capacity/Size2 UOM	KW
Capacity/Size3Quantity	139
Capacity/Size3 UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1967
Source of Installation	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Generator Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded

NYC Department of Education
Building Condition Assessment Survey 2017 - 2018

Electrical Inspection

Q415

Question	Response
EMERGENCY GENERATOR SET	Inspected
Natural Gas	
Violations	No violations recorded.
EMERGENCY LIGHT/EXIT LIGHT PANEL	Inspected
Condition	2 - Between Good and Fair
Deficiency	LESS THAN 20% SPARE CIRCUIT BREAKERS
Deficiency Location/Instance	Electrical Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL NEW PANEL BOARD
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
EMERGENCY LIGHTING	Inspected
Battery Pack	Inspected
Condition	3 - Fair
Deficiency	BATTERY NOT OPERATIONAL
Deficiency Location/Instance	Auditorium, Library, Corridors By Rooms (114, 119, 129, 135, 158)
Deficiency Quantity	11
Quantity Uom	EACH
Potential Action	REPLACE BATTERY
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Non Battery Pack	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
EXIT LIGHT	Inspected
Battery Pack	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Non Battery Pack	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
EXIT/EMERGENCY LIGHT	Does not Exist
CITY FIRE ALARM SYSTEM	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
FIRE ALARM SYSTEM	Inspected
Replacement Quantity	284,000
Replacement Uom	S.F.
Bell/Horn	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Strobe	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2017 - 2018**

Electrical Inspection

Q415

Question	Response
FIRE ALARM SYSTEM	
Manual Pull Station	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Fan Shutdown Control	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Duct Smoke Detector	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Area Smoke Detector	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
CO Detector	Does not Exist
Heat Detector	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Elevator Recall	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Magnetic Door Holder/Contactor	Does not Exist
Fused Cutout Panel	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Fire Alarm Digital Communicator	Does not Exist
Main Panel	Inspected
Bell At Panel	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Main Entrance Lobby
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	General Electric
Equipment	Fire Alarm Control Panel
Model	EST 2
Capacity/Size Quantity	14
Capacity/Size UOM	Zones
Capacity/Size2 Quantity	1
Capacity/Size2 UOM	Section(S)
Source of Capacity/Size	Diagram
Installation Year	2010
Source of Installation	Custodial Staff
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	Does not Exist
Sub-Panel	Does not Exist
Remote Annunciator	Inspected
Display Monitor	Does not Exist

**NYC Department of Education
Building Condition Assessment Survey 2017 - 2018**

Electrical Inspection

Q415

Question	Response
FIRE ALARM SYSTEM	
Remote Annunciator	
Panel	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Printer	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Punch Register	Does not Exist
Sprinkler Flow/Air Pressure Switch	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Tamper Flow Switch/Chain	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
INTERCOM SYSTEM	Inspected
Elevator	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Holding Area	Does not Exist
LAN	Inspected
Local Distribution Frame (I/LDF)	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Main Equipment Rack (MDF)	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
LIGHTNING PROTECTION	Does not Exist
MOTOR CONTROL CENTER	Does not Exist
MOTOR STARTER/CONTACTOR	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
PANEL BOARD	Inspected
Fused Disconnect Switch Type	Inspected
Condition	3 - Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Boiler Room, Basement - Fan Room, Fan Room - A, Fan Room - B, Fan Room - C
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Deficiency Photo	No photo recorded
Violations	No violations recorded.
Fused Knife Switch Type	Does not Exist
Fused Toggle Switch Type	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2017 - 2018

Electrical Inspection

Q415

Question	Response
PANEL BOARD	
Molded Case Circuit Breaker Type	Inspected
Condition	3 - Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Boiler Room, Rooms (B35, B39, 253, 255, 257), Gymnasium - Girls, Corridors By Rooms (B11, B19, B59, 138, 141, 161, 175, 178, 209, 235, 244, 251, 301, 311, 322, 342, 343, 352)
Deficiency Quantity	32
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	NO SPARE
Deficiency Location/Instance	Electrical Room, Cafeteria, Kitchen, Gymnasium - Boys, Rooms (251, 252), Corridors By Rooms (B40, 154, 169, 201, 216, 261, 330)
Deficiency Quantity	17
Quantity Uom	EACH
Potential Action	REPLACE PANEL BOARD
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	PANEL BOARD COVER IS MISSING
Deficiency Location/Instance	Gymnasium - Boys, Corridors By Rooms (B19, B40, 169, 201)
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	NO SPARE
Deficiency Location/Instance	Electrical Room, Room 347
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	INSTALL NEW PANEL BOARD
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	PANEL BOARD DIRECTORY MISSING OR REQUIRES UPDATING
Deficiency Location/Instance	Boiler Room, Kitchen, Gymnasium - Girls, Room 243, Corridors By Rooms (Auditorium, 104, 108, 161, 135, 138)
Deficiency Quantity	11
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2

NYC Department of Education
Building Condition Assessment Survey 2017 - 2018

Electrical Inspection

Q415

Question	Response
PANEL BOARD	Inspected
Molded Case Circuit Breaker Type	
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
PUBLIC ADDRESS SYSTEM	Inspected
Replacement Quantity	284,000
Replacement Uom	S.F.
Instance	Room 105D
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Dukane 250
Installation Year	2005
Source of Installation	Custodial Staff
Deficiency	CLOCK NOT OPERATIONAL
Deficiency Location/Instance	Auditorium, Rooms (B57, 253, 303), Corridor By Room 346
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
SECURITY	Inspected
IPDVS/CCTV System	Inspected
Replacement Quantity	284,000
Replacement Uom	S.F.
Installation Year	2007
Source of Installation	Custodial Staff
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Intrusion Alarm System	Inspected
Replacement Quantity	284,000
Replacement Uom	S.F.
Central Control Panel	Inspected
Instance	Custodian's Office
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista - 128BPT
Installation Year	2014
Source of Installation	Custodial Staff
Deficiency	No deficiencies recorded
Infrared Sensor	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Panic Switch	Inspected
Condition	5 - Poor
Deficiency	SWITCH NOT OPERATIONAL

NYC Department of Education
Building Condition Assessment Survey 2017 - 2018

Electrical Inspection

Q415

Question	Response
SECURITY	
Intrusion Alarm System	
Panic Switch	
Deficiency Location/Instance	Principal's Office
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 4
Purpose of Action	LEVEL 3
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Remote Annunciator	
	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Siren/Strobe	
	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Ultrasonic Sensor	
	Does not Exist
Lighting - Security	
	Inspected
Replacement Quantity	61
Replacement Uom	EACH
Condition	2 - Between Good and Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Location/Instance	Building Perimeters
Deficiency Quantity	11
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 3
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
SERVICE SWITCH	
	Inspected
Instance	Electrical Room
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Federal Pacific Electric
Equipment	5000A SW. 4000A Fuse Main Switch
Capacity/Size Quantity	4,000
Capacity/Size UOM	Amps
Source of Capacity/Size	Fuse Size
Installation Year	1967
Source of Installation	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Generator Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1

NYC Department of Education
Building Condition Assessment Survey 2017 - 2018

Electrical Inspection

Q415

Question	Response
SERVICE SWITCH	
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance	Electrical Room
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Federal Pacific Electric
Equipment	2500A SW. 2001A Fuse SUB DIST PNL
Capacity/Size Quantity	2,001
Capacity/Size UOM	Amps
Source of Capacity/Size	Fuse Size
Installation Year	1967
Source of Installation	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Generator Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance	Electrical Room
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Federal Pacific Electric
Equipment	400A SW. 400A Fuse Kitchen DIST PNL
Capacity/Size Quantity	400
Capacity/Size UOM	Amps
Source of Capacity/Size	Fuse Size
Installation Year	1967
Source of Installation	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Generator Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance	Electrical Room
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Federal Pacific Electric

NYC Department of Education
Building Condition Assessment Survey 2017 - 2018

Electrical Inspection

Q415

Question	Response
SERVICE SWITCH	
Equipment	1200A SW. 1200A Fuse Chiller Unit
Capacity/Size Quantity	1,200
Capacity/Size UOM	Amps
Source of Capacity/Size	Fuse Size
Installation Year	1967
Source of Installation	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Generator Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
SWITCHBOARD	
Number of Spares	Inspected 14
Air Circuit Breaker Type	Does not Exist
Fused Disconnect Switch Type	Inspected
Instance	Electrical Room
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Federal Pacific Electric
Equipment	N/A
Capacity/Size Quantity	4,000
Capacity/Size UOM	Amps Total
Capacity/Size2 Quantity	6
Capacity/Size2 UOM	Section(S)
Source of Capacity/Size	Service Switch Fuse Size
Installation Year	1967
Source of Installation	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Generator Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance	Room B45
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Federal Pacific Electric
Equipment	Main DIS. 2500A
Capacity/Size Quantity	2,001

NYC Department of Education
Building Condition Assessment Survey 2017 - 2018

Electrical Inspection

Q415

Question	Response
SWITCHBOARD	
Fused Disconnect Switch Type	
Capacity/Size UOM	Amps Total
Capacity/Size2 Quantity	4
Capacity/Size2 UOM	Section(S)
Source of Capacity/Size	Service Switch Fuse Size
Installation Year	1967
Source of Installation	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Generator Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance	Electrical Room
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Federal Pacific Electric
Equipment	Kitchen DIST PNL
Capacity/Size Quantity	400
Capacity/Size UOM	Amps Total
Capacity/Size2 Quantity	1
Capacity/Size2 UOM	Section(S)
Source of Capacity/Size	Service Switch Fuse Size
Installation Year	1967
Source of Installation	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Generator Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Fused Knife Switch Type	Does not Exist
Molded Case Circuit Breaker Type	Does not Exist
TELEPHONE SYSTEM	Inspected
PBX/Intercom	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Standard	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
TRANSFORMER	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2017 - 2018

Electrical Inspection

Q415

Question	Response
TV SYSTEM	Inspected
Cable System Exist?	Yes
Operational?	Yes
Main Equipment Rack	Does not Exist