

NYC Department of Education
Building Condition Assessment Survey 2018 - 2019

Electrical Inspection

Q481

Asset: JOHN ADAMS AF - QUEENS, 101-01 ROCKAWAY BLVD, New York, 11417

Inspection Id	Inspection Type	Time In	Last Edited
EE : Q481	Electrical	2018-12-28 9:04 AM	2019-05-13 9:46 AM

Asset Data

Question	Answer
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	No
Water Penetration in Electrical Room?	No
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Scoreboard
	Years: 2010

DEDICATED INTERCOMS IN FIRE RESCUE AREAS

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	No

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
No condition recorded								

Inspection

Question	Response
Electrical	
ATHLETIC FIELD	Inspected
Exterior Lighting	Does not Exist
Local Sound System	Inspected
Installation Year	1990
Source of Installation	Inspector Estimate
Condition	5 - Poor
Deficiency	AMPLIFIER NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE SYSTEM
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Scoreboard	Inspected
Instance	Back off Main Asset Q480 facing Football Field
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	No deficiencies recorded
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	Does not Exist
LOCKER ROOM	Does not Exist
TOILET ROOM - STAFF	Does not Exist
TOILET ROOM - STUDENT	Does not Exist
AUXILIARY SIGNAL/BELL SYSTEM	Does not Exist
EMERGENCY DC STANDBY BATTERY POWER	Does not Exist
EMERGENCY GENERATOR SET	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2018 - 2019

Electrical Inspection

Q481

Question	Response
EMERGENCY LIGHT/EXIT LIGHT PANEL	Does not Exist
EMERGENCY LIGHTING	Does not Exist
EXIT LIGHT	Does not Exist
EXIT/EMERGENCY LIGHT	Does not Exist
FIRE ALARM SYSTEM	Does not Exist
GROUNDING SYSTEM	Does not Exist
LAN	Does not Exist
LIGHTNING PROTECTION	Does not Exist
MOTOR CONTROL CENTER	Does not Exist
MOTOR STARTER/CONTACTOR	Does not Exist
PANEL BOARD	Does not Exist
PUBLIC ADDRESS SYSTEM	Does not Exist
SECURITY	Does not Exist
SERVICE SWITCH	Does not Exist
SWITCHBOARD	Does not Exist
TELEPHONE SYSTEM	Does not Exist
TRANSFORMER	Does not Exist
TV SYSTEM	Does not Exist