

**NYC Department of Education
Building Condition Assessment Survey 2018 - 2019**

Mechanical Inspection

Q822

Asset: P.S. 811 MINISCHOOL (OLD 136 MN)-Q, 114-36 202ND STREET, New York, 11412

Inspection Id	Inspection Type	Time In	Last Edited
ME : Q822	Mechanical	2018-10-31 8:47 AM	2018-10-31 3:00 PM

Asset Data

Question	Answer
Are there fuel tanks?	No
Total # of water main service entries to the asset	1
MERs/Fan Rooms Locations	MER M-8
Are there any spaces with Missing or Defective CO Detectors?	No
Are there any Emergency Stop Switches with Missing Hammers?	No
Are there any Painted/Obstructed Sprinkler Heads?	No
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Gas Fired Domestic Water Heater
	Years: 2008

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
No condition recorded								

Inspection

Question	Response
Mechanical	
AIR CONDITIONING	Inspected
Chilled Water System	Does not Exist
Condenser Water Distribution: Piping, Pumps and Auxiliaries	Does not Exist
Cooling Coil in Ductwork	Does not Exist
Cooling Tower	Does not Exist
DX Split System	Inspected
Indoor Unit	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Outdoor Unit	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Dry Cooler	Does not Exist
Packaged / Rooftop Unit	Does not Exist
Packaged Terminal A/C	Does not Exist
Refrigerant Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Return Fan	Does not Exist
CENTRAL ACID WASTE NEUTRALIZING TANK	Does not Exist
CLIMATE CONTROL SYSTEM	Does not Exist
COMPACTOR	Does not Exist
CONVEYING	Does not Exist
DOMESTIC WATER SYSTEM	Inspected
Domestic Cold Water System	Inspected
Gravity System	Does not Exist
Pressure Booster System	Does not Exist

**NYC Department of Education
Building Condition Assessment Survey 2018 - 2019**

Mechanical Inspection

Q822

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Cold Water System	
Water Service	Inspected
Instance	MER M-8
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	No deficiencies recorded
Domestic Hot Water System	Inspected
Domestic Hot Water Remote Storage Tank	Does not Exist
Domestic Water Heat Exchanger	Does not Exist
Electric Domestic Water Heater	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Gas Fired Domestic Water Heater	Does not Exist
Oil Fired Domestic Water Heater	Does not Exist
Domestic Water Distribution Piping	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
DRAIN/WASTE/VENT AND STORM SYSTEM	Inspected
Interior Storm Piping	Does not Exist
Sewage/Waste/Vent Piping	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Sewage Ejector Pump	Does not Exist
Sump Pump	Does not Exist
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	Does not Exist
FIXTURES	Inspected
Staff And Other	Inspected
Janitor Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Urinal	Does not Exist
Student	Inspected
Drinking Fountain	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Locker Room Shower	Does not Exist
Sink And Fountain Combo Unit	Does not Exist

**NYC Department of Education
Building Condition Assessment Survey 2018 - 2019**

Mechanical Inspection

Q822

Question	Response
FIXTURES	
Student	
Toilet	Inspected
Condition	3 - Fair
Deficiency	CLOGGED/LEAKING
Deficiency Location/Instance	Boy's Toilet Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Urinal	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
GAS FIRED FURNACE	Does not Exist
GAS SERVICE	Does not Exist
HEATING	Inspected
Heating Coil In Ductwork	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hydronic Heating	Does not Exist
Radiator/Convactor/Fin Tube	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Steam Heating	Does not Exist
Steam supplied by External Sources	Does not Exist
Unit Heater/Cabinet Heater	Does not Exist
HEATING PLANT	Does not Exist
Enclosed IDF Room	Does not Exist
KITCHEN	Inspected
Instance on 1st Floor	Inspected
CO Detector	Not Required
Instance on 1st Floor	Not Required
Gas System	Does not Exist
Instance on 1st Floor	Does not Exist
Grease Trap	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood	Does not Exist
Instance on 1st Floor	Does not Exist
Hood Exhaust Ductwork	Does not Exist
Instance on 1st Floor	Does not Exist
Hood Exhaust Fan	Does not Exist
Instance on 1st Floor	Does not Exist
Hood Fire Suppression System	Does not Exist
Instance on 1st Floor	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2018 - 2019

Mechanical Inspection

Q822

Question	Response
KITCHEN	
Hot Water Temperature Booster	Does not Exist
Instance on 1st Floor	Does not Exist
Kitchen Sink	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
MDF Room	Does not Exist
SCIENCE DEMO ROOM	Does not Exist
SCIENCE LAB	Does not Exist
SCIENCE PREP ROOM	Does not Exist
SPRINKLERS, STANDPIPE, FIRE SYSTEM	Inspected
Dry Sprinkler Alarm Valve Assembly	Does not Exist
Wet Sprinkler Alarm Valve Assembly	Does not Exist
Fire Booster Pump Assembly	Does not Exist
Roof Tank	Does not Exist
Siamese Connection	Does not Exist
Sprinkler Head	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sprinkler Piping	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Standpipe System	Does not Exist
Water Gong	Does not Exist
SWIMMING POOL	Does not Exist
VENTILATION	Inspected
Exhaust Fan	Inspected
Approximate Total # of Fans	1-25
Condition	3 - Fair
Deficiency	No deficiencies recorded
Heating And Ventilating Unit	Does not Exist
Metal Ductwork	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE REGISTER/DIFFUSER
Deficiency Location/Instance	Room M-13
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Supply Fan	Does not Exist
Unit Ventilator	Does not Exist