

NYC Department of Education
Building Condition Assessment Survey 2017 - 2018

Electrical Inspection

Q864

Asset: P.S. 54 MINISCHOOL - QUEENS, 86-02 127TH STREET, New York, 11418

Inspection Id	Inspection Type	Time In	Last Edited
EE : Q864	Electrical	2018-01-23 11:26 AM	2018-01-29 3:15 PM

Asset Data

Question	Answer
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	Yes
Water Penetration in Electrical Room?	No
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Partial Security Lights
	Years: 2016
	Systems: Telephone System, LAN
	Years: 2007
	Systems: All Other Electrical Systems and Components
	Years: 1992

DEDICATED INTERCOMS IN FIRE RESCUE AREAS

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	No

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
No condition recorded								

Inspection

Question	Response
Electrical	
AUDITORIUM	Does not Exist
CAFETERIA	Does not Exist
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	Inspected
Lighting	Inspected
Does a Chandelier exist?	No
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not Exist
Surface Mounted	Inspected
Condition	3 - Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Recessed Mounted	Inspected
Condition	3 - Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3

**NYC Department of Education
Building Condition Assessment Survey 2017 - 2018**

Electrical Inspection

Q864

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
Lighting	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Lighting Fixture - HID	Does not Exist
Lighting Fixture - Incandescent	Does not Exist
Lighting Fixture - LED	Does not Exist
COMPUTER LAB	Does not Exist
GYMNASIUM	Does not Exist
KITCHEN	Does not Exist
LIBRARY	Does not Exist
LOCKER ROOM	Does not Exist
MULTIPURPOSE ROOM	Does not Exist
SCIENCE DEMO ROOM	Does not Exist
SCIENCE LAB	Does not Exist
SCIENCE PREP ROOM	Does not Exist
SWIMMING POOL	Does not Exist
TOILET ROOM - STAFF	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not Exist
Surface Mounted	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not Exist
Lighting Fixture - HID	Does not Exist
Lighting Fixture - Incandescent	Does not Exist
Lighting Fixture - LED	Does not Exist
TOILET ROOM - STUDENT	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not Exist
Surface Mounted	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not Exist
Lighting Fixture - HID	Does not Exist
Lighting Fixture - Incandescent	Does not Exist
Lighting Fixture - LED	Does not Exist
AUXILIARY SIGNAL/BELL SYSTEM	Inspected
Replacement Quantity	10,000
Replacement Uom	S.F.
Condition	3 - Fair
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2017 - 2018

Electrical Inspection

Q864

Question	Response
EMERGENCY DC STANDBY BATTERY POWER	Does not Exist
EMERGENCY GENERATOR SET	Does not Exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Inspected
Condition	3 - Fair
Deficiency	PANEL BOARD ID IS MISSING
Deficiency Location/Instance	Electrical Room inside Mechanical Room 117
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
EMERGENCY LIGHTING	Inspected
Battery Pack	Inspected
Condition	3 - Fair
Deficiency	BATTERY NOT OPERATIONAL
Deficiency Location/Instance	Mechanical Room 117, 1st Floor By Exits (11, 12)
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE BATTERY
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Non Battery Pack	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
EXIT LIGHT	Inspected
Battery Pack	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Does not Exist
EXIT/EMERGENCY LIGHT	Does not Exist
CITY FIRE ALARM SYSTEM	Does not Exist
FIRE ALARM SYSTEM	Inspected
Replacement Quantity	10,000
Replacement Uom	S.F.
Bell/Horn	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Strobe	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Manual Pull Station	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Fan Shutdown Control	Does not Exist
Duct Smoke Detector	Does not Exist

**NYC Department of Education
Building Condition Assessment Survey 2017 - 2018**

Electrical Inspection

Q864

Question	Response
FIRE ALARM SYSTEM	
Area Smoke Detector	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
CO Detector	Does not Exist
Heat Detector	Does not Exist
Elevator Recall	Does not Exist
Magnetic Door Holder/Contactor	Does not Exist
Fused Cutout Panel	Does not Exist
Fire Alarm Digital Communicator	Does not Exist
Main Panel	Does not Exist
Sub-Panel	Does not Exist
Remote Annunciator	Inspected
Display Monitor	Does not Exist
Panel	Does not Exist
Printer	Inspected
Condition	5 - Poor
Deficiency	PRINTER NOT OPERATIONAL
Deficiency Location/Instance	Room 122
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Punch Register	Does not Exist
Sprinkler Flow/Air Pressure Switch	Does not Exist
Tamper Flow Switch/Chain	Does not Exist
GROUNDING SYSTEM	Does not Exist
INTERCOM SYSTEM	Does not Exist
LAN	Inspected
Local Distribution Frame (I/LDF)	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Main Equipment Rack (MDF)	Does not Exist
LIGHTNING PROTECTION	Does not Exist
MOTOR CONTROL CENTER	Does not Exist
MOTOR STARTER/CONTACTOR	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
PANEL BOARD	Inspected
Fused Disconnect Switch Type	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Fused Knife Switch Type	Does not Exist
Fused Toggle Switch Type	Inspected
Condition	3 - Fair

NYC Department of Education
Building Condition Assessment Survey 2017 - 2018

Electrical Inspection

Q864

Question	Response
PANEL BOARD	Inspected
Fused Toggle Switch Type	Inspected
Deficiency	No deficiencies recorded
Molded Case Circuit Breaker Type	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
PUBLIC ADDRESS SYSTEM	Inspected
Replacement Quantity	10,000
Replacement Uom	S.F.
Instance	Connected to Main Asset Q054
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	N/A
Installation Year	1992
Source of Installation	Documented
Deficiency	No deficiencies recorded
SECURITY	Inspected
IPDVS/CCTV System	Does not Exist
Intrusion Alarm System	Inspected
Replacement Quantity	10,000
Replacement Uom	S.F.
Central Control Panel	Does not Exist
Infrared Sensor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Panic Switch	Does not Exist
Remote Annunciator	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Siren/Strobe	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Ultrasonic Sensor	Does not Exist
Lighting - Security	Inspected
Replacement Quantity	8
Replacement Uom	EACH
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
SERVICE SWITCH	Does not Exist
SWITCHBOARD	Inspected
Number of Spares	0
Air Circuit Breaker Type	Does not Exist
Fused Disconnect Switch Type	Inspected
Instance	Electrical Room Inside Mechanical Room 117
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Square D

**NYC Department of Education
Building Condition Assessment Survey 2017 - 2018**

Electrical Inspection

Q864

Question	Response
SWITCHBOARD	
Fused Disconnect Switch Type	
Equipment	DP-1
Capacity/Size Quantity	600
Capacity/Size UOM	Amps Total
Capacity/Size2 Quantity	1
Capacity/Size2 UOM	Section(S)
Source of Capacity/Size	Nameplate
Installation Year	1992
Source of Installation	Documented
Deficiency	No deficiencies recorded
Fused Knife Switch Type	Does not Exist
Molded Case Circuit Breaker Type	Does not Exist
TELEPHONE SYSTEM	
PBX/Intercom	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Standard	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
TRANSFORMER	Does not Exist
TV SYSTEM	Does not Exist