

**NYC Department of Education**  
**Building Condition Assessment Survey 2018 - 2019**

Electrical Inspection

Q980

**Asset:** COURT SQUARE CONF CENTER - QUEENS, 45-18 COURT SQUARE, New York, 11101

Inspection Id	Inspection Type	Time In	Last Edited
EE : Q980	Electrical	2018-10-22 11:46 AM	2018-10-29 3:08 PM

Asset Data

Question	Answer
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	Yes
Water Penetration in Electrical Room?	No
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: IPDVS/CCTV System
	Years: 2010
	Systems: Intrusion Alarm System
	Years: 2008
	Systems: All Other Electrical Systems and Components
	Years: 1998

**DEDICATED INTERCOMS IN FIRE RESCUE AREAS**

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	No

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
No condition recorded								

Inspection

Question	Response
<b>Electrical</b>	
<b>AUDITORIUM</b>	Does not Exist
<b>CAFETERIA</b>	Does not Exist
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	Inspected
<b>Lighting</b>	Inspected
Does a Chandelier exist?	Yes
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	Inspected
<b>Pendant Mounted</b>	Does not Exist
<b>Surface Mounted</b>	Does not Exist
<b>Recessed Mounted</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - Incandescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3 - Fair

**NYC Department of Education**  
**Building Condition Assessment Survey 2018 - 2019**

Electrical Inspection

Q980

<b>Question</b>	<b>Response</b>
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Incandescent</b>	
<b>Pendant Mounted</b>	
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Does not Exist
<b>Lighting Fixture - LED</b>	Does not Exist
<b>COMPUTER LAB</b>	Does not Exist
<b>GYMNASIUM</b>	Does not Exist
<b>KITCHEN</b>	Does not Exist
<b>LIBRARY</b>	Does not Exist
<b>LOCKER ROOM</b>	Does not Exist
<b>MULTIPURPOSE ROOM</b>	Does not Exist
<b>SCIENCE DEMO ROOM</b>	Does not Exist
<b>SCIENCE LAB</b>	Does not Exist
<b>SCIENCE PREP ROOM</b>	Does not Exist
<b>SWIMMING POOL</b>	Does not Exist
<b>TOILET ROOM - STAFF</b>	Inspected
<b>Lighting</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Does not Exist
<b>Surface Mounted</b>	Does not Exist
<b>Recessed Mounted</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	Does not Exist
<b>Lighting Fixture - Incandescent</b>	Does not Exist
<b>Lighting Fixture - LED</b>	Does not Exist
<b>TOILET ROOM - STUDENT</b>	Does not Exist
<b>AUXILIARY SIGNAL/BELL SYSTEM</b>	Does not Exist
<b>EMERGENCY DC STANDBY BATTERY POWER</b>	Does not Exist
<b>EMERGENCY GENERATOR SET</b>	Does not Exist
<b>EMERGENCY LIGHT/EXIT LIGHT PANEL</b>	Inaccessible
<b>EMERGENCY LIGHTING</b>	Inspected
<b>Battery Pack</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Non Battery Pack</b>	Does not Exist
<b>EXIT LIGHT</b>	Inspected
<b>Battery Pack</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Non Battery Pack</b>	Does not Exist
<b>EXIT/EMERGENCY LIGHT</b>	Inspected
Condition	3 - Fair

**NYC Department of Education  
Building Condition Assessment Survey 2018 - 2019**

Electrical Inspection

Q980

<b>Question</b>	<b>Response</b>
<b>EXIT/EMERGENCY LIGHT</b>	Inspected
Deficiency	No deficiencies recorded
<b>CITY FIRE ALARM SYSTEM</b>	Does not Exist
<b>FIRE ALARM SYSTEM</b>	Inspected
Replacement Quantity	24,000
Replacement Uom	S.F.
<b>Bell/Horn</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Strobe</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Manual Pull Station</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Fan Shutdown Control</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Duct Smoke Detector</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Area Smoke Detector</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>CO Detector</b>	Does not Exist
<b>Heat Detector</b>	Does not Exist
<b>Elevator Recall</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Magnetic Door Holder/Contactor</b>	Does not Exist
<b>Fused Cutout Panel</b>	Inaccessible
<b>Fire Alarm Digital Communicator</b>	Does not Exist
<b>Main Panel</b>	Inspected
<b>Bell At Panel</b>	Does not Exist
<b>Fire Alarm Control Panel (Electronic)</b>	Inspected
Instance	Main Entrance Lobby
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	N/A
Equipment	FIRE COMMAND STATION
Model	N/A
Capacity/Size Quantity	48
Capacity/Size UOM	Zones
Capacity/Size2 Quantity	2
Capacity/Size2 UOM	Section(S)
Source of Capacity/Size	Inspector Estimate
Installation Year	1998
Source of Installation	Documented

**NYC Department of Education  
Building Condition Assessment Survey 2018 - 2019**

Electrical Inspection

Q980

<b>Question</b>	<b>Response</b>
<b>FIRE ALARM SYSTEM</b>	Inspected
<b>Main Panel</b>	
<b>Fire Alarm Control Panel (Electronic)</b>	
Deficiency	PANEL DIRECTION/DIAGRAM IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>Fire Alarm Control Panel (Standard)</b>	Does not Exist
<b>Sub-Panel</b>	Does not Exist
<b>Remote Annunciator</b>	Inspected
<b>Display Monitor</b>	Does not Exist
<b>Panel</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Printer</b>	Does not Exist
<b>Punch Register</b>	Does not Exist
<b>Sprinkler Flow/Air Pressure Switch</b>	Inaccessible
<b>Tamper Flow Switch/Chain</b>	Inaccessible
<b>GROUNDING SYSTEM</b>	Inaccessible
<b>INTERCOM SYSTEM</b>	Inspected
<b>Elevator</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Holding Area</b>	Does not Exist
<b>LAN</b>	Inspected
<b>Local Distribution Frame (I/LDF)</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Main Equipment Rack (MDF)</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>LIGHTNING PROTECTION</b>	Does not Exist
<b>MOTOR CONTROL CENTER</b>	Does not Exist
<b>MOTOR STARTER/CONTACTOR</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>PANEL BOARD</b>	Inspected
<b>Fused Disconnect Switch Type</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Fused Knife Switch Type</b>	Does not Exist

**NYC Department of Education**  
**Building Condition Assessment Survey 2018 - 2019**

Electrical Inspection

Q980

<b>Question</b>	<b>Response</b>
<b>PANEL BOARD</b>	Inspected
<b>Fused Toggle Switch Type</b>	Does not Exist
<b>Molded Case Circuit Breaker Type</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>PUBLIC ADDRESS SYSTEM</b>	Does not Exist
<b>SECURITY</b>	Inspected
<b>IPDVS/CCTV System</b>	Inspected
Replacement Quantity	24,000
Replacement Uom	S.F.
Installation Year	2010
Source of Installation	Documented
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Intrusion Alarm System</b>	Inspected
Replacement Quantity	24,000
Replacement Uom	S.F.
<b>Central Control Panel</b>	Inspected
Instance	Room 269
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista - 50P
Installation Year	2008
Source of Installation	Documented
Deficiency	No deficiencies recorded
<b>Infrared Sensor</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Panic Switch</b>	Does not Exist
<b>Remote Annunciator</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Siren/Strobe</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Ultrasonic Sensor</b>	Does not Exist
<b>Lighting - Security</b>	Inspected
Replacement Quantity	9
Replacement Uom	EACH
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>SERVICE SWITCH</b>	Inaccessible
<b>SWITCHBOARD</b>	Inspected
Number of Spares	2
<b>Air Circuit Breaker Type</b>	Does not Exist
<b>Fused Disconnect Switch Type</b>	Inspected
Instance	Electrical Room near Staircase B
Instance Condition	3 - Fair

**NYC Department of Education  
Building Condition Assessment Survey 2018 - 2019**

Electrical Inspection

Q980

<b>Question</b>	<b>Response</b>
<b>SWITCHBOARD</b>	
<b>Fused Disconnect Switch Type</b>	
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	General Electric
Equipment	DP2A
Capacity/Size Quantity	1,200
Capacity/Size UOM	Amps Total
Capacity/Size2 Quantity	2
Capacity/Size2 UOM	Section(S)
Source of Capacity/Size	Nameplate
Installation Year	1998
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Mechanical Room
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	General Electric
Equipment	DP2C
Capacity/Size Quantity	800
Capacity/Size UOM	Amps Total
Capacity/Size2 Quantity	2
Capacity/Size2 UOM	Section(S)
Source of Capacity/Size	Nameplate
Installation Year	1998
Source of Installation	Documented
Deficiency	No deficiencies recorded
<b>Fused Knife Switch Type</b>	Does not Exist
<b>Molded Case Circuit Breaker Type</b>	Does not Exist
<b>TELEPHONE SYSTEM</b>	Inspected
<b>PBX/Intercom</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Standard</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>TRANSFORMER</b>	Does not Exist
<b>TV SYSTEM</b>	Does not Exist