

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

R051

School: **I.S. 51 - STATEN ISLAND, 20 HOUSTON STREET, STATEN ISLAND, NY, 10302**

InspectionId	Inspection Type	Time In	Last Edited
3140	ELECTRICAL	2019-03-19 09:37AM	2019-06-16 04:58PM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Public Address System, Local Sound System, Fire Alarm System, Gymnasium (Scoreboard) Years: 2014 Systems: Intercom System (Elevator) Years: 2013 Systems: Exit Lights Years: 2012 Systems: Interior Lighting, Retrofitted Recessed Fluorescent Lighting (Main Entrance Lobby) Years: 2010 Systems: LAN, Telephone System, Fused Disconnect Switch Type Panel Board Years: 2009 Systems: IPDVS/CCTV System, Security Lights Years: 2007 Systems: Emergency Light/Exit Light Panel Years: 2002 Systems: Partial Molded Case Circuit Breaker Panel Board Years: 2002, 2009, 2013 Systems: Intrusion Alarm System Years: 2001 Systems: Gymnasium (LED Lighting), Most Emergency Lighting (Battery Pack) Years: 2018
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	Yes
Water Penetration In Electrical Room?	No

DEDICATED INTERCOMS IN FIRE RESCUE AREAS

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	No

Priority Condition

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image
No	Fire Alarm System - Defective	N/A	Fire Alarm System	Main Entrance Lobby	Michael Ahrens	Custodian	No Photo Taken

Inspection

Question	Response
Electrical	
ATHLETIC FIELD	Does not exist
AUDITORIUM	
Instance on 1st Floor	Inspected
House Lighting	
Instance on 1st Floor	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

R051

Question	Response
AUDITORIUM	
House Lighting	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - LED	
Instance on 1st Floor	Does not exist
Local Sound System	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Installation Year	2014
Source of Installation Year	Custodial Staff
Deficiency	No deficiencies recorded
Projection System	
Instance on 1st Floor	Does not exist
Theater Lighting System	
Instance on 1st Floor	Inspected
Dimming System	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	DIMMING RACK/LIGHT CONSOLE BEYOND USEFUL LIFE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Theater Lighting	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	100
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
AUXILIARY SIGNAL/BELL SYSTEM	
Condition	3- Fair
Deficiency	No deficiencies recorded
CAFETERIA	
Instance on Basement - Students	Inspected
Instance on Basement - Staff	Inspected
Lighting	

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

R051

Question	Response
CAFETERIA	
Lighting	
Instance on Basement - Students	Inspected
Instance on Basement - Staff	Inspected
Lighting Fixture - Fluorescent	
Instance on Basement - Students	Inspected
Instance on Basement - Staff	Inspected
Pendant Mounted	
Instance on Basement - Students	Does not exist
Instance on Basement - Staff	Does not exist
Recessed Mounted	
Instance on Basement - Students	Does not exist
Instance on Basement - Staff	Does not exist
Surface Mounted	
Instance on Basement - Students	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Basement - Staff	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Basement - Students	Does not exist
Instance on Basement - Staff	Does not exist
Lighting Fixture - Incandescent	
Instance on Basement - Students	Does not exist
Instance on Basement - Staff	Does not exist
Lighting Fixture - LED	
Instance on Basement - Students	Does not exist
Instance on Basement - Staff	Does not exist
Local Sound System	
Instance on Basement - Students	Inspected
Instance Condition	2- Between Good and Fair
Installation Year	2014
Source of Installation Year	Custodial Staff
Deficiency	No deficiencies recorded
Instance on Basement - Staff	Does not exist
Projection System	
Instance on Basement - Students	Does not exist
Instance on Basement - Staff	Does not exist
Theater Lighting System	
Instance on Basement - Students	Does not exist
Instance on Basement - Staff	Does not exist
CITY FIRE ALARM SYSTEM	
Condition	3- Fair
Deficiency	No deficiencies recorded
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
Lighting	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	
Pendant Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

R051

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
Lighting	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Deficiency	No deficiencies recorded
Surface Mounted	
Condition	Inspected
	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Does not exist
COMPUTER LAB	
Instance on Room B2	Inspected
Power Panel?	Yes
Lighting	
Instance on Room B2	Inspected
Lighting Fixture - Fluorescent	
Instance on Room B2	Inspected
Pendant Mounted	
Instance on Room B2	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room B2	Does not exist
Surface Mounted	
Instance on Room B2	Does not exist
Lighting Fixture - HID	
Instance on Room B2	Does not exist
Lighting Fixture - Incandescent	
Instance on Room B2	Does not exist
Lighting Fixture - LED	
Instance on Room B2	Does not exist
Raceway With Receptacles	
Instance on Room B2	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY DC STANDBY BATTERY POWER	Does not exist
EMERGENCY GENERATOR SET	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

R051

Question	Response
EMERGENCY LIGHTING	Inspected
Battery Pack	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT LIGHT	Inspected
Battery Pack	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
EXIT/EMERGENCY LIGHT	Does not exist
FIRE ALARM SYSTEM	Inspected
Area Smoke Detector	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Bell/Horn	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
CO Detector	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Duct Smoke Detector	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Elevator Recall	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Fan Shutdown Control	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Fire Alarm Digital Communicator	Does not exist
Fused Cutout Panel	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Heat Detector	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Magnetic Door Holder/Contactor	Does not exist
Main Panel	Inspected
Bell At Panel	Does not exist
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Main Entrance Lobby
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards System Technology
Model	EST3X
EquipmentId	Fire Alarm Control Panel
Capacity/Size Quantity	16

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

R051

Question	Response
FIRE ALARM SYSTEM	
Main Panel	
Fire Alarm Control Panel (Electronic)	
Capacity/Size UOM	Zones
Capacity/Size 2 Quantity	1
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Diagram
Installation Year	2014
Source of Installation Year	Documented
Deficiency	SYSTEM DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR SYSTEM
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	12065038X
Fire Alarm Control Panel (Standard)	Does not exist
Manual Pull Station	Inspected
Condition	1- Good
Deficiency	PULL STATION COVER IS MISSING
Deficiency Location/Instance	Boiler Room, 1st Floor Corridor By Room B35
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	INSTALL COVER
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
Remote Annunciator	Inspected
Display Monitor	Does not exist
Panel	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Printer	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Punch Register	Does not exist
Sprinkler Flow/Air Pressure Switch	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Strobe	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Sub-Panel	Does not exist
Tamper Flow Switch/Chain	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
GYMNASIUM	
Instance on 1st Floor	Inspected
Lighting	
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

R051

Question	Response
GYMNASIUM	
Lighting	
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - LED	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not exist
Recessed Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Local Sound System	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Installation Year	2014
Source of Installation Year	Custodial Staff
Deficiency	No deficiencies recorded
Projection System	
Instance on 1st Floor	Does not exist
Scoreboard	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Theater Lighting System	
Instance on 1st Floor	Does not exist
INTERCOM SYSTEM	
	Inspected
Elevator	
Condition	1- Good
Deficiency	No deficiencies recorded
Holding Area	
Condition	3- Fair
Deficiency	No deficiencies recorded
KITCHEN	
Instance on Basement	Inspected
Lighting	
Instance on Basement	Inspected
Lighting Fixture - Fluorescent	
Instance on Basement	Inspected
Pendant Mounted	
Instance on Basement	Does not exist
Recessed Mounted	
Instance on Basement	Does not exist
Surface Mounted	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Basement	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

R051

Question	Response
KITCHEN	
Lighting	
Lighting Fixture - Incandescent	
Instance on Basement	Does not exist
Lighting Fixture - LED	
Instance on Basement	Does not exist
LAN	
Local Distribution Frame (I/LDF)	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Main Equipment Rack (MDF)	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LIBRARY	
Instance on Room 212	Inspected
Lighting	
Instance on Room 212	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 212	Inspected
Pendant Mounted	
Instance on Room 212	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 212	Does not exist
Surface Mounted	
Instance on Room 212	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Room 212	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 212	Does not exist
Lighting Fixture - LED	
Instance on Room 212	Does not exist
Projection System	
Instance on Room 212	Does not exist
Raceway With Receptacles	
Instance on Room 212	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
LIGHTNING PROTECTION	
Does not exist	
LOCKER ROOM	
Instance on Basement - Boys	Inspected
Alternative Use	Yes
Lighting	
Instance on Basement - Boys	Inspected
Lighting Fixture - Fluorescent	
Instance on Basement - Boys	Inspected
Pendant Mounted	
Instance on Basement - Boys	Does not exist
Recessed Mounted	
Instance on Basement - Boys	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

R051

Question	Response
LOCKER ROOM	
Lighting	
Lighting Fixture - Fluorescent	
Surface Mounted	
Instance on Basement - Boys	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Basement - Boys	Does not exist
Lighting Fixture - Incandescent	
Instance on Basement - Boys	Does not exist
Lighting Fixture - LED	
Instance on Basement - Boys	Does not exist
MOTOR CONTROL CENTER	Does not exist
MOTOR STARTER/CONTACTOR	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
MULTIPURPOSE ROOM	Does not exist
PANEL BOARD	Inspected
Fused Disconnect Switch Type	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Fused Knife Switch Type	Does not exist
Fused Toggle Switch Type	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Molded Case Circuit Breaker Type	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Corridors, Mechanical Room 247, Mechanical Room B45, Kitchen, Auditorium, Boiler Room
Deficiency Quantity	20
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	NO SPARE
Deficiency Location/Instance	2nd Floor Corridor By Room 205, 1st Floor Corridor By Room 123, Kitchen, Gymnasium
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE PANEL BOARD
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	PANEL BOARD DIRECTORY MISSING OR REQUIRES UPDATING

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

R051

Question	Response
PANEL BOARD	
Molded Case Circuit Breaker Type	
Deficiency Location/Instance	B43
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
PUBLIC ADDRESS SYSTEM	
	Inspected
Instance	General Office - Room 131
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Dukane 250
Installation Year	2014
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	
Instance on Rooms 113, 115	Inspected
Power Panel?	No
Alternative Use	Yes
Instance on Rooms 109, 209, 213, 219	Inspected
Power Panel?	No
Alternative Use	Yes
Emergency Gas Shut-Off Valve	
Instance on Rooms 113, 115	Does not exist
Instance on Rooms 109, 209, 213, 219	Does not exist
Emergency Shut-Off Power	
Instance on Rooms 113, 115	Does not exist
Instance on Rooms 109, 209, 213, 219	Does not exist
Lighting	
Instance on Rooms 113, 115	Inspected
Instance on Rooms 109, 209, 213, 219	Inspected
Lighting Fixture - Fluorescent	
Instance on Rooms 113, 115	Inspected
Instance on Rooms 109, 209, 213, 219	Inspected
Pendant Mounted	
Instance on Rooms 113, 115	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Rooms 109, 209, 213, 219	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Rooms 113, 115	Does not exist
Instance on Rooms 109, 209, 213, 219	Does not exist
Surface Mounted	
Instance on Rooms 113, 115	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Rooms 109, 209, 213, 219	Does not exist
Lighting Fixture - HID	
Instance on Rooms 113, 115	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

R051

Question	Response
SCIENCE DEMO ROOM	
Lighting	
Lighting Fixture - HID	
Instance on Rooms 109, 209, 213, 219	Does not exist
Lighting Fixture - Incandescent	
Instance on Rooms 113, 115	Does not exist
Instance on Rooms 109, 209, 213, 219	Does not exist
Lighting Fixture - LED	
Instance on Rooms 113, 115	Does not exist
Instance on Rooms 109, 209, 213, 219	Does not exist
Power Supply	
Instance on Rooms 113, 115	Does not exist
Instance on Rooms 109, 209, 213, 219	Does not exist
Projection System	
Instance on Rooms 113, 115	Does not exist
Instance on Rooms 109, 209, 213, 219	Does not exist
SCIENCE LAB	
Instance on Rooms 105, 203, 205, 215	Inspected
Power Panel?	No
Alternative Use	Yes
Emergency Gas Shut-Off Valve	
Instance on Rooms 105, 203, 205, 215	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Emergency Shut-Off Power	
Instance on Rooms 105, 203, 205, 215	Does not exist
Lighting	
Instance on Rooms 105, 203, 205, 215	Inspected
Lighting Fixture - Fluorescent	
Instance on Rooms 105, 203, 205, 215	Inspected
Pendant Mounted	
Instance on Rooms 105, 203, 205, 215	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Rooms 105, 203, 205, 215	Does not exist
Surface Mounted	
Instance on Rooms 105, 203, 205, 215	Does not exist
Lighting Fixture - HID	
Instance on Rooms 105, 203, 205, 215	Does not exist
Lighting Fixture - Incandescent	
Instance on Rooms 105, 203, 205, 215	Does not exist
Lighting Fixture - LED	
Instance on Rooms 105, 203, 205, 215	Does not exist
Power Supply	
Instance on Rooms 105, 203, 205, 215	Does not exist
Projection System	
Instance on Rooms 105, 203, 205, 215	Does not exist
SCIENCE PREP ROOM	
Instance on Rooms 111, 211	Inspected
Power Panel?	No
Alternative Use	Yes
Emergency Gas Shut-Off Valve	

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

R051

Question	Response
SCIENCE PREP ROOM	
Emergency Gas Shut-Off Valve	
Instance on Rooms 111, 211	Does not exist
Emergency Shut-Off Power	
Instance on Rooms 111, 211	Does not exist
Lighting	
Instance on Rooms 111, 211	Inspected
Lighting Fixture - Fluorescent	
Instance on Rooms 111, 211	Inspected
Pendant Mounted	
Instance on Rooms 111, 211	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Rooms 111, 211	Does not exist
Surface Mounted	
Instance on Rooms 111, 211	Does not exist
Lighting Fixture - HID	
Instance on Rooms 111, 211	Does not exist
Lighting Fixture - Incandescent	
Instance on Rooms 111, 211	Does not exist
Lighting Fixture - LED	
Instance on Rooms 111, 211	Does not exist
Power Supply	
Instance on Rooms 111, 211	Does not exist
SECURITY	Inspected
Intrusion Alarm System	Inspected
Central Control Panel	Inspected
Instance	Custodian's Office - Room 133
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista - 50P
Installation Year	2001
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Infrared Sensor	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Panic Switch	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Remote Annunciator	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Siren/Strobe	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Ultrasonic Sensor	Does not exist
IPDVS/CCTV System	Inspected
Condition	2- Between Good and Fair
Installation Year	2007
Source of Installation Year	Custodial Staff
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

R051

Question	Response
SECURITY	
Lighting - Security	Inspected
Condition	2- Between Good and Fair
Replacement Quantity	17
Replacement Uom	EACH
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Location/Instance	Roof
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 3
Violations	No violations recorded
SERVICE SWITCH	Inspected
Instance	Electrical Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Pringle
EquipmentId	SECT A
Capacity/Size Quantity	1200
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1960
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Pringle
EquipmentId	SECT B
Capacity/Size Quantity	1200
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1960
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
SWIMMING POOL	Does not exist
SWITCHBOARD	Inspected
Number of Spares	1
Air Circuit Breaker Type	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

R051

Question	Response
SWITCHBOARD	
Fused Disconnect Switch Type	Does not exist
Fused Knife Switch Type	Does not exist
Molded Case Circuit Breaker Type	Inspected
Instance	Electrical Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	N/A
EquipmentId	SECT A
Capacity/Size Quantity	1200
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	1
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Service Switch Size
Installation Year	1960
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	N/A
EquipmentId	SECT B
Capacity/Size Quantity	1200
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	1
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Service Switch Size
Installation Year	1960
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
TELEPHONE SYSTEM	Inspected
PBX/Intercom	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Standard	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
TOILET ROOM - STAFF	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

R051

Question	Response
TOILET ROOM - STAFF	
Lighting	
Lighting Fixture - Fluorescent	
Pendant Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Does not exist
TOILET ROOM - STUDENT	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Does not exist
TRANSFORMER	Does not exist
TV SYSTEM	Inspected
Cable System Exist?	Yes
Operational?	Yes
Main Equipment Rack	Does not exist