

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

X110

School: **P.S. 110 - BRONX, 580 CROTONA PARK SOUTH, BRONX, NY, 10456**

InspectionId	Inspection Type	Time In	Last Edited
1665	ELECTRICAL	2019-01-22 08:29AM	2019-01-22 03:17PM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Partial Emergency Lighting (Battery Pack) Years: 2018 Systems: Intrusion Alarm System Years: 2001 Systems: LAN Years: 2010 Systems: Library, Science Lab Room 331, Auditorium (Theater Lighting System) Years: 2009 Systems: Emergency Light/Exit Light Panel Years: 1995 Systems: Public Address System, Local Sound System Years: 2003 Systems: Lighting - Security, Gymnasium (HID Lighting) Years: 2006 Systems: Interior Fluorescent Lighting (Except Library, Science Lab Room 331), Exit Lights (Battery Pack), Computer Lab Room 326 Years: 2012 Systems: Fire Alarm System Years: 2004 Systems: Partial Molded Case Circuit Breaker Panel Board Years: 1995, 2006 Below Ground
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	Yes
Water Penetration In Electrical Room?	No

DEDICATED INTERCOMS IN FIRE RESCUE AREAS

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	No

Priority Condition

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image	
No		No condition recorded						

Inspection

Question	Response
Electrical	
ATHLETIC FIELD	Does not exist
AUDITORIUM	
Instance on Ground Floor - Lower Level	Inspected
House Lighting	
Instance on Ground Floor - Lower Level	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	
Instance on Ground Floor - Lower Level	Inspected
Pendant Mounted	
Instance on Ground Floor - Lower Level	Does not exist
Recessed Mounted	
Instance on Ground Floor - Lower Level	Inspected
Instance Condition	2- Between Good and Fair

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

X110

Question	Response
AUDITORIUM	
House Lighting	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Ground Floor - Lower Level	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Ground Floor - Lower Level	Does not exist
Lighting Fixture - Incandescent	
Instance on Ground Floor - Lower Level	Does not exist
Lighting Fixture - LED	
Instance on Ground Floor - Lower Level	Does not exist
Local Sound System	
Instance on Ground Floor - Lower Level	Inspected
Instance Condition	3- Fair
Installation Year	2003
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Projection System	
Instance on Ground Floor - Lower Level	Does not exist
Theater Lighting System	
Instance on Ground Floor - Lower Level	Inspected
Dimming System	
Instance on Ground Floor - Lower Level	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Theater Lighting	
Instance on Ground Floor - Lower Level	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
AUXILIARY SIGNAL/BELL SYSTEM	
Condition	3- Fair
Deficiency	No deficiencies recorded
CAFETERIA	
Instance on Ground Floor - Upper Level	Inspected
Lighting	
Instance on Ground Floor - Upper Level	Inspected
Lighting Fixture - Fluorescent	
Instance on Ground Floor - Upper Level	Inspected
Pendant Mounted	
Instance on Ground Floor - Upper Level	Does not exist
Recessed Mounted	
Instance on Ground Floor - Upper Level	Does not exist
Surface Mounted	
Instance on Ground Floor - Upper Level	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Ground Floor - Upper Level	Does not exist
Lighting Fixture - Incandescent	

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

X110

Question	Response
CAFETERIA	
Lighting	
Lighting Fixture - Incandescent	
Instance on Ground Floor - Upper Level	Does not exist
Lighting Fixture - LED	
Instance on Ground Floor - Upper Level	Does not exist
Local Sound System	
Instance on Ground Floor - Upper Level	Inspected
Instance Condition	3- Fair
Installation Year	2003
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Projection System	
Instance on Ground Floor - Upper Level	Does not exist
Theater Lighting System	
Instance on Ground Floor - Upper Level	Does not exist
CITY FIRE ALARM SYSTEM	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
Lighting	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Does not exist
COMPUTER LAB	
Instance on Room 326	Inspected
Power Panel?	Yes
Lighting	
Instance on Room 326	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 326	Inspected
Pendant Mounted	
Instance on Room 326	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 326	Does not exist
Surface Mounted	
Instance on Room 326	Does not exist
Lighting Fixture - HID	
Instance on Room 326	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 326	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

X110

Question	Response
COMPUTER LAB	
Lighting	
Lighting Fixture - LED	
Instance on Room 326	Does not exist
Raceway With Receptacles	
Instance on Room 326	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
EMERGENCY DC STANDBY BATTERY POWER	Does not exist
EMERGENCY GENERATOR SET	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Inspected
Condition	3- Fair
Deficiency	LESS THAN 20% SPARE CIRCUIT BREAKERS
Deficiency Location/Instance	Electrical Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL NEW PANEL BOARD
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
EMERGENCY LIGHTING	Inspected
Battery Pack	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT LIGHT	Inspected
Battery Pack	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Does not exist
EXIT/EMERGENCY LIGHT	Does not exist
FIRE ALARM SYSTEM	Inspected
Area Smoke Detector	Does not exist
Bell/Horn	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
CO Detector	Does not exist
Duct Smoke Detector	Does not exist
Elevator Recall	Does not exist
Fan Shutdown Control	Does not exist
Fire Alarm Digital Communicator	Does not exist
Fused Cutout Panel	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Heat Detector	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Magnetic Door Holder/Contactor	Does not exist
Main Panel	Inspected
Bell At Panel	Inspected
Condition	2- Between Good and Fair

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

X110

Question	Response
FIRE ALARM SYSTEM	
Main Panel	
Bell At Panel	
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	
Instance	Main Entrance Lobby
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards System Technology
Model	EST 2
EquipmentId	Fire Alarm Control Panel
Capacity/Size Quantity	16
Capacity/Size UOM	Zones
Capacity/Size 2 Quantity	1
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Diagram
Installation Year	2004
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	
Does not exist	
Manual Pull Station	
Inspected	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Remote Annunciator	
Inspected	
Display Monitor	
Does not exist	
Panel	
Inspected	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Printer	
Inspected	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Punch Register	
Does not exist	
Sprinkler Flow/Air Pressure Switch	
Inspected	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Strobe	
Inspected	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Sub-Panel	
Does not exist	
Tamper Flow Switch/Chain	
Inspected	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	
Inspected	
Condition	3- Fair
Deficiency	No deficiencies recorded
GYMNASIUM	
Instance on 1st Floor	
Inspected	
Lighting	
Instance on 1st Floor	
Inspected	
Lighting Fixture - Fluorescent	
Instance on 1st Floor	
Does not exist	
Lighting Fixture - HID	
Instance on 1st Floor	
Inspected	

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

X110

Question	Response
GYMNASIUM	
Lighting	
Lighting Fixture - HID	
Pendant Mounted	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - LED	
Instance on 1st Floor	Does not exist
Local Sound System	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Installation Year	2003
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Projection System	
Instance on 1st Floor	Does not exist
Scoreboard	
Instance on 1st Floor	Does not exist
Theater Lighting System	
Instance on 1st Floor	Does not exist
INTERCOM SYSTEM	
Does not exist	
KITCHEN	
Instance on Ground Floor - Upper Level	Inspected
Lighting	
Instance on Ground Floor - Upper Level	Inspected
Lighting Fixture - Fluorescent	
Instance on Ground Floor - Upper Level	Inspected
Pendant Mounted	
Instance on Ground Floor - Upper Level	Does not exist
Recessed Mounted	
Instance on Ground Floor - Upper Level	Does not exist
Surface Mounted	
Instance on Ground Floor - Upper Level	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Ground Floor - Upper Level	Does not exist
Lighting Fixture - Incandescent	
Instance on Ground Floor - Upper Level	Does not exist
Lighting Fixture - LED	
Instance on Ground Floor - Upper Level	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

X110

Question	Response
LAN	Inspected
Local Distribution Frame (L/DF)	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Main Equipment Rack (MDF)	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LIBRARY	
Instance on Room 202	Inspected
Lighting	
Instance on Room 202	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 202	Inspected
Pendant Mounted	
Instance on Room 202	Does not exist
Recessed Mounted	
Instance on Room 202	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Room 202	Does not exist
Lighting Fixture - HID	
Instance on Room 202	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 202	Does not exist
Lighting Fixture - LED	
Instance on Room 202	Does not exist
Projection System	
Instance on Room 202	Does not exist
Raceway With Receptacles	
Instance on Room 202	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LIGHTNING PROTECTION	Does not exist
LOCKER ROOM	Does not exist
MOTOR CONTROL CENTER	Does not exist
MOTOR STARTER/CONTACTOR	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
MULTIPURPOSE ROOM	Does not exist
PANEL BOARD	Inspected
Fused Disconnect Switch Type	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	2nd Floor Fan Room, Boiler Room
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Fused Knife Switch Type	Does not exist
Fused Toggle Switch Type	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

X110

Question	Response
PANEL BOARD	
Fused Toggle Switch Type	
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Molded Case Circuit Breaker Type	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD DIRECTORY MISSING OR REQUIRES UPDATING
Deficiency Location/Instance	Rooms 327, 227
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	NO SPARE
Deficiency Location/Instance	Corridors by Rooms (112, G30, G112)
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE PANEL BOARD
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	PANEL BOARD DOOR LOCK IS MISSING
Deficiency Location/Instance	Kitchen
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Kitchen, Corridors
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
PUBLIC ADDRESS SYSTEM	Inspected
Instance	General Office - Room 112
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Dukane 250
Installation Year	2003
Source of Installation Year	Documented
Deficiency	SPEAKER NOT OPERATIONAL
Deficiency Location/Instance	Kitchen, Room 331

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

X110

Question	Response
PUBLIC ADDRESS SYSTEM	
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
SCIENCE DEMO ROOM	
	Does not exist
SCIENCE LAB	
Instance on Room 331	Inspected
Power Panel?	No
Alternative Use	No
Emergency Gas Shut-Off Valve	
Instance on Room 331	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Emergency Shut-Off Power	
Instance on Room 331	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting	
Instance on Room 331	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 331	Inspected
Pendant Mounted	
Instance on Room 331	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 331	Does not exist
Surface Mounted	
Instance on Room 331	Does not exist
Lighting Fixture - HID	
Instance on Room 331	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 331	Inspected
Pendant Mounted	
Instance on Room 331	Does not exist
Recessed Mounted	
Instance on Room 331	Does not exist
Surface Mounted	
Instance on Room 331	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - LED	
Instance on Room 331	Does not exist
Power Supply	
Instance on Room 331	Inspected
Instructor Unit	
Instance on Room 331	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Meter Demonstration Unit	

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

X110

Question	Response
SCIENCE LAB	
Power Supply	
Meter Demonstration Unit	
Instance on Room 331	Does not exist
Student Unit	
Instance on Room 331	Does not exist
Projection System	
Instance on Room 331	Does not exist
SCIENCE PREP ROOM	
	Does not exist
SECURITY	
	Inspected
Intrusion Alarm System	Inspected
Central Control Panel	Inspected
Instance	Custodian's Office - Room 103
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista - 128B
Installation Year	2001
Source of Installation Year	Documented
Deficiency	PANEL NOT CONNECTED TO DOE CENTRAL STATION
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REWIRE
Urgency of Action	PRIORITY 4
Purpose of Action	LEVEL 3
Violations	No violations recorded
Infrared Sensor	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Panic Switch	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Remote Annunciator	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Siren/Strobe	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Ultrasonic Sensor	Does not exist
IPDVS/CCTV System	Does not exist
Lighting - Security	Inspected
Condition	2- Between Good and Fair
Replacement Quantity	23
Replacement Uom	EACH
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Location/Instance	Roof
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 3
Violations	No violations recorded
SERVICE SWITCH	Inspected
Instance	Ground Floor Electrical Room

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

X110

Question	Response
SERVICE SWITCH	
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Royal Switchboard Co.
EquipmentId	Main Switch
Capacity/Size Quantity	2000
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1964
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Ground Floor Electrical Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
SWIMMING POOL	Does not exist
SWITCHBOARD	Inspected
Number of Spares	1
Air Circuit Breaker Type	Does not exist
Fused Disconnect Switch Type	Inspected
Instance	Ground Electrical Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Royal Switchboard Co.
EquipmentId	Main Distribution Panel
Capacity/Size Quantity	2000
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	2
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Service Switch Size
Installation Year	1964
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Ground Electrical Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Fused Knife Switch Type	Does not exist
Molded Case Circuit Breaker Type	Does not exist
TELEPHONE SYSTEM	Inspected
PBX/Intercom	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Standard	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
TOILET ROOM - STAFF	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

X110

Question	Response
TOILET ROOM - STAFF	
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Does not exist
TOILET ROOM - STUDENT	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - LED	Does not exist
TRANSFORMER	Does not exist
TV SYSTEM	Inspected
Cable System Exist?	Yes
Operational?	Yes
Main Equipment Rack	Does not exist