

NYC Department of Education
Building Condition Assessment Survey 2017 - 2018

Electrical Inspection

X451

Asset: STEVENSON AF - BRONX, 1980 LAFAYETTE AVENUE, New York, 10473

Inspection Id	Inspection Type	Time In	Last Edited
EE : X451	Electrical	2017-11-20 8:54 AM	2017-12-29 6:39 PM

Asset Data

Question	Answer
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	No
Water Penetration in Electrical Room?	No
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Interior Fluorescent Lighting (Except Toilet Rooms)
	Years: 2002

DEDICATED INTERCOMS IN FIRE RESCUE AREAS

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	No

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
No condition recorded								

Inspection

Question	Response
Electrical	
ATHLETIC FIELD	Inspected
Exterior Lighting	Does not Exist
Local Sound System	Does not Exist
Scoreboard	Inspected
Instance	East Side
Instance Condition	5 - Poor
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	Inspected
Lighting	Inspected
Does a Chandelier exist?	No
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not Exist
Surface Mounted	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not Exist
Lighting Fixture - HID	Does not Exist
Lighting Fixture - Incandescent	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2017 - 2018**

Electrical Inspection

X451

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
Lighting	
Lighting Fixture - Incandescent	
Pendant Mounted	Does not Exist
Surface Mounted	Inspected
Condition	3 - Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Recessed Mounted	Does not Exist
Lighting Fixture - LED	Does not Exist
LOCKER ROOM	Does not Exist
TOILET ROOM - STAFF	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not Exist
Surface Mounted	Inspected
Condition	3 - Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Recessed Mounted	Does not Exist
Lighting Fixture - Incandescent	Does not Exist
Lighting Fixture - LED	Does not Exist
TOILET ROOM - STUDENT	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not Exist
Surface Mounted	Inspected
Condition	3 - Fair

**NYC Department of Education
Building Condition Assessment Survey 2017 - 2018**

Electrical Inspection

X451

Question	Response
TOILET ROOM - STUDENT	
Lighting	
Lighting Fixture - Fluorescent	
Surface Mounted	
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Recessed Mounted	Does not Exist
Lighting Fixture - Incandescent	Does not Exist
Lighting Fixture - LED	Does not Exist
AUXILIARY SIGNAL/BELL SYSTEM	Does not Exist
EMERGENCY DC STANDBY BATTERY POWER	Does not Exist
EMERGENCY GENERATOR SET	Does not Exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Does not Exist
EMERGENCY LIGHTING	Does not Exist
EXIT LIGHT	Does not Exist
EXIT/EMERGENCY LIGHT	Does not Exist
FIRE ALARM SYSTEM	Does not Exist
GROUNDING SYSTEM	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
LAN	Does not Exist
MOTOR CONTROL CENTER	Does not Exist
MOTOR STARTER/CONTACTOR	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
PANEL BOARD	Inspected
Fused Disconnect Switch Type	Does not Exist
Fused Knife Switch Type	Does not Exist
Fused Toggle Switch Type	Does not Exist
Molded Case Circuit Breaker Type	Inspected
Condition	3 - Fair
Deficiency	PANEL BOARD COVER IS MISSING
Deficiency Location/Instance	Field House
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	PANEL BOARD DIRECTORY MISSING OR REQUIRES UPDATING
Deficiency Location/Instance	Field House

NYC Department of Education
Building Condition Assessment Survey 2017 - 2018

Electrical Inspection

X451

Question	Response
PANEL BOARD	
Molded Case Circuit Breaker Type	
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Field House
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
PUBLIC ADDRESS SYSTEM	Does not Exist
SECURITY	Does not Exist
SERVICE SWITCH	Inspected
Instance	Field House
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Federal Pacific Electric
Equipment	N/A
Capacity/Size Quantity	400
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1970
Source of Installation	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Field House
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
SWITCHBOARD	Does not Exist
TELEPHONE SYSTEM	Does not Exist
TRANSFORMER	Does not Exist
TV SYSTEM	Does not Exist