

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

X853

School: P.S. 59 ANNEX - BRONX, 2120 QUARRY RD, BRONX, NY, 10457

InspectionId	Inspection Type	Time In	Last Edited
4820	ELECTRICAL	2019-05-16 11:00AM	2019-05-20 10:26AM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Interior Lighting, Emergency/Exit Light Panel, Molded Case Circuit Breaker Panel Board, Fused Disconnect Switch Type Panel Board, Fire Alarm System, Switchboard Years: 2007 Systems: Most Security Lights Years: 2005 Systems: Intrusion Alarm System Years: 2003
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	Yes
Water Penetration In Electrical Room?	No

DEDICATED INTERCOMS IN FIRE RESCUE AREAS

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	No

Priority Condition

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image	
No		No condition recorded						

Inspection

Question	Response
Electrical	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Does not exist
AUXILIARY SIGNAL/BELL SYSTEM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
CAFETERIA	
Instance on 1st Floor	Inspected
Lighting	
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - LED	

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

X853

Question	Response
CAFETERIA	
Lighting	
Lighting Fixture - LED	
Instance on 1st Floor	Does not exist
Local Sound System	
Instance on 1st Floor	Does not exist
Projection System	
Instance on 1st Floor	Does not exist
Theater Lighting System	
Instance on 1st Floor	Does not exist
CITY FIRE ALARM SYSTEM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	Inspected
Lighting	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Does not exist
COMPUTER LAB	Does not exist
EMERGENCY DC STANDBY BATTERY POWER	Does not exist
EMERGENCY GENERATOR SET	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
EMERGENCY LIGHTING	Inspected
Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT LIGHT	Inspected
Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT/EMERGENCY LIGHT	Does not exist
FIRE ALARM SYSTEM	Inspected
Area Smoke Detector	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Bell/Horn	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

X853

Question	Response
FIRE ALARM SYSTEM	
Bell/Horn	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
CO Detector	Does not exist
Duct Smoke Detector	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Elevator Recall	Does not exist
Fan Shutdown Control	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Fire Alarm Digital Communicator	Does not exist
Fused Cutout Panel	Inaccessible
Heat Detector	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Magnetic Door Holder/Contactor	Does not exist
Main Panel	Inspected
Bell At Panel	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Main Entrance Lobby
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards System Technology
Model	EST 2
EquipmentId	Fire Alarm Control Panel
Capacity/Size Quantity	8
Capacity/Size UOM	Zones
Capacity/Size 2 Quantity	1
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Inspector Estimate
Installation Year	2007
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	Does not exist
Manual Pull Station	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Remote Annunciator	Inspected
Display Monitor	Does not exist
Panel	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Printer	Inspected
Condition	5- Poor
Deficiency	PRINTER NOT OPERATIONAL
Deficiency Location/Instance	Custodian's Office
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

X853

Question	Response
FIRE ALARM SYSTEM	
Remote Annunciator	
Printer	
Purpose of Action	LEVEL 2
Violations	No violations recorded
Punch Register	Does not exist
Sprinkler Flow/Air Pressure Switch	Does not exist
Strobe	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Sub-Panel	Does not exist
Tamper Flow Switch/Chain	Does not exist
GROUNDING SYSTEM	Inaccessible
GYMNASIUM	Does not exist
INTERCOM SYSTEM	Does not exist
KITCHEN	
Instance on 1st Floor	Inspected
Lighting	
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not exist
Recessed Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - LED	
Instance on 1st Floor	Does not exist
LAN	Inspected
Local Distribution Frame (I/LDF)	Does not exist
Main Equipment Rack (MDF)	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
LIBRARY	Does not exist
LIGHTNING PROTECTION	Does not exist
LOCKER ROOM	Does not exist
MOTOR CONTROL CENTER	Does not exist
MOTOR STARTER/CONTACTOR	Does not exist
MULTIPURPOSE ROOM	Does not exist
PANEL BOARD	Inspected
Fused Disconnect Switch Type	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Fused Knife Switch Type	Does not exist
Fused Toggle Switch Type	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

X853

Question	Response
PANEL BOARD	
Molded Case Circuit Breaker Type	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
PUBLIC ADDRESS SYSTEM	Does not exist
SCIENCE DEMO ROOM	Does not exist
SCIENCE LAB	Does not exist
SCIENCE PREP ROOM	Does not exist
SECURITY	Inspected
Intrusion Alarm System	Inspected
Central Control Panel	Inspected
Instance	Room H
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista - 128B
Installation Year	2003
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Infrared Sensor	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Panic Switch	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Remote Annunciator	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Siren/Strobe	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Ultrasonic Sensor	Does not exist
IPDVS/CCTV System	Does not exist
Lighting - Security	Inspected
Condition	2- Between Good and Fair
Replacement Quantity	11
Replacement Uom	EACH
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Location/Instance	Wall facing Playground
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 3
Violations	No violations recorded
SERVICE SWITCH	Inaccessible
SWIMMING POOL	Does not exist
SWITCHBOARD	Inspected
Number of Spares	4
Air Circuit Breaker Type	Does not exist
Fused Disconnect Switch Type	Inspected
Instance	Electrical Room E
Instance Condition	2- Between Good and Fair

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

X853

Question	Response
SWITCHBOARD	
Fused Disconnect Switch Type	
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	All City Switchboard
EquipmentId	N/A
Capacity/Size Quantity	1000
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	2
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Inspector Estimate
Installation Year	2007
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fused Knife Switch Type	Does not exist
Molded Case Circuit Breaker Type	Does not exist
TELEPHONE SYSTEM	Inspected
PBX/Intercom	Does not exist
Standard	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
TOILET ROOM - STAFF	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Does not exist
TOILET ROOM - STUDENT	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Does not exist
TRANSFORMER	Does not exist
TV SYSTEM	Inspected
Cable System Exist?	Yes
Operational?	Yes
Main Equipment Rack	Does not exist