

**NYC Department of Education**  
**Building Condition Assessment Survey 2017 - 2018**

Electrical Inspection

X862

**Asset: P.S. 63 MINISCHOOL - BRONX, 1260 FRANKLIN AVENUE, New York, 10456**

Inspection Id	Inspection Type	Time In	Last Edited
EE : X862	Electrical	2017-10-03 7:43 AM	2017-10-10 10:42 AM

Asset Data

Question	Answer
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	Yes
Water Penetration in Electrical Room?	No
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Interior Fluorescent Lighting
	Years: 2014
	Systems: Partial Molded Case Circuit Breaker Panel Board, Telephone System, LAN
	Years: 2012
	Systems: Public Address System
	Years: 2002
	Systems: Fire Alarm System, Service Switch
	Years: 1998
	Systems: Intrusion Alarm System
	Years: 1996
	Systems: Security Lights
	Years: 1992

**DEDICATED INTERCOMS IN FIRE RESCUE AREAS**

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	No

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
No condition recorded								

Inspection

Question	Response
<b>Electrical</b>	
<b>AUDITORIUM</b>	Does not Exist
<b>CAFETERIA</b>	Does not Exist
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	Inspected
<b>Lighting</b>	Inspected
Does a Chandelier exist?	No
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Does not Exist
<b>Lighting Fixture - HID</b>	Does not Exist
<b>Lighting Fixture - Incandescent</b>	Does not Exist
<b>Lighting Fixture - LED</b>	Does not Exist
<b>COMPUTER LAB</b>	Does not Exist

**NYC Department of Education  
Building Condition Assessment Survey 2017 - 2018**

Electrical Inspection

X862

<b>Question</b>	<b>Response</b>
<b>GYMNASIUM</b>	Does not Exist
<b>KITCHEN</b>	Does not Exist
<b>LIBRARY</b>	Does not Exist
<b>LOCKER ROOM</b>	Does not Exist
<b>MULTIPURPOSE ROOM</b>	Does not Exist
<b>SCIENCE DEMO ROOM</b>	Does not Exist
<b>SCIENCE LAB</b>	Does not Exist
<b>SCIENCE PREP ROOM</b>	Does not Exist
<b>SWIMMING POOL</b>	Does not Exist
<b>TOILET ROOM - STAFF</b>	Inspected
<b>Lighting</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Does not Exist
<b>Surface Mounted</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Does not Exist
<b>Lighting Fixture - HID</b>	Does not Exist
<b>Lighting Fixture - Incandescent</b>	Does not Exist
<b>Lighting Fixture - LED</b>	Does not Exist
<b>TOILET ROOM - STUDENT</b>	Inspected
<b>Lighting</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Does not Exist
<b>Surface Mounted</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Does not Exist
<b>Lighting Fixture - HID</b>	Does not Exist
<b>Lighting Fixture - Incandescent</b>	Does not Exist
<b>Lighting Fixture - LED</b>	Does not Exist
<b>AUXILIARY SIGNAL/BELL SYSTEM</b>	Does not Exist
<b>EMERGENCY DC STANDBY BATTERY POWER</b>	Does not Exist
<b>EMERGENCY GENERATOR SET</b>	Does not Exist
<b>EMERGENCY LIGHT/EXIT LIGHT PANEL</b>	Does not Exist
<b>EMERGENCY LIGHTING</b>	Inspected
<b>Battery Pack</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Non Battery Pack</b>	Does not Exist
<b>EXIT LIGHT</b>	Inspected
<b>Battery Pack</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Non Battery Pack</b>	Does not Exist
<b>EXIT/EMERGENCY LIGHT</b>	Does not Exist
<b>CITY FIRE ALARM SYSTEM</b>	Does not Exist

**NYC Department of Education  
Building Condition Assessment Survey 2017 - 2018**

Electrical Inspection

X862

<b>Question</b>	<b>Response</b>
<b>FIRE ALARM SYSTEM</b>	Inspected
Replacement Quantity	8,000
Replacement Uom	S.F.
<b>Bell/Horn</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Strobe</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Manual Pull Station</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Fan Shutdown Control</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Duct Smoke Detector</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Area Smoke Detector</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>CO Detector</b>	Does not Exist
<b>Heat Detector</b>	Does not Exist
<b>Elevator Recall</b>	Does not Exist
<b>Magnetic Door Holder/Contactor</b>	Does not Exist
<b>Fused Cutout Panel</b>	Does not Exist
<b>Fire Alarm Digital Communicator</b>	Does not Exist
<b>Main Panel</b>	Does not Exist
<b>Sub-Panel</b>	Does not Exist
<b>Remote Annunciator</b>	Does not Exist
<b>Sprinkler Flow/Air Pressure Switch</b>	Does not Exist
<b>Tamper Flow Switch/Chain</b>	Does not Exist
<b>GROUNDING SYSTEM</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>INTERCOM SYSTEM</b>	Does not Exist
<b>LAN</b>	Inspected
<b>Local Distribution Frame (I/LDF)</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Main Equipment Rack (MDF)</b>	Does not Exist
<b>LIGHTNING PROTECTION</b>	Does not Exist
<b>MOTOR CONTROL CENTER</b>	Does not Exist
<b>MOTOR STARTER/CONTACTOR</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>PANEL BOARD</b>	Inspected
<b>Fused Disconnect Switch Type</b>	Does not Exist
<b>Fused Knife Switch Type</b>	Does not Exist

**NYC Department of Education  
Building Condition Assessment Survey 2017 - 2018**

Electrical Inspection

X862

<b>Question</b>	<b>Response</b>
<b>PANEL BOARD</b>	
<b>Fused Toggle Switch Type</b>	Does not Exist
<b>Molded Case Circuit Breaker Type</b>	Inspected
Condition	3 - Fair
<b>PUBLIC ADDRESS SYSTEM</b>	
	Inspected
Replacement Quantity	8,000
Replacement Uom	S.F.
Instance	Connected to Main Asset X063
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	N/A
Installation Year	2002
Source of Installation	Documented
Deficiency	CLOCK NOT OPERATIONAL
Deficiency Location/Instance	1st Floor Corridor - By Room 5
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>SECURITY</b>	
	Inspected
<b>IPDVS/CCTV System</b>	Does not Exist
<b>Intrusion Alarm System</b>	Inspected
Replacement Quantity	8,000
Replacement Uom	S.F.
<b>Central Control Panel</b>	Inspected
Instance	Mechanical Room
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista - 50P
Installation Year	1996
Source of Installation	Documented
Deficiency	PANEL NOT CONNECTED TO DOE CENTRAL STATION
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL CONNECTION
Urgency of Action	PRIORITY 4
Purpose of Action	LEVEL 3
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>Infrared Sensor</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded

**NYC Department of Education  
Building Condition Assessment Survey 2017 - 2018**

Electrical Inspection

X862

<b>Question</b>	<b>Response</b>
<b>SECURITY</b>	
<b>Intrusion Alarm System</b>	
<b>Panic Switch</b>	Does not Exist
<b>Remote Annunciator</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Siren/Stroke</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Ultrasonic Sensor</b>	Does not Exist
<b>Lighting - Security</b>	Inspected
Replacement Quantity	8
Replacement Uom	EACH
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>SERVICE SWITCH</b>	
Instance	Mechanical Room
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Siemens
Equipment	N/A
Capacity/Size Quantity	600
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1998
Source of Installation	Documented
Deficiency	No deficiencies recorded
<b>SWITCHBOARD</b>	
Does not Exist	
<b>TELEPHONE SYSTEM</b>	
Inspected	
<b>PBX/Intercom</b>	
Inspected	
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Standard</b>	
Inspected	
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>TRANSFORMER</b>	
Does not Exist	
<b>TV SYSTEM</b>	
Does not Exist	
Cable System Exist?	No