

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

X927

School: **P.S. 927 - BRONX, 1455 WEBSTER AVENUE, BRONX, NY, 10456**

InspectionId	Inspection Type	Time In	Last Edited
5066	ELECTRICAL	2019-05-24 12:36PM	2019-05-24 05:02PM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: All Electrical Systems and Components Years: 2013
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	Yes
Water Penetration In Electrical Room?	No

DEDICATED INTERCOMS IN FIRE RESCUE AREAS

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	No

Priority Condition

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image
No condition recorded							

Inspection

Question	Response
Electrical	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Does not exist
AUXILIARY SIGNAL/BELL SYSTEM	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
CAFETERIA	Does not exist
CITY FIRE ALARM SYSTEM	Does not exist
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	Inspected
Lighting	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Does not exist
COMPUTER LAB	Does not exist
EMERGENCY DC STANDBY BATTERY POWER	Does not exist
EMERGENCY GENERATOR SET	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Does not exist
EMERGENCY LIGHTING	Inspected
Battery Pack	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Does not exist
EXIT LIGHT	Inspected
Battery Pack	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

X927

Question	Response
EXIT LIGHT	
Battery Pack	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Does not exist
EXIT/EMERGENCY LIGHT	Does not exist
FIRE ALARM SYSTEM	Inspected
Area Smoke Detector	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Bell/Horn	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
CO Detector	Does not exist
Duct Smoke Detector	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Elevator Recall	Does not exist
Fan Shutdown Control	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Fire Alarm Digital Communicator	Inspected
Instance	Outside Room 3
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Silent Knight
EquipmentId	N/A
Capacity/Size Quantity	3
Capacity/Size UOM	Zones
Source of Capacity/Size	Inspector Estimate
Installation Year	2013
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fused Cutout Panel	Does not exist
Heat Detector	Does not exist
Magnetic Door Holder/Contactor	Does not exist
Main Panel	Inspected
Bell At Panel	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Outside Room 3
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Faraday
Model	MPC - 6000
EquipmentId	Fire Control Panel
Capacity/Size Quantity	6
Capacity/Size UOM	Zones
Capacity/Size 2 Quantity	1
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Inspector Estimate

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

X927

Question	Response
FIRE ALARM SYSTEM	
Main Panel	
Fire Alarm Control Panel (Electronic)	
Installation Year	2013
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	Does not exist
Manual Pull Station	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Remote Annunciator	Inspected
Display Monitor	Does not exist
Panel	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Printer	Does not exist
Punch Register	Does not exist
Sprinkler Flow/Air Pressure Switch	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Strobe	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Sub-Panel	Does not exist
Tamper Flow Switch/Chain	Does not exist
GROUNDING SYSTEM	Does not exist
GYMNASIUM	Does not exist
INTERCOM SYSTEM	Does not exist
KITCHEN	Does not exist
LAN	Inspected
Local Distribution Frame (I/LDF)	Does not exist
Main Equipment Rack (MDF)	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LIBRARY	Does not exist
LIGHTNING PROTECTION	Does not exist
LOCKER ROOM	Does not exist
MOTOR CONTROL CENTER	Does not exist
MOTOR STARTER/CONTACTOR	Does not exist
MULTIPURPOSE ROOM	
Instance on Room 7	Inspected
Lighting	
Instance on Room 7	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 7	Inspected
Pendant Mounted	
Instance on Room 7	Does not exist
Recessed Mounted	
Instance on Room 7	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Room 7	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

X927

Question	Response
MULTIPURPOSE ROOM	
Lighting	
Lighting Fixture - HID	
Instance on Room 7	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 7	Does not exist
Lighting Fixture - LED	
Instance on Room 7	Does not exist
Local Sound System	
Instance on Room 7	Does not exist
Projection System	
Instance on Room 7	Does not exist
Theater Lighting System	
Instance on Room 7	Does not exist
PANEL BOARD	Inspected
Fused Disconnect Switch Type	Does not exist
Fused Knife Switch Type	Does not exist
Fused Toggle Switch Type	Does not exist
Molded Case Circuit Breaker Type	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
PUBLIC ADDRESS SYSTEM	Does not exist
SCIENCE DEMO ROOM	Does not exist
SCIENCE LAB	Does not exist
SCIENCE PREP ROOM	Does not exist
SECURITY	Inspected
Intrusion Alarm System	Inspected
Central Control Panel	Inspected
Instance	MDF Room
Instance Condition	4- Between Fair and Poor
Instance Quantity	1
Instance Quantity Uom	EACH
Model	
Installation Year	2013
Source of Installation Year	Documented
Deficiency	PANEL NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 4
Purpose of Action	LEVEL 3
Violations	No violations recorded
Infrared Sensor	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Panic Switch	Does not exist
Remote Annunciator	Does not exist
Siren/Strobe	Does not exist
Ultrasonic Sensor	Does not exist
IPDVS/CCTV System	Inspected
Condition	2- Between Good and Fair
Installation Year	2013
Source of Installation Year	Documented
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2018-2019**

Electrical Inspection

X927

Question	Response
SECURITY	
Lighting - Security	Does not exist
SERVICE SWITCH	Does not exist
SWIMMING POOL	Does not exist
SWITCHBOARD	Does not exist
TELEPHONE SYSTEM	Inspected
PBX/Intercom	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Standard	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
TOILET ROOM - STAFF	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Does not exist
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - LED	Does not exist
TOILET ROOM - STUDENT	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Does not exist
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - LED	Does not exist
TRANSFORMER	Does not exist
TV SYSTEM	Does not exist