

## 2020 Interagency School Opening Walkthrough Checklist

<b>Bld ID</b>	K625		<b>Visit Date:</b>	8/29/2020
<b>Building Name</b>	ROBESON HS COMP&BUS TC (A HML) - BROOKLYN			
<b>Geo Dist</b>	17			
<b>Address and Directions</b>	150 ALBANY AVENUE, Brooklyn NY- 11213			

**Kitchen AC?** Yes-But Not Operational

K625 (ROBESON HS COMP&BUS TC (A HML) - BROOKLYN)

ROOM #	Primary Usage? (Student-Staff Space/ Building Support Space/ Inaccessible/ Room Not Found)	Windows? (Yes/No)	At least one window can be opened? (Yes/No)	Supply Fan (Operational/ Partially Operational/ Not Operational/ Doesn't Exist/ Cannot Access )	Exhaust Fan (Operational/ Partially Operational/ Not Operational/ Doesn't Exist/ Cannot Access )	Unit Ventilators (Operational/ Partially Operational/ Not Operational/ Doesn't Exist/ Cannot Access )	Comments
103	Student-Staff Space	Yes	Yes	Not Operational	Not Operational	Doesn't Exist	
104	Student-Staff Space	No	No	Not Operational	Not Operational	Doesn't Exist	
105	Student-Staff Space	Yes	Yes	Not Operational	Not Operational	Doesn't Exist	
106	Student-Staff Space	No	No	Not Operational	Not Operational	Doesn't Exist	
107-11	Student-Staff space	Yes	Yes	Not Operational	Not Operational	Doesn't Exist	
108	Student-Staff Space	No	No	Not Operational	Not Operational	Doesn't Exist	
108A	Student-Staff Space	No	No	Doesn't Exist	Not Operational	Doesn't Exist	
110	Student-Staff Space	Yes	Yes	Not Operational	Not Operational	Doesn't Exist	
110E	Student-Staff Space	No	No	Doesn't Exist	Not Operational	Doesn't Exist	
112	Student-Staff Space	Yes	Yes	Not Operational	Not Operational	Doesn't Exist	
113	Student-Staff Space	No	No	Not Operational	Not Operational	Doesn't Exist	
113A	Student-Staff Space	Yes	Yes	Not Operational	Not Operational	Doesn't Exist	
114	Student-Staff Space	Yes	Yes	Not Operational	Not Operational	Doesn't Exist	
114A	Student-Staff Space	No	No	Not Operational	Not Operational	Doesn't Exist	
117	Student-Staff Space	Yes	Yes	Not Operational	Not Operational	Doesn't Exist	
117A	Student-Staff Space	Yes	Yes	Not Operational	Not Operational	Doesn't Exist	
118	Student-Staff Space	No	No	Doesn't Exist	Not Operational	Doesn't Exist	
120	Student-Staff Space	No	No	Doesn't Exist	Not Operational	Doesn't Exist	
129	Student-Staff Space	No	No	Not Operational	Not Operational	Doesn't Exist	
139	Student-Staff Space	Yes	Yes	Not Operational	Not Operational	Doesn't Exist	
139A	Student-Staff Space	No	No	Doesn't Exist	Not Operational	Doesn't Exist	
140	Student-Staff Space	Yes	Yes	Not Operational	Not Operational	Doesn't Exist	
140A	Student-Staff Space	Yes	Yes	Not Operational	Not Operational	Doesn't Exist	
141	Student-Staff Space	Yes	Yes	Not Operational	Not Operational	Doesn't Exist	
141A	Student-Staff Space	No	No	Doesn't Exist	Not Operational	Doesn't Exist	
141B	Student-Staff Space	No	No	Doesn't Exist	Not Operational	Doesn't Exist	
141C	Student-Staff Space	No	No	Doesn't Exist	Not Operational	Doesn't Exist	
142	Student-Staff Space	Yes	Yes	Not Operational	Not Operational	Doesn't Exist	
145	Student-Staff Space	No	No	Not Operational	Doesn't Exist	Doesn't Exist	
145A	Student-Staff Space	Yes	Yes	Not Operational	Not Operational	Doesn't Exist	
146	Student-Staff Space	No	No	Not Operational	Not Operational	Doesn't Exist	
146A	Student-Staff Space	No	No	Doesn't Exist	Doesn't Exist	Doesn't Exist	
146B	Student-Staff Space	No	No	Not Operational	Doesn't Exist	Doesn't Exist	
146C	Student-Staff Space	No	No	Not Operational	Not Operational	Doesn't Exist	
146D	Student-Staff Space	No	No	Not Operational	Not Operational	Doesn't Exist	
146E	Student-Staff Space	No	No	Doesn't Exist	Not Operational	Doesn't Exist	
149/A-B	Student-Staff Space	Yes	Yes	Not Operational	Not Operational	Doesn't Exist	
149A	Student-Staff Space	Yes	Yes	Not Operational	Not Operational	Doesn't Exist	
149B	Student-Staff Space	No	No	Not Operational	Not Operational	Doesn't Exist	
150	Student-Staff Space	No	No	Not Operational	Not Operational	Doesn't Exist	
150A	Student-Staff Space	Yes	Yes	Not Operational	Not Operational	Doesn't Exist	
150B	Student-Staff Space	Yes	Yes	Not Operational	Not Operational	Doesn't Exist	
150C	Student-Staff Space	No	No	Not Operational	Not Operational	Doesn't Exist	
150D	Student-Staff Space	No	No	Not Operational	Not Operational	Doesn't Exist	
150E	Student-Staff Space	Yes	Yes	Not Operational	Not Operational	Doesn't Exist	
150F	Student-Staff Space	No	No	Not Operational	Not Operational	Doesn't Exist	
150H	Student-Staff Space	No	No	Not Operational	Not Operational	Doesn't Exist	
150J	Student-Staff Space	No	No	Not Operational	Not Operational	Doesn't Exist	
166	Student-Staff Space	Yes	Yes	Not Operational	Not Operational	Doesn't Exist	
200	Student-Staff Space	Yes	Yes	Not Operational	Not Operational	Doesn't Exist	
203	Student-Staff Space	Yes	Yes	Not Operational	Not Operational	Doesn't Exist	
204	Student-Staff Space	Yes	Yes	Not Operational	Not Operational	Doesn't Exist	
205	Student-Staff Space	Yes	Yes	Not Operational	Not Operational	Doesn't Exist	
208	Student-Staff Space	Yes	Yes	Not Operational	Not Operational	Doesn't Exist	
208A	Student-Staff Space	No	No	Doesn't Exist	Not Operational	Doesn't Exist	
210	Student-Staff Space	Yes	Yes	Not Operational	Not Operational	Doesn't Exist	
212	Student-Staff Space	Yes	Yes	Not Operational	Not Operational	Doesn't Exist	
213	Student-Staff Space	No	No	Not Operational	Not Operational	Doesn't Exist	
213A	Student-Staff Space	Yes	Yes	Not Operational	Not Operational	Doesn't Exist	
215	Student-Staff Space	Yes	Yes	Not Operational	Not Operational	Doesn't Exist	
217	Student-Staff Space	Yes	Yes	Not Operational	Not Operational	Doesn't Exist	
218	Student-Staff Space	No	No	Doesn't Exist	Not Operational	Doesn't Exist	
220	Student-Staff Space	No	No	Doesn't Exist	Not Operational	Doesn't Exist	
225	Student-Staff Space	Yes	Yes	Not Operational	Not Operational	Doesn't Exist	



ROOM #	Primary Usage? (Student-Staff Space/ Building Support Space/ Inaccessible/ Room Not Found)	Windows? (Yes/No)	At least one window can be opened? (Yes/No)	Supply Fan (Operational/ Partially Operational/ Not Operational/ Doesn't Exist/ Cannot Access )	Exhaust Fan (Operational/ Partially Operational/ Not Operational/ Doesn't Exist/ Cannot Access )	Unit Ventilators (Operational/ Partially Operational/ Not Operational/ Doesn't Exist/ Cannot Access )	Comments
445	Student-Staff Space	No	No	Not Operational	Not Operational	Doesn't Exist	
445A	Student-Staff Space	Yes	Yes	Not Operational	Not Operational	Doesn't Exist	
448	Student-Staff Space	Yes	Yes	Not Operational	Not Operational	Doesn't Exist	
449	Student-Staff Space	Yes	Yes	Not Operational	Not Operational	Doesn't Exist	
450A	Student-Staff Space	Yes	Yes	Not Operational	Not Operational	Doesn't Exist	
450B	Student-Staff Space	Yes	Yes	Not Operational	Not Operational	Doesn't Exist	
B10A	Student-Staff Space	No	No	Not Operational	Not Operational	Doesn't Exist	
B25	Student-Staff Space	Yes	Yes	Not Operational	Not Operational	Doesn't Exist	
B29	Student-Staff Space	No	No	Not Operational	Doesn't Exist	Doesn't Exist	
B29A	Student-Staff Space	No	No	Doesn't Exist	Not Operational	Doesn't Exist	
B29B	Student-Staff Space	No	No	Doesn't Exist	Not Operational	Doesn't Exist	
B30	Student-Staff Space	No	No	Not Operational	Not Operational	Doesn't Exist	
B30A	Student-Staff Space	No	No	Doesn't Exist	Not Operational	Doesn't Exist	
B30B	Student-Staff Space	No	No	Doesn't Exist	Not Operational	Doesn't Exist	
B30C	Student-Staff Space	No	No	Doesn't Exist	Not Operational	Doesn't Exist	
B39	Student-Staff Space	Yes	Yes	Not Operational	Not Operational	Doesn't Exist	
B40	Student-Staff Space	No	No	Doesn't Exist	Not Operational	Doesn't Exist	
B41	Student-Staff Space	Yes	Yes	Not Operational	Doesn't Exist	Doesn't Exist	
B41A	Student-Staff Space	No	No	Doesn't Exist	Not Operational	Doesn't Exist	
B41B	Student-Staff Space	No	No	Doesn't Exist	Not Operational	Doesn't Exist	
B50	Student-Staff Space	Yes	Yes	Doesn't Exist	Not Operational	Doesn't Exist	
B50A	Student-Staff Space	No	No	Doesn't Exist	Not Operational	Doesn't Exist	
B51	Student-Staff Space	Yes	Yes	Not Operational	Not Operational	Doesn't Exist	
B52	Student-Staff Space	No	No	Doesn't Exist	Not Operational	Doesn't Exist	
B52A	Student-Staff Space	No	No	Doesn't Exist	Not Operational	Doesn't Exist	
B64	Student-Staff Space	No	No	Doesn't Exist	Not Operational	Doesn't Exist	
B64A	Student-Staff Space	No	No	Doesn't Exist	Not Operational	Doesn't Exist	
B66	Student-Staff Space	No	No	Doesn't Exist	Not Operational	Doesn't Exist	
B66A	Student-Staff Space	No	No	Doesn't Exist	Not Operational	Doesn't Exist	
B84	Student-Staff Space	No	No	Not Operational	Doesn't Exist	Doesn't Exist	
B90	Student-Staff Space	No	No	Not Operational	Not Operational	Doesn't Exist	
KIT	Student-Staff Space	No	No	Not Operational	Not Operational	Doesn't Exist	
KIT2	Student-Staff Space	No	No	Not Operational	Not Operational	Doesn't Exist	
M2	Student-Staff Space	No	No	Doesn't Exist	Not Operational	Doesn't Exist	
M5	Student-Staff Space	No	No	Doesn't Exist	Not Operational	Doesn't Exist	