

2020 Interagency School Opening Walkthrough Checklist

Bid ID	Q222		Visit Date:	9/8/2020
Building Name	P.S. 222 (ECC) - QUEENS			
Geo Dist	30			
Address and Directions	86-15 37TH AVENUE, Queens NY- 11372			

Kitchen AC?	Yes & Operational	Q222 (P.S. 222 (ECC) - QUEENS)
--------------------	-------------------	--------------------------------

ROOM #	Primary Usage? (Student-Staff Space/ Building Support Space/ Inaccessible/ Room Not Found)	Windows? (Yes/No)	At least one window can be opened? (Yes/No)	Supply Fan (Operational/ Partially Operational/ Not Operational/ Doesn't Exist/ Cannot Access)	Exhaust Fan (Operational/ Partially Operational/ Not Operational/ Doesn't Exist/ Cannot Access)	Unit Ventilators (Operational/ Partially Operational/ Not Operational/ Doesn't Exist/ Cannot Access)	Comments
101A	Student-Staff Space	No	No	Doesn't Exist	Not Operational	Doesn't Exist	
103	Student-Staff Space	No	No	Doesn't Exist	Not Operational	Doesn't Exist	
104A	Student-Staff Space	No	No	Doesn't Exist	Operational	Doesn't Exist	
104B	Student-Staff Space	No	No	Doesn't Exist	Operational	Doesn't Exist	
111A	Student-Staff Space	Yes	Yes	Operational	Operational	Doesn't Exist	
111B	Student-Staff Space	No	No	Doesn't Exist	Operational	Doesn't Exist	
201	Student-Staff Space	Yes	Yes	Operational	Operational	Doesn't Exist	
201A/203A	Student-Staff Space	No	No	Doesn't Exist	Operational	Doesn't Exist	
202	Student-Staff Space	Yes	Yes	Operational	Operational	Doesn't Exist	
202A/204A	Student-Staff Space	No	No	Doesn't Exist	Operational	Doesn't Exist	
203	Student-Staff Space	Yes	Yes	Operational	Operational	Doesn't Exist	
205A	Student-Staff Space	No	No	Doesn't Exist	Operational	Doesn't Exist	
301	Student-Staff Space	Yes	Yes	Operational	Operational	Doesn't Exist	
301A/303A	Student-Staff Space	No	No	Doesn't Exist	Operational	Doesn't Exist	
302	Student-Staff Space	Yes	Yes	Operational	Partially Operational	Doesn't Exist	1 out of 3 Exhaust Not Operational
302A	Student-Staff Space	No	No	Doesn't Exist	Operational	Doesn't Exist	
303	Student-Staff Space	Yes	Yes	Operational	Operational	Doesn't Exist	
304	Student-Staff Space	No	No	Doesn't Exist	Operational	Doesn't Exist	
306	Student-Staff Space	Yes	Yes	Operational	Partially Operational	Doesn't Exist	2 out of 4 Exhaust Not Operational
306A	Student-Staff Space	No	No	Doesn't Exist	Operational	Doesn't Exist	
307	Student-Staff Space	Yes	Yes	Operational	Operational	Doesn't Exist	
308	Student-Staff Space	No	No	Doesn't Exist	Operational	Doesn't Exist	
402	Student-Staff Space	Yes	Yes	Operational	Operational	Doesn't Exist	
402A	Student-Staff Space	No	No	Doesn't Exist	Operational	Doesn't Exist	
403	Student-Staff Space	Yes	Yes	Operational	Operational	Doesn't Exist	
403A	Student-Staff Space	No	No	Doesn't Exist	Operational	Doesn't Exist	
404	Student-Staff Space	No	No	Doesn't Exist	Operational	Doesn't Exist	
405	Student-Staff Space	Yes	Yes	Operational	Operational	Doesn't Exist	
405A	Student-Staff Space	No	No	Doesn't Exist	Operational	Doesn't Exist	
406	Student-Staff Space	Yes	Yes	Operational	Partially Operational	Doesn't Exist	1 out of 3 Exhaust Not Operational
406A	Student-Staff Space	No	No	Doesn't Exist	Operational	Doesn't Exist	
407	Student-Staff Space	Yes	Yes	Operational	Operational	Doesn't Exist	
407A	Student-Staff Space	No	No	Doesn't Exist	Operational	Doesn't Exist	
408	Student-Staff Space	Yes	Yes	Operational	Partially Operational	Doesn't Exist	1 out of 3 Exhaust Not Operational
408A	Student-Staff Space	No	No	Doesn't Exist	Operational	Doesn't Exist	
C06B	Student-Staff Space	No	No	Operational	Operational	Doesn't Exist	
C06C	Student-Staff Space	No	No	Operational	Operational	Doesn't Exist	
C10	Student-Staff Space	No	No	Operational	Operational	Doesn't Exist	
C15	Student-Staff Space	No	No	Doesn't Exist	Operational	Doesn't Exist	